

MAHARASHTRA STATE ELECTRICITY TRANSMISSION COMPANY LTD.

Maharashtra State Load Despatch Centre, Kalwa

To,
Hon. Energy Minister/ Chief Secretary/ Energy Secretary.
Maharashtra State, Mumbai.

Sub: Report of the Power System position for the period

21-Dec-09

To

27-Dec-09

Date	Monday 21-Dec-09	Tuesday 22-Dec-09	Wednesday 23-Dec-09	Thursday 24-Dec-09	Friday 25-Dec-09	Saturday 26-Dec-09	Sunday 27-Dec-09
On Line Capacity							
MSPGCL THM	5458	5301	5606	5338	5503	5469	5533
MSPGCL HY	1150	1135	1263	1263	1264	1254	1265
MSPGCL GAS	650	630	620	640	470	650	580
MSPGCL TOTAL	7258	7066	7489	7241	7237	7373	7378
Cent. Sect.	2933	3105	3063	3060	2972	3151	3018
MSPGCL + CS	10191	10171	10552	10301	10209	10524	10396
TPCL	1777	1827	1857	1877	1877	1777	1777
REL	500	500	500	500	500	500	500
TPCL + REL	2277	2327	2357	2377	2377	2277	2277
RGPPL	580	300	600	900	895	900	900
STATE OLC	13048	12798	13509	13578	13481	13701	13573
Morning Peak Demand (MW)	12 Hrs	11 Hrs	12 Hrs	12 Hrs	12 Hrs	12 Hrs	12 Hrs
MSPGCL THM	4973	5271	5193	5194	5425	5234	5224
MSPGCL HY	343	615	333	333	167	618	229
MSPGCL GAS	630	640	608	637	409	654	599
MSPGCL TOTAL	5946	6526	6134	6164	6001	6506	6052
Cent. Sect.	4010	3706	4021	3538	3378	3530	3819
RGPPL Gen	635	340	619	875	875	961	958
TPCL Asst	-286	-259	-262	-283	-95	-215	-24
MSEDCL Ctrd	10616	10719	10662	10457	10230	10817	10895
Load Shedding	3134	3210	3173	3297	3205	3267	3331
MSEDCL Demand	13750	13929	13835	13754	13435	14084	14226
TPCL + REL Dem.	2518	2419	2441	2386	1988	2064	1635
State Demand	16268	16348	16276	16140	15423	16148	15861
Sys. Freq. (Hz)	49.8	49.82	49.65	49.68	49.63	49.45	49.56
Evening Peak Demand (MW)	19 Hrs	20 Hrs	19 Hrs	20 Hrs	19 Hrs	20 Hrs	20 Hrs
MSPGCL THM	5015	5418	5282	5454	5411	5471	5417
MSPGCL HY	680	448	928	336	668	260	559
MSPGCL GAS	632	652	654	659	575	607	604
MSPGCL TOTAL	6327	6518	6864	6449	6654	6338	6580
Cent. Sect.	4397	4420	3845	3965	3415	4089	3310
RGPPL Gen	637	338	859	623	946	962	963
TPCL Asst	-295	-289	-304	-293	-172	-302	-94
MSEDCL Ctrd	11258	11140	11415	10945	10930	11133	10847
Load Shedding	3396	3462	3335	3690	3318	3513	3611
MSEDCL Demand	14654	14602	14750	14635	14248	14646	14458
TPCL + REL Dem.	2508	2473	2471	2403	2050	2118	1814
State Demand	17162	17075	17221	17038	16298	16764	16272
Sys. Freq. (Hz)	49.8	49.63	49.9	49.66	49.79	49.67	49.86

Copy s.w.rs to : M.D. (MSETCL) / Director (OP), MSETCL, Mumbai.

Copy s.w.rs to : C.E. (LM), MSEDCL, Mumbai.

Chief Engineer
MSLDC, Kalwa