

Maharashtra State Load Despatch Centre												
WRPC OCCM approved Monthly Outage list for the Month of February'2019												
Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
1	39	400	NAGOTHANE - DABHOL 1	01/Feb/19	08:00	08/Feb/19	18:00	Daily	LE Scheme for insulator string replacement & Cold washing insulators	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-II line
2	40	400	Kalwa-Padgha Ckt.-2	01/Feb/19	9:00	09/Feb/19	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-2 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
3	42	400	BABLESHWAR- AURANGABAD (WALU) ON TBC @ BABHALESHWAR	01/Feb/19	09:00	10/Feb/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	Line will be in service through TBC for Repairing of 29A & 29B P.G Isolator, Scissors (Hanger dropper assembly of Aurangabad bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
4	43	400	Kalwa-Padgha Ckt.-2	01/Feb/19	9:00	05/Feb/19	18:00	Continuous	1) Dismantling of conductor at loc. No. 1103 to 1106 2) Tower erection at loc. No. 1104 to 1105 3) Dismantling of Tower existing Loc.No.1104 4) Stringing of conductor at Loc.No. 1103 to 1106	MSETCL	MSETCL	
5	44	400	BABHALESHWAR - PADGHE 1	01/Feb/19	08:00	13/Feb/19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	Require A/R out of service
6	50	400	Dabhol-Nagothane Line-1 equipment's.	01/Feb/19	9:00	07/Feb/19	18:00	Daily	Main bkr (406-52 A) overhauling & equipment testing works.	RGPPPL	RGPPPL	R
7	51	400	NEW KOYNA-KARAD - D/C Permission for A/R to be kept OFF	01/Feb/19	09:00	28/Feb/19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	
8	61	400	400 KV SSNL-Dhule-1 with Auto reclose out in SSP - Dhule - 1	02/Feb/19	8:00	02/Feb/19	18:00	Daily	PMM work	NCA	GETCO	
9	68	400	400KV KORADI-SATPURA	02/Feb/19	9:00	02/Feb/19	18:00	Daily	For Replacement of B phase CVT at Kodari end & Line AMP works.	WRTS-I	WRTS-I	R
10	71	400	MAIN BUS - 1 @ KORADI - 2	02/Feb/19	10:00	02/Feb/19	15:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to 400KV Main Bus-II (One & Half Breaker System)
11	83	220	PGCIL Line No.1 at 220KV Boisar-II Stsn.	03/Feb/19	7:00	03/Feb/19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
12	88	765	BUS - 1 @ TIRODA	03/Feb/19	08:00	03/Feb/19	21:00	Daily	Testing and Maintenance of Bus Connected Isolator and CVT	APML	APML	Testing and Maintenance of Bus Connected Isolator and CVT
13	95	400	MAIN BUS - 2 @ KORADI 2	04/Feb/19	10:00	04/Feb/19	15:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to 400KV Main Bus-I (One & Half Breaker System)
14	99	400	SSP - Dhule - 2 with auto reclose out of Dhule - 1	04/Feb/19	8:00	04/Feb/19	18:00	Daily	PMM work	NCA	GETCO	Non auto reclose code for 400kv SSP- Dhule No. 1 is to be required.
15	126	400	KHADKA- DEEPNAGAR D/C	04/Feb/19	06:00	05/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400KV Khadka Deepnagar ckt 1&2 A/R in non auto mode
16	127	400	DHULE - SSNNL I & II	04/Feb/19	08:00	05/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kv SSNNL-1&2 A/R switch to be kept on non-auto mode
17	142	765	Akola II-Ektuni Line1	05/Feb/19	08:00	05/Feb/19	18:00	Daily	Annual Maintenance of Line	MEGPTCL	MEGPTCL	Annual Maintenance of Line
18	152	400	CHANDRAPUR 2 - WARORA CKT-2	05/Feb/19	08:00	05/Feb/19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
19	189	400	BUS COUPLER @ BABHALESHWAR	05/Feb/19	09:00	06/Feb/19	17:00	Continuous	Quarterly Maintenance work & Repair of scissors of 400KV P.G Isolator, Servicing and alignment of isolators	MSETCL	MSETCL	Bus will be separated to work in minimum time on 400kv bus coupler Outage, outage taken on 400KV Auraganabad on TBC is taken as per the schedule of the outage.
20	194	400	GTR - 6 @ CHANDRAPUR (On TBC)	05/Feb/19	09:00	08/Feb/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Pumatic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay.
21	200	765	Akola II-Ektuni Line2	06/Feb/19	08:00	06/Feb/19	18:00	Daily	Annual Maintenance of Line	MEGPTCL	MEGPTCL	Annual Maintenance of Line
22	209	400	CHANDRAPUR 2 - WARORA CKT-1	06/Feb/19	08:00	06/Feb/19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
23	212	132	MANSAR-PENCH	06/Feb/19	09:00	06/Feb/19	17:00	Daily	Replacement of jumper	MSETCL	MSETCL	Outage will be taken subject to wheather condition
24	218	220	220KV Boisar-Boisar-III line at Boisar	06/Feb/19	9:00	06/Feb/19	17:30	Daily	Line Equipment AMP	POWER GRID	WR-II	R
25	223	400	MAIN BUS - 1 @ KHAPARKHEDA	06/Feb/19	09:00	06/Feb/19	18:00	Daily	Diagonastic testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
26	228	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) I	06/Feb/19	9:00	06/Feb/19	18:00	Daily	For AMP works. Other Ckt-2, & Parli-1 & 2 A/R to kept in Non-Auto mode.	WRTS-I	WRTS-I	R
27	234	400	400 KV KARAD - SOLAPUR (PG) (Karad end)	06/Feb/19	10:00	06/Feb/19	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load managed on other Ckt.
28	235	765	Main bay 713 of 1500MVA ICT 2 @ 765kv Ektuni	06/Feb/19	10:00	06/Feb/19	18:00	Daily	CB Timing & DCRM Testing	MSETCL	MSETCL	765/400kv ICT 2 will be in service through ICT 1 (712) bay & Main Bus-I
29	236	400	PARLI-SOLAPUR (LAMBOTI)	06/Feb/19	10:00	06/Feb/19	18:00	Daily	Hardware Tightting and Fitting work of line & bay maintenance work	MSETCL	MSETCL	-
30	242	220	KALMESHVAR-PANDHURNA	06/Feb/19	08:00	07/Feb/19	18:00	Daily	Restranging of bottom ph conductor and Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Work will be carried out subject to wheather condition
31	253	400	TIE BAY (426) OF WARORA CKT - 2 @ CHANDRAPUR 2	07/Feb/19	09:00	07/Feb/19	18:00	Daily	Routine Maintenance & Diagnostic testing works	MSETCL	MSETCL	Routine Maintenance & Diagnostic testing works
32	256	400	MAIN BAY (406) OF PGCIL @ LAMBOTI	07/Feb/19	10:00	07/Feb/19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400KV Lamboti-Parali Line

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
33	258	765	Koradi-III - Akola-II Ckt-1	07/Feb/19	08:00	07/Feb/19	18:00	Daily	Annual Maintenance of Line	MEGPTCL	MEGPTCL	Annual Maintenance of Line
34	264	220	220KV Boisar-Boisar-I line at Boisar	07/Feb/19	9:00	07/Feb/19	17:30	Daily	Line Equipment AMP	POWER GRID	WR-II	R
35	267	400	PARLI - KUMBHARGAON(NANDED) CKT - 2	07/Feb/19	09:00	07/Feb/19	18:00	Daily	CB DCRM & Timing test & Bay maintenance work	MSETCL	MSETCL	-
36	276	765	Main bay 710 of 1500MVA ICT 1@ 765kv Ektuni	07/Feb/19	10:00	07/Feb/19	18:00	Daily	CB Timing & DCRM Testing	MSETCL	MSETCL	765/400KV ICT-1 will be in service through this tie (709) Bay & Main Bus-I
37	285	400	400KV SSP- Dhule-1 Line	07/Feb/19	8:00	08/Feb/19	21:00	Continuous	Relay Testing of Protection Panel- Main-1 & Main-2 with help of M/S. ABB Bangalore Engineer.	SSNNL	NCA	R
38	289	400	400kv WARDHA-AKOLA II	07/Feb/19	9:00	07/Feb/19	18:00	Daily	For Replacement of BCU CPU Card for SCADA upgradation & Line AMP Other ckt A/R to be kept in Non-Auto mode.	WRTS-I	WRTS-I	R
39	291	400	220kv Boisar-Nalasopara line at Boisar (Bay No. 203)	08/Feb/19	14:00	08/Feb/19	19:00	Daily	For tripping and A/R Trials of Main-I relay (Line outage required)	POWERGRID	WR-II	R
40	292	400	TIE BAY (408) OF WARORA CKT - 2 @ TIRORA	08/Feb/19	09:00	08/Feb/19	18:00	Daily	Testing & Maintenance of bay breaker & CT	ATIL	ATIL	Testing & Maintenance of bay breaker & CT
41	301	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	08/Feb/19	09:00	08/Feb/19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400 kv Lonikand-II - Lonikand-I interconnector I, load effected NIL
42	306	400	400kv WARDHA-AKOLA I	08/Feb/19	9:00	08/Feb/19	18:00	Daily	For Replacement of BCU CPU Card for SCADA upgradation & Line AMP Other ckt A/R to be kept in Non-Auto mode.	WRTS-I	WRTS-I	R
43	308	765	Koradi-III - Akola-II Ckt-2	08/Feb/19	08:00	08/Feb/19	18:00	Daily	Annual Maintenance of Line	MEGPTCL	MEGPTCL	Annual Maintenance of Line
44	309	400	BUS COUPLER @ KHARGHAR	08/Feb/19	08:00	08/Feb/19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Nil
45	319	400	MAIN BAY (406) OF NANDED CKT - 1 @ CHANDRAPUR 2	08/Feb/19	09:00	08/Feb/19	18:00	Daily	Routine Maintenance & Diagnostic testing works	MSETCL	MSETCL	Routine Maintenance & Diagnostic testing works
46	335	400	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	08/Feb/19	08:00	10/Feb/19	18:00	Continuous	Diagnostic Testing Work & oil filtration R & B phase	MSETCL	MSETCL	220kv Temghar-1&2 line will remain Handtripped during outage
47	338	400	NAGOTHANE - DABHOL 2	09/Feb/19	08:00	09/Feb/19	17:00	Daily	tree cutting	MSETCL	MSETCL	Nil
48	340	400	MAIN BUS - 1 @ AKOLA	09/Feb/19	08:00	09/Feb/19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
49	351	220	MAHALAXMI - AMONA	09/Feb/19	09:00	09/Feb/19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	-
50	360	400	MAIN BAY-422 OF STATION TF - 1 @ KORADI - 2	09/Feb/19	10:00	09/Feb/19	17:00	Daily	DCRM, IR ,Timing Measurement of CB 422-Q52	MSETCL	MSETCL	Station Transformer-I will remain in service through Tie Bay 423.
51	374	400	NEW KOYNA - DABHOL - II	10/Feb/19	08:00	16/Feb/19	18:00	Daily	IE Scheme for insulator string replacement & Cold washing insulators	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-I line
52	380	400	CHANDRAPUR-PARLI CKT-3	10/Feb/19	07:00	10/Feb/19	19:00	Daily	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .	MSETCL	MSETCL	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .
53	381	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	10/Feb/19	08:00	10/Feb/19	17:00	Daily	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .	MSETCL	MSETCL	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .
54	393	220	MUDSHINGI - CHIKODI	11/Feb/19	09:00	11/Feb/19	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
55	394	220	TILARI - AMONA LINE	11/Feb/19	09:00	11/Feb/19	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
56	398	400	TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	11/Feb/19	09:00	11/Feb/19	18:00	Daily	Bay equipment Maintenance Activity	MEGPTCL	MEGPTCL	Bay equipment Maintenance Activity
57	405	400	KOLHAPUR (TALANDGE) - ALKUD	11/Feb/19	09:30	11/Feb/19	17:30	Daily	Quarterly Maint. Work	MSETCL	MSETCL	NA
58	410	765	TIE BAY - 709 OF 765/400KV ICT-1 @ EKTUNI	11/Feb/19	10:00	11/Feb/19	18:00	Daily	CB Timing & DCRM Testing	MSETCL	MSETCL	765/400KV ICT-1 will be in service through this main (710) Bay & Main Bus-II
59	415	400	DHULE - SSNNL D/C	11/Feb/19	08:00	12/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kv SSNNL-1&2 A/R switch to be kept on non-auto mode
60	422	400	Dabhol - New Koyna line 2 equipment's.	11/Feb/19	9:00	14/Feb/19	18:00	Daily	PM & equipment testing works	RGPP	RGPP	R
61	423	400	400KV KORADI-BHUSAWAL (Bhusawal end)	11/Feb/19	08:00	15/Feb/19	18:00	Continuous	Restranging of conductor of all three phases of Koradi-Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kv Akola - Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
62	426	400	CHANDRAPUR - KHAPERKHEDA ON TBC @ CHANDRAPUR	11/Feb/19	09:00	16/Feb/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Pumatic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-I bay.
63	427	400	Kalwa-Padgha Ckt.-1	11/Feb/19	9:00	16/Feb/19	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-1 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
64	434	400	KALWA-KHARGHAR	11/Feb/19	9:00	20/Feb/19	19:00	Continuous	1) Dismantling of conductor at loc. No. 170 to 172 2) Tower erection at loc. No. 170 to 172 3) Dismantling of Tower existing Loc.No.172 4) Stringing of conductor at Loc.No. 170 to 172			

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
65	436	400	KALWA-KHARGHAR & KALWA - TALEGAON	11/Feb/19	9:00	20/Feb/19	19:00	Continuous	1) Dismantling of conductor at loc. No. 170 to 172 2) Tower erection at loc. No. 170 to 172 3) Dismantling of Tower existing Loc.No.172 4) Stringing of conductor at Loc.No. 170 to 172	MSETCL	MSETCL	
66	451	400	DHULE - SSNNL I & A/R OF DHULE SSNNL-2 to be kept on non-auto mode	12/Feb/19	08:00	12/Feb/19	18:00	Daily	Jumper tightening at various loc.	MSETCL	MSETCL	400KV SSNNL-2 A/R switch to be kept on non-auto mode
67	455	400	BABHALESHWAR - PADGHE 2	12/Feb/19	09:00	12/Feb/19	17:00	Daily	Quarterly Maintenance work, Servicing and alignment of PG isolators	MSETCL	MSETCL	400kv Babhaleshwar-Padghe-Ckt-1 will be in service
68	463	765	TIE BAY (705) OF KORADI 3 CKT - 2 & BUS REACTOR @ TIRORA	12/Feb/19	09:00	12/Feb/19	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	-
69	476	765	TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	12/Feb/19	10:00	12/Feb/19	18:00	Daily	CB Timing & DCRM Testing	MSETCL	MSETCL	765KV EKTUNI-AKOLA ckt-1 will be in service through its main (705) Bay & Main Bus-II
70	482	220	TAPS-3&4 - Boisar line	12/Feb/19	9:00	13/Feb/19	18:00	Continuous	CB, ES, DS, LA, CT, LA, WT, CVT Annual PM	POWERGRID	NPCIL	
71	496	400	DHULE - SSNNL II AND A/R OF DHULE - SSNNL-1 to be kept on non-auto mode	13/Feb/19	08:00	13/Feb/19	18:00	Daily	Jumper tightening at various loc.	MSETCL	MSETCL	400KV SSNNL-1 A/R switch to be kept on non-auto mode
72	499	400	MAIN BAY (429) OF WARORA-WARDHA(PG) @400 KV WARDHA(PG)	13/Feb/19	09:00	13/Feb/19	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .	MSETCL	MSETCL	Line will be charged through Tie CB 428.
73	500	132	KANHAN-PENCH	13/Feb/19	09:00	13/Feb/19	17:00	Daily	Replacement of jumper	MSETCL	MSETCL	outage to be availed subject to wheather condition
74	503	765	MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	13/Feb/19	09:00	13/Feb/19	18:00	Daily	Bay Equipment Maintenance Activity	MEGPTCL	MEGPTCL	Bay Equipment Maintenance Activity
75	526	400	BUS REACTOR_400kv_80MVAR_KOLHAPUR	13/Feb/19	10:00	13/Feb/19	18:00	Daily	For AMP works.	WRTS-I	WRTS-I	R
76	528	220	TALEGAON (AMBI)-TALEGAON (PG) CKT 2	14/Feb/19	09:00	14/Feb/19	18:00	Daily	Cu palm replacement by Al Palm	MSETCL	MSETCL	-
77	535	765	TIE BAY - 702 OF EKTUNI-AKOLA II ckt-2 @ EKTUNI	14/Feb/19	10:00	14/Feb/19	18:00	Daily	CB Timing & DCRM Testing	MSETCL	MSETCL	765KV EKTUNI-AKOLA ckt-2 will be in service through its main (702) Bay & Main Bus-II
78	544	400	KOLHAPUR - KOLHAPUR (PG) CKT - 1	14/Feb/19	09:00	14/Feb/19	18:00	Daily	C Bus Isolator Alignment and Quarterly Maintenance work	POWERGRID	MSETCL	-
79	545	400	MAIN BAY (414) OF TIRODA CKT - 2 @ WARORA	14/Feb/19	09:00	14/Feb/19	18:00	Daily	Testing & Maintenance of bay breaker & CT	ATIL	ATIL	Testing & Maintenance of bay breaker & CT
80	553	400	KALWA - KHARGHAR	14/Feb/19	09:30	14/Feb/19	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	Bay Maintenance & testing work.
81	556	765	BUS REACTOR (240 MVAR) @ EKTUNI	14/Feb/19	10:00	14/Feb/19	18:00	Daily	Routine Maintain & Diagnostic Testing	MSETCL	MSETCL	Bus Reactor will be out of service
82	562	400	BABHALESHWAR - PADGHE 2	14/Feb/19	08:00	22/Feb/19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	require A/R out of service only
83	570	220	BOISER- (PGCIL) - Nalasopara Line	15/Feb/19	7:00	15/Feb/19	18:00	Daily	Replacement of insulators & Diagnostic testing works	MSETCL	MSETCL	
84	572	400	AKOLA - WARDHA(PG) CKT - 1	15/Feb/19	08:00	15/Feb/19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
85	576	220	(nashik) EKLAHARA-(OCR)-NAVASARI I	15/Feb/19	09:00	15/Feb/19	14:00	Daily	Maintenance work	MSETCL	MSETCL	-
86	577	400	KOLHAPUR - KOLHAPUR (PG) CKT - 2	15/Feb/19	09:00	15/Feb/19	17:00	Daily	Quarterly Maintenance work	POWERGRID	MSETCL	-
87	578	400	KORADI 2-WARDHA PGCIL	15/Feb/19	09:00	15/Feb/19	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400KV WARORA-IEPL Line is in ckt
88	584	765	704 LR (Aurangabad-ckt-I) Reactor @ AKOLA 2	15/Feb/19	09:00	15/Feb/19	18:00	Daily	Reactor & Reactor Bay equipment maintenance activity	MEGPTCL	MEGPTCL	Reactor & Reactor Bay equipment maintenance activity
89	598	220	SHENDRA-CHITTEPIMPALGAON(PGCIL) 1	15/Feb/19	10:00	15/Feb/19	18:00	Daily	Maintenance Work	MSETCL	MSETCL	Maintenance Work
90	605	400	CHANDRAPUR-PARLI CKT-3	15/Feb/19	08:00	28/Feb/19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
91	606	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	15/Feb/19	08:00	28/Feb/19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
92	607	400	NAGOTHANE - DABHOL 2	15/Feb/19	08:00	16/Feb/19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-I line
93	610	400	400 KV D/C Parli - Pune (GIS)	16/Feb/19	8:00	17/Feb/19	20:00	Daily	Power line crossing of 400 KV D/C Parli - Pune at tower loc. no. 658 & 659 by 765 KV D/C LILO Aurangabad - Padghe Line	WTPCL	CWRTL	C
94	617	220	EKALAHARA(OCR)-NAVASARI II	16/Feb/19	09:00	16/Feb/19	15:00	Daily	Maintenance work	MSETCL	MSETCL	-
95	633	400	NAGOTHANE - DABHOL 1	17/Feb/19	08:00	17/Feb/19	17:00	Daily	emergency tree cutting	MSETCL	MSETCL	...
96	637	220	PGCIL Line No.3 at 220KV Boisar-II Stsn.	17/Feb/19	7:00	17/Feb/19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
97	640	220	TALEGAON (AMBI)-TALEGAON (PG) CKT 1	17/Feb/19	09:00	17/Feb/19	18:00	Daily	Cu palm replacement by Al Palm	MSETCL	MSETCL	-
98	651	400	Dabhol - New Koyna line 1 equipment's.	18/Feb/19	9:00	24/Feb/19	18:00	Daily	PM ,testing & 400 kv insulator string to be changed.	RGPPCL	RGPPCL	R
99	659	220	TALANDAGE - CHIKODI	18/Feb/19	09:00	18/Feb/19	17:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	-
100	661	765	BUS - II @ KORADI - 3	18/Feb/19	09:00	18/Feb/19	18:00	Daily	Testing & Maintenance of Bus related equipment	MEGPTCL	MEGPTCL	Testing & Maintenance of Bus related equipment
101	662	765	TIE BAY (708) OF KORADI 3 CKT - 1 & GENERATING UNIT - 5 @ TIRORA	18/Feb/19	09:00	18/Feb/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	--

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
102	673	400	400kV Solapur Main bay at Kolhapur (MSETCL)	18/Feb/19	10:00	18/Feb/19	18:00	Daily	For AMP works.	WRTS-I	WRTS-I	R
103	674	400	KHADKA- DEEPNAGAR D/ C	18/Feb/19	06:00	19/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kV Khadka Deepnagar ckt 1&2 A/R in non auto mode
104	677	400	NEW KOYNA - DABHOL - I	18/Feb/19	08:00	19/Feb/19	18:00	Daily	Cold washing & replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-II line
105	678	400	DHULE- - BABLESHWAR -D/C	18/Feb/19	08:00	19/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kV BBLR-1&2 A/R switch to be kept on non-auto mode
106	687	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	18/Feb/19	08:00	22/Feb/19	18:00	Continuous	Restranging of conductor of all three phases of Akola- Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
107	688	400	TBC @ BABHALESHWAR	18/Feb/19	09:00	22/Feb/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kv TBC Bay is for Repairing of 29A & 29B & 29C P.G Isoaltor P.G Isolator Scissors (Hanger dropper assembly of TBC bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
108	691	400	Kalwa-Talegaon & Kalwa-Kharghar Line	18/Feb/19	9:00	23/Feb/19	18:00	Daily	PID Testing work of 400 KV Kalwa-Talegaon & 400KV Kalwa-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
109	730	400	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	20/Feb/19	08:00	20/Feb/19	17:00	Daily	Routine maintainance and diagnostic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
110	737	765	TIE BAY (702) OF ICT-1 & FUTURE BAY @ KORADI 3	20/Feb/19	09:00	20/Feb/19	18:00	Daily	Testing & Maintenance of Bay breaker & CT.	MEGPTCL	MEGPTCL	Testing & Maintenance of Bay breaker & CT.
111	756	400	Dabhol-Nagothane Line-2 equipment's.	20/Feb/19	9:00	23/Feb/19	18:00	Daily	PM & equipment testing works	RGPPL	RGPPL	R
112	758	400	GTR - 4 @ CHANDRAPUR ON TBC	20/Feb/19	09:00	25/Feb/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Puematic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-I bay
113	763	400	MAIN BUS - 1 @ CHANDRAPUR SWICHING SS	21/Feb/19	09:00	21/Feb/19	18:00	Daily	Routine Maintenance & Diagnostic testing works	MSETCL	MSETCL	Routine Maintenance & Diagnostic testing works
114	778	400	CHAKAN - TALEGAON(PG)	21/Feb/19	09:00	21/Feb/19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
115	800	765	765KV AURANGABAD(PG)-PADGHE(GIS) I	21/Feb/19	10:00	27/Feb/19	18:00	Continuous.	For attending SF6 gas leakage in chamber of R-PH line & Insulator replacement work in Otar and Madh section of A'bad Line 1, at Padghe Dia shall be open condition Ckt-2 A/R-keep in Non-auto mode.	WRTS-I	WRTS-I	R
116	803	400	PARLI - LONIKAND 2 CKT 1	22/Feb/19	10:00	22/Feb/19	18:00	Daily	Hardware Tightening and Fitting work of line & bay maintenance work	MSETCL	MSETCL	-
117	804	400	EKTUNI - BABLESHWAR CKT 1	22/Feb/19	09:00	22/Feb/19	17:00	Daily	Quarterly Maintenance work, Servicing and alignment of PG isolators	MSETCL	MSETCL	400 kv Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
118	811	400	PARLI - LONIKAND 2 CKT 2	22/Feb/19	09:00	22/Feb/19	18:00	Daily	Distance relay testing work, Hardware Tightening and Fitting work, bay maintenance work.	MSETCL	MSETCL	-
119	832	220	SHENDRA-CHITTEPIMPALGAON(PGCIL) 2	22/Feb/19	10:00	22/Feb/19	18:00	Daily	Maintenance Work	MSETCL	MSETCL	Maintenance Work
120	839	400	BABHALESHWAR - PADGHE 1	23/Feb/19	09:00	23/Feb/19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators	MSETCL	MSETCL	400kV Babhaleshwar-Padghe-Ckt-2 will be in service
121	840	400	MAIN BUS - 2 @ AKOLA	23/Feb/19	08:00	23/Feb/19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
122	845	400	KORADI 2-WARDHA PGCIL	23/Feb/19	08:00	23/Feb/19	18:00	Daily	Refixing of jumper nut bolts on jumper & conductor hardware at various locations.	MSETCL	MSETCL	outage will be availed subject to wheather condition.
123	846	400	KHARGHAR - TALEGAON (PG)	23/Feb/19	08:00	23/Feb/19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Nil
124	848	220	220KV Pandhurna-Kamleshwar	23/Feb/19	9:00	23/Feb/19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
125	861	400	BUS COUPLER @ NEW KOYNA	24/Feb/19	08:00	24/Feb/19	18:00	Daily	Routine maintenance, diagnostic testing and relay testing	MSETCL	MSETCL	Bus load will be managed
126	862	400	MAIN BUS - 2 @ CHANDRAPUR SWICHING SS	24/Feb/19	09:00	24/Feb/19	18:00	Daily	Routine Maintenance & Diagnostic testing works	MSETCL	MSETCL	Routine Maintenance & Diagnostic testing works
127	863	400	Kalwa-Padghe Ckt.-1	24/Feb/19	8:00	24/Feb/19	18:00	Daily	Routine Maintenance	MSETCL	MSETCL	
128	874	400	EKTUNI - BABLESHWAR CKT 2	25/Feb/19	09:00	25/Feb/19	17:00	Daily	Quarterly Maintenance work, Servicing and alignment of PG isolators	MSETCL	MSETCL	400 kv Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-1 will be in service
129	878	400	MAIN BUS - 1 @ TIRORA	25/Feb/19	08:00	25/Feb/19	21:00	Daily	Testing and Maintenance of bus connected isolator and CVT	APML	APML	Testing and Maintenance of bus connected isolator and CVT
130	880	400	KALWA - TALEGAON (PGCIL)	25/Feb/19	09:30	25/Feb/19	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	Bay Maintenance & testing work.
131	908	400	DHULE- - BABLESHWAR - D/C	25/Feb/19	08:00	26/Feb/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kV BBLR-1&2 A/R switch to be kept on non-auto mode
132	915	400	Kalwa-Talegaon & Kharghar-Talegaon Line	25/Feb/19	9:00	28/Feb/19	18:00	Daily	PID Testing work of 400 KV Kalwa-Talegaon & 400KV Kharghar-Talegaon (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
133	922	765	707 LR (TIRODA CKT - 2) REACTOR @ KORADI 3	26/Feb/19	09:00	26/Feb/19	16:00	Daily	Reactor & Reactor bay equipments Maintenance activity	MEGPTCL	MEGPTCL	Reactor & Reactor bay equipments Maintenance activity
134	949	400	MAIN BUS - 1 @ WARORA	26/Feb/19	08:00	26/Feb/19	18:00	Daily	Routine maintainance and diagnostic testing such as CVT/ CT tandelta,and ,isolater maintainance work	MSETCL	MSETCL	400KV MAIN BUS-2 WILL BE IN SERVICE

Sr. No	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
135	962	400KV	Solapur - Kolhapur Circuit - I (Solapur - Alkud)	27/Feb/19	8:00	27/Feb/19	16:00	Daily	Annual Maintenance work	WTPL	WTPL	R
136	966	220	220 KV Navsari-Nashik line No. 1	27/Feb/19	9:00	27/Feb/19	17:00	Daily	General bay maint.	GETCO	GETCO	
137	970	400	MAIN BUS - 1 @ KORADI	27/Feb/19	09:00	27/Feb/19	18:00	Daily	Cutting of 400KV Khaperkheda 1& 2 old jumper to avoid any Bus fault in future	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
138	994	400KV	Solapur - Kolhapur Circuit - II	28/Feb/19	8:00	28/Feb/19	16:00	Daily	Annual Maintenance work	WTPL	WTPL	R
139	1004	220	220 KV Navsari-Nashik line no.2	28/Feb/19	9:00	28/Feb/19	17:00	Daily	General bay maint.	GETCO	GETCO	
140	1007	765	MAIN BAY (706) OF BUS REACTOR @ KORADI 3	28/Feb/19	09:00	28/Feb/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	Testing & Maintenance of Bay Breaker & CT
141	1008	400	PARLI - KUMBHARGAON (NANDED) CKT - 1	28/Feb/19	09:00	28/Feb/19	18:00	Daily	CB DCRM & Timing test & Bay maintenance work	MSETCL	MSETCL	-
142	1015	400	LONIKAND 1 - TALEGAON (PGCIL)	28/Feb/19	10:00	28/Feb/19	17:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-

State Element Outages list for the month of February'19

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400	LONIKAND 1 - KOYNA STAGE-IV	01-Feb-19	09:00	28-Feb-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	Permission for A/R to be kept OFF
2	400	JEJURI- KOYNA STAGE-IV	01-Feb-19	09:00	28-Feb-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	Permission for A/R to be kept OFF
3	400	PADGHE - NAGOTHANE 2	01-Feb-19	08:00	01-Feb-19	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
4	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	01-Feb-19	08:00	02-Feb-19	18:00	Daily	Diagnostic testing , relay testing & routine maintenance	MSETCL	MSETCL	Load can be managed on 315MVA 400/220KV ICT I
5	400	CHANDRAPUR - KHAPERKHEDA	01-Feb-19	08:00	14-Feb-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
6	400	400/220/20 KV 500MVA ICT - 1 @ KALWA	03-Feb-19	09:30	03-Feb-19	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	Bay Maintenance & testing work.
7	400	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	04-Feb-19	08:00	05-Feb-19	18:00	Daily	Diagnostic testing,relay testing & routine maintenance	MSETCL	MSETCL	Load can be managed on 315MVA 400/220KV ICT II
8	400	400/220 KV 315MVA ICT - 1 @ KARAD	04-Feb-19	10:00	04-Feb-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on other Two ICT's
9	400	THAPTI TANDA - WALUJ	04-Feb-19	09:00	04-Feb-19	18:00	Daily	Line Maintenance	MSETCL	MSETCL	NIL
10	400	MAIN BAY (403) OF CHANDRAPUR GCR CKT - 1 @ CHANDRAPUR - 2	04-Feb-19	09:00	04-Feb-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	Routine Maintenance and Diagnostic Testing Works
11	400	AKOLA-NANDGAONPETH (RPL-AMT)	04-Feb-19	12:00	06-Feb-19	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.
12	400	105 MVA SPARE ICT @ AKOLA	04-Feb-19	08:00	04-Feb-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
13	400	KHADKA-AURANGABAD	05-Feb-19	07:00	06-Feb-19	17:00	Daily	Replacement of Broken Disc Insulator string	MSETCL	MSETCL	Preventive Line maintenance work
14	400	JAIGAD-NEW KOYNA-I	05-Feb-19	09:00	05-Feb-19	18:00	Daily	Coldline work	JPTL	JPTL	insulator washing washing/Overhead hardware replacement
15	400	400/132 KV 200 MVA ICT - 1 @ KHADKA	05-Feb-19	08:00	05-Feb-19	18:00	Daily	For DCRM of Main breaker and ICT will be shifted on TBC	MSETCL	MSETCL	Maintenance work
16	400	400/220 KV 315MVA ICT - 2 @ KARAD	05-Feb-19	10:00	05-Feb-19	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load manage on other Two ICT's
17	400	THAPTI TANDA - WALUJ	06-Feb-19	09:00	06-Feb-19	18:00	Daily	Line Maintenance	MSETCL	MSETCL	NIL
18	400	JAIGAD-NEW KOYNA-II	06-Feb-19	09:00	06-Feb-19	18:00	Daily	Coldline work	JPTL	JPTL	insulator washing washing/Overhead hardware replacement
19	400	125 MVAR BUS REACTOR @ TALANDGE	06-Feb-19	09:00	06-Feb-19	18:00	Daily	Annual testing and maintenance work	MSETCL	MSETCL	-
20	400	DEEPNAGAR AURANGABAD	06-Feb-19	06:00	09-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint & Replacement of faulty insulator string	MSETCL	MSETCL	Line Maintenance work
21	400	DEEPNAGAR - THAPTI TANDA	07-Feb-19	09:00	07-Feb-19	18:00	Daily	Line Maintenance	MSETCL	MSETCL	NIL
22	400	JAIGAD-NEW KOYNA-II	07-Feb-19	08:00	07-Feb-19	18:00	Daily	Diagnostic ,relay testing & routine maintenance	MSETCL	MSETCL	Load can be managed on New Koyna-Jaigad CKT-II line
23	400	JEJURI- KOYNA STAGE-IV	07-Feb-19	08:00	07-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
24	400	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	07-Feb-19	10:00	07-Feb-19	17:00	Daily	Routine Diagnostic testing & maintenance work	MSETCL	MSETCL	-
25	400	DEEPNAGAR - THAPTI TANDA	07-Feb-19	09:00	07-Feb-19	18:00	Daily	Line Maintenance	MSETCL	MSETCL	NIL
26	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	07-Feb-19	10:00	07-Feb-19	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
27	400	JAIGAD-KARAD-I	07-Feb-19	09:00	07-Feb-19	18:00	Daily	Coldline work	JPTL	JPTL	insulator washing washing/Overhead hardware replacement
28	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	07-Feb-19	09:00	07-Feb-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
29	400	AKOLA-NANDGAONPETH (RPL-AMT)	07-Feb-19	08:00	09-Feb-19	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency by availing outages (cold line).	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.
30	400	JAIGAD-KARAD-II	08-Feb-19	09:00	08-Feb-19	18:00	Daily	Coldline work	JPTL	JPTL	insulator washing washing/Overhead hardware replacement
31	400	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	08-Feb-19	08:00	08-Feb-19	18:00	Daily	Routine testing and maintenance work	MSETCL	MSETCL	Routine testing and maintenance work
32	400	400/220 KV 3X200 MVA ICT - 2 @ KALWA	10-Feb-19	09:30	10-Feb-19	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	Bay Maintenance & testing work.
33	400	AKOLA - KHADKA (BHUSAWAL)	11-Feb-19	06:00	12-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint at Crossing Point of these Lines	MSETCL	MSETCL	Preventive Line maintenance work
34	400	DEEPNAGAR AURANGABAD	11-Feb-19	06:00	16-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint & Replacement of faulty insulator string	MSETCL	MSETCL	Line maintenance work
35	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	11-Feb-19	08:00	11-Feb-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
36	400	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	12-Feb-19	09:00	12-Feb-19	13:00	Daily	CB DCRM work	MSETCL	MSETCL	ICT-II will remain charged through Tie bay- 415 .Load affected Nil
37	400	KHADKA- DEEPNAGAR CKT 2 @ KHADKA	12-Feb-19	08:00	12-Feb-19	18:00	Daily	For DCRM of Main breaker and Line will be shifted on TBC	MSETCL	MSETCL	Maintenance work
38	400	80 MVAR REACTOR @ KHARGHAR	12-Feb-19	08:00	12-Feb-19	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Nil
39	400	LONIKAND 1 - KOYNA STAGE-IV	12-Feb-19	08:00	12-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
40	400	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	12-Feb-19	14:00	12-Feb-19	18:00	Daily	CB DCRM work	MSETCL	MSETCL	ICT-II will remain charged through Own bay- 416 .Load affected Nil
41	400	NEW KOYNA-KARAD-CKT 1	13-Feb-19	08:00	13-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	New Koyna-II ckt will be in service
42	400	KORADI-KHADKA	13-Feb-19	06:00	14-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint at Crossing Point of these Lines	MSETCL	MSETCL	Preventive Line maintenance work

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
43	400	THAPTI TANDA - WALUJ	13-Feb-19	10:00	13-Feb-19	17:00	Daily	Routine Maintenance and testing works in r/o Thaptitanda bay@ Waluj	MSETCL	MSETCL	Routine maintenance and testing works in r/o Thaptitanda Bay @Waluj end
44	400	400/220/33 KV 315 MVA ICT - 2 @ KORADI	13-Feb-19	09:00	13-Feb-19	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
45	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	13-Feb-19	10:00	13-Feb-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400/220/33 KV 500MVA ICT I
46	400	BABLESHWAR- AURANGABAD (WALUJ)	13-Feb-19	09:00	13-Feb-19	17:00	Daily	Quarterly Maintenance work, Servicing and allignment of PG Isolators	MSETCL	MSETCL	400 kV Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
47	400	JAIGAD-NEW KOYNA-I	13-Feb-19	09:00	19-Feb-19	18:00	Daily	Hotline washing work	JPTL	JPTL	Hotline Insulator washing on Jaigad-Newkoyna I & II
48	400	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	14-Feb-19	09:00	14-Feb-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400/220KV ICT-I BHEL & ICT-III Alstom
49	400	WARORA - IEPL	14-Feb-19	09:00	14-Feb-19	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt
50	400	CHANDRAPUR - KHAPERKHEDA	14-Feb-19	08:00	14-Feb-19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
51	400	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	14-Feb-19	09:00	14-Feb-19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Routine Maintenance & Dignostic testing work
52	400	400/220/33 KV 315 MVA ICT - 2 @ PARLI	14-Feb-19	09:00	14-Feb-19	18:00	Daily	Differential relay and NDR relay testing work, bay maintenance work.	MSETCL	MSETCL	-
53	400	KHADKA - BABLESHWAR	14-Feb-19	09:00	14-Feb-19	17:00	Daily	Quarterly Maintenance work , Servicing and allignment of PG Isolators	MSETCL	MSETCL	400 kV Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
54	400	JEJURI- KOYNA STAGE-IV	14-Feb-19	08:00	14-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
55	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	15-Feb-19	10:00	15-Feb-19	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
56	400	NEW KOYNA-KARAD -CKT 1	15-Feb-19	08:00	15-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	New Koyna-II ckt will be in service
57	400	CHANDRAPUR 2 - CHANDRAPUR SWITCHING CKT1	16-Feb-19	08:00	16-Feb-19	17:00	Daily	Tightning of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
58	400	NEW KOYNA-KARAD -CKT 1	16-Feb-19	08:00	16-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	New Koyna-II ckt will be in service
59	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	16-Feb-19	08:00	16-Feb-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220KV 315MVA ICT- I , 501 MVA ICT -III& IV will be in service
60	400	400/220/20 KV 500MVA ICT - 3 @ KALWA	17-Feb-19	09:30	17-Feb-19	17:30	Daily	Bay Maintenance & testing work.	MSETCL	MSETCL	Bay Maintenance & testing work.
61	400	400/220/33 KV 315MVA ICT - 2 @ AKOLA	18-Feb-19	08:00	18-Feb-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
62	400	LONIKAND 1 - KOYNA STAGE-IV	19-Feb-19	08:00	19-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
63	400	JEJURI- KOYNA STAGE-IV	20-Feb-19	08:00	20-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
64	400	DEEPNAGAR - THAPTI TANDA	20-Feb-19	06:00	23-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint & Replacement of faulty insulator string	MSETCL	MSETCL	Preventive Line maintenance work
65	400	400/132 KV 200 MVA ICT - 2 @ KHADKA	20-Feb-19	08:00	20-Feb-19	18:00	Daily	For DCRM of Main breaker and ICT will be shifted on TBC	MSETCL	MSETCL	Maintenance work
66	400	AKOLA - KHADKA (BHUSAWAL)	20-Feb-19	06:00	21-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint at Crossing Point of these Lines	MSETCL	MSETCL	Preventive Line Maintenance work
67	400	JAIGAD-KARAD-I	20-Feb-19	10:00	20-Feb-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV JAIGAD -2
68	400	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	21-Feb-19	09:00	21-Feb-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
69	400	NEW KOYNA - STAGE IV CKT 1	21-Feb-19	08:00	22-Feb-19	18:00	Daily	Cold washing & replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
70	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	21-Feb-19	10:00	21-Feb-19	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
71	400	KHADKA- DEEPNAGAR CKT 1	21-Feb-19	09:00	21-Feb-19	17:00	Daily	Routine Maintenance & Dignostic testing work of Main CB	MSETCL	MSETCL	400KV Line Charged through Tie CB
72	400	125MVAr BUS REACTOR @ WARORA	21-Feb-19	08:00	21-Feb-19	18:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	During outage reactor is in off condition
73	400	LONIKAND 1 - KOYNA STAGE-IV	21-Feb-19	10:00	21-Feb-19	17:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	-
74	400	JAIGAD-KARAD-II	21-Feb-19	10:00	21-Feb-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV JAIGAD -1
75	400	SPARE LINE @ LONIKAND 2	21-Feb-19	09:00	21-Feb-19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Spare Line bay
76	400	BABLESHWAR- AURANGABAD (WALUJ)	22-Feb-19	08:00	28-Feb-19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	Require A/R out of servcie
77	400	KORADI 2-IEPL	22-Feb-19	08:00	22-Feb-19	18:00	Daily	Refixing of jumper nut bolts on jumper & conductor hardware at various locations.	MSETCL	MSETCL	Outage will be availed subject to wheather condition.
78	400	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	22-Feb-19	08:00	22-Feb-19	17:00	Daily	Routine maintainance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL	400KV PGCL Line will be charged through Tie CB 421.
79	400	NEW KOYNA - STAGE IV CKT 2	22-Feb-19	08:00	23-Feb-19	18:00	Daily	Cold washing & replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
80	400	KORADI-KHADKA	22-Feb-19	06:00	23-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint at Crossing Point of these Lines	MSETCL	MSETCL	Preventive Line maintenance work
81	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	23-Feb-19	08:00	23-Feb-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220KV 315MVA ICT- II , 501 MVA ICT -III& IV will be in service
82	400	CHANDRAPUR - KHAPERKHEDA	24-Feb-19	10:00	24-Feb-19	18:00	Daily	Pid Testing work	MSETCL	MSETCL	Auto reclose in non auto mode
83	400	KHADKA-AURANGABAD	25-Feb-19	08:00	25-Feb-19	18:00	Daily	For distance relay testing work	MSETCL	MSETCL	Testing work
84	400	DEEPNAGAR - THAPTI TANDA	25-Feb-19	06:00	28-Feb-19	18:00	Daily	Replacement of Dead End & Mid Span Joint & Replacement of faulty insulator string	MSETCL	MSETCL	Preventive Line Maintenance work
85	400	NEW KOYNA-KARAD -CKT 1	25-Feb-19	08:00	25-Feb-19	18:00	Daily	Routine maintenance, diagnostic testing and relay testing work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna-Karad CKT-II line

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
86	400	80 MVAR BUS REACTOR - 1 @ BABHALESHWAR	25-Feb-19	08:00	25-Feb-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -2 are in servise
87	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	25-Feb-19	12:00	28-Feb-19	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
88	400	80 MVAR BUS REACTOR - 2 @ BABHALESHWAR	26-Feb-19	08:00	26-Feb-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -1 are in service
89	400	NEW KOYNA-KARAD -CKT 1	27-Feb-19	08:00	27-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	New Koyna-II ckt will be in service
90	400	THE BAY (411) OF STATION TF 8A & CHANDRAPUR 2 CKT - 2 @ CHANDRAPUR SMC S/S	27-Feb-19	09:00	27-Feb-19	18:00	Daily	Routine Maintenance &Diagnostic testing works	MSETCL	MSETCL	Routine Maintenance &Diagnostic testing works
91	400	DHULE- - BABLESHWAR - I	27-Feb-19	09:00	27-Feb-19	17:00	Daily	Quarterly Maintenance work & Servicing ,allignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Bhusawal Dhule-Ckt 2, Ektuni-ckt-1 will be in service
92	400	KORADI-KHADKA	27-Feb-19	08:00	27-Feb-19	18:00	Daily	For taking tan delta of reactor bushing and winding and other bay maintenance	MSETCL	MSETCL	Routine testing work
93	400	GTR - 7 @ CHANDRAPUR	27-Feb-19	09:00	27-Feb-19	18:00	Daily	1) The Measurement of DCRM, CRM & Timing of breaker. 2) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay.
94	400	LONIKAND 1 - KOYNA STAGE-IV	27-Feb-19	08:00	27-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
95	400	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	28-Feb-19	09:00	28-Feb-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400/220KV ICT-II CGL & ICT-III Alstom
96	400	JEJURI- KOYNA STAGE-IV	28-Feb-19	08:00	28-Feb-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
97	400	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	28-Feb-19	09:00	28-Feb-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400/220KV ICT-I BHEL & ICT-II CGL
98	400	DHULE- - BABLESHWAR - II	28-Feb-19	09:00	28-Feb-19	17:00	Daily	Quarterly Maintenance work & Servicing, allignment of PG isolators	MSETCL	MSETCL	400 kV Auragabad ,Bhusawal Dhule-Ckt-1, Ektuni-ckt-1 will be in service