

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Jan/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.577	313.417	1) Gujrat	-5.467	-8.706
2) Hydro	9.149	13.998	2) Madhya Pradesh	1.886	3.729
3) Gas	6.405	13.407	3) Chattisgarh	7.040	13.750
Total MSPGCL	178.131	340.822	4) Maharashtra	184.583	362.452
B) 1) APLM	46.543	95.380	5) Goa (Amona)	-1.599	-3.156
2) JSWEL	23.544	46.460	Total	186.443	368.069
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.915	63.077
4) RPL(AMT)	25.412	50.513	b) Mumbai Drawl	35.669	70.291
5) SWPGPL	12.125	24.102	c) MSEDCL Bilateral *	64.217	123.662
6) Other IPP	44.744	88.931	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.915	63.077
C) 1) TPCL Thermal	13.469	26.577	Include PX	0.000	0.000
2) TPCL Hydro	4.825	9.128	Standby	0.000	0.000
3) TPCL Gas	1.406	1.406	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.042	10.299	1) MSEDCL	491.186	962.792
D) STATE			2) Mumbai Discoms	60.413	117.703
1) Thermal	333.456	655.679	3) Other Discoms	10.203	20.382
(A1+C1+C4+(B1-B6))			TOTAL STATE	561.802	1100.877
2) Hydro	13.974	23.126			
(A2+C2)					
3) Gas	7.811	14.813			
(A3+B7+C3)					
4) Wind	6.862	12.359			
6) SOLAR	13.254	26.829			
TOTAL STATE	375.357	732.806			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7500	6591	7358	6022
MSPGCL Hydro	1182	272	1060	143
MSPGCL Gas	147	277	289	299
MSPGCL Total Generation	8829	7140	8707	6464
Central Sector Receipt	8310	9168	7960	6370
WIND	187	152	133	326
CPP / IPP Thermal	6621	6127	6549	6086
CPP / IPP Gas	0	0	0	0
SOLAR	1837	2095	5	0
Exchange with Mumbai	-1654	-1784	-1548	-1271
MSEDCL DEMAND MET	23682	22462	21318	17637
Load Shedding	0	0	0	0
MSEDCL DEMAND	23682	22462	21318	17637
TPCL GENERATION	1153	1009	1151	446
AEML GENERATION	218	248	251	156
MUMBAI DEMAND	3025	3041	2950	1873
OTHER DISCOM DEMAND	448	436	488	338
STATE DEMAND MET	27155	25939	24756	19848
STATE DEMAND	27155	25939	24756	19848
Frequency (Hz)	49.99	49.95	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 16:03 Hrs	49.7 Hz at 17:25 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Jan/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.27	8.54	185	155
Unit 8	14.42	28.01	629	470
Unit 9	12.99	25.97	595	440
Unit 10	13.98	27.66	600	470
Total	45.66	90.17		
Bhusawal				
Unit 3	3.43	6.90	180	120
Unit 4	9.54	18.84	500	290
Unit 5	8.86	17.91	500	215
Total	21.82	43.66		
Parli				
Unit 6	4.24	8.56	232	144
Unit 7	4.44	8.68	241	147
Unit 8	4.33	8.38	247	142
Total	13.02	25.62		
Chandrapur				
Unit 3	3.40	6.67	165	114
Unit 4	3.13	6.31	143	118
Unit 5	8.35	16.84	420	285
Unit 6	7.40	14.84	345	275
Unit 7	0.00	0.00	0	0
Unit 8	8.01	12.72	359	295
Unit 9	8.71	9.00	457	210
Total	39.01	66.38		
Paras				
Unit 3	5.42	10.80	238	216
Unit 4	5.90	11.42	253	239
Total	11.32	22.22		
Khaparkheda				
Unit 1	3.95	7.80	190	115
Unit 2	2.87	5.70	128	112
Unit 3	3.77	7.55	175	129
Unit 4	4.00	8.04	193	131
Unit 5	10.39	20.49	470	290
Total	24.99	49.58		
Nasik				
Unit 3	0.00	2.70	0	0
Unit 4	3.92	7.18	190	127
Unit 5	2.84	5.90	159	0
Total	6.76	15.78		
Uran				
All Units	6.40	13.41	302	139
Total	6.40	13.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	0.42	53	0
Total	0.20	0.42		
Koyna				
Stage 1-2	1.90	3.06	350	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.40	2.40	760	0
Stage 3	0.89	1.32	160	0
Total	5.18	6.77		
Hydro				
KDPH	0.43	0.86	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.96	4.00	85	79
GHATGHAR	1.37	1.95	250	0
Total	3.76	6.81		
Wind				
Total	6.86	12.36	0	0
Total	6.86	12.36		
CPP				
APML(Mus)	46.54	95.38	0	0
JSWEL(Mus)	23.54	46.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.41	50.51	0	0
SWPGPL-Mus	12.12	24.10	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.46	10.62	274	152
Other(Mus)	37.12	74.06	0	0
JPL	2.16	4.25	131	67
Total	152.37	305.39		
SOLAR				
Total	13.25	26.83	0	0
Total	13.25	26.83		
Tata				
Trombay 5	8.90	17.62	449	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.24	1.24	104	0
Trombay 7B	0.16	0.16	37	0
TATA Hydro	4.82	9.13	400	32
Trombay 8	4.57	8.95	226	131
Total	19.70	37.11		
AEML				
DTPS U-1&2	5.04	10.30	251	144
Total	5.04	10.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.58	313.42	MSPGCL Total	178.13	340.82
			MSPGCL Thml+Gas	168.98	326.82	Koyna 1,2 & 4 Total	4.30	5.45
			MSPGCL Hydro	9.15	14.00	State Total	375.36	732.81

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Jan/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5539	137	296	5972	295	6069	0	0	7245	6896	-1433	17403	0	0	17403	2104	395	19903	49.99
2	5874	143	298	6315	346	6132	0	0	6943	6498	-1340	17598	0	0	17598	1971	353	19922	49.99
3	6022	143	299	6464	326	6086	0	0	6678	6370	-1271	17637	0	0	17637	1873	338	19848	49.98
4	5918	142	299	6359	369	6110	0	0	6725	6754	-1212	18052	0	0	18052	1812	329	20192	49.99
5	6160	137	299	6596	343	6199	0	0	6762	6959	-1199	18547	0	0	18547	1811	350	20709	49.96
6	6798	137	302	7237	407	6313	0	0	7225	7495	-1244	19836	0	0	19836	1911	373	22119	49.98
7	7277	134	302	7713	482	6389	0	2	7885	8013	-1357	20841	0	0	20841	2076	401	23318	50.03
8	7525	225	254	8004	547	6675	0	148	8081	8395	-1260	22089	0	0	22089	2249	420	24758	49.97
9	7448	689	142	8279	477	6693	0	668	7980	8000	-1361	22319	0	0	22319	2557	437	25313	49.89
10	7459	1470	139	9068	286	6691	0	1237	7589	7776	-1421	23202	0	0	23202	2837	435	26474	49.99
11	7500	1182	147	8829	187	6621	0	1837	8235	8310	-1654	23682	0	0	23682	3025	448	27155	49.99
12	7315	613	175	8103	243	6479	0	2021	9052	8585	-1803	23170	0	0	23170	3098	458	26726	50.02
13	6591	272	277	7140	152	6127	0	2095	9273	9168	-1784	22462	0	0	22462	3041	436	25939	49.95
14	6488	168	280	6936	123	6044	0	1948	9112	9022	-1749	21884	0	0	21884	2920	440	25244	50.02
15	6673	148	282	7103	83	6076	0	1614	9273	9399	-1806	22026	0	0	22026	2938	443	25407	49.96
16	7213	140	285	7638	70	6140	0	1060	9351	9268	-1751	21966	0	0	21966	2948	459	25373	50.00
17	7441	141	286	7868	63	6496	0	530	8584	8618	-1602	21490	0	0	21490	2971	483	24944	49.95
18	7449	579	288	8316	49	6542	0	89	7629	7894	-1532	20865	0	0	20865	2944	493	24302	49.88
19	7358	1060	289	8707	133	6549	0	5	7784	7960	-1548	21318	0	0	21318	2950	488	24756	49.98
20	7264	901	290	8455	191	6515	0	0	7360	7473	-1428	20749	0	0	20749	2822	457	24028	50.00
21	6923	160	291	7374	283	6493	0	0	7491	7120	-1480	19328	0	0	19328	2637	462	22427	50.00
22	6321	143	292	6756	451	6338	0	0	7113	6936	-1529	18499	0	0	18499	2450	453	21402	49.98
23	6017	140	295	6452	480	6278	0	0	6922	6905	-1487	18196	0	0	18196	2294	433	20922	50.02
24	6004	144	298	6446	476	6312	0	0	6499	6630	-1418	18028	0	0	18028	2172	418	20618	50.02
MUs	162.58	9.15	6.40	178.13	6.86	152.37	0.00	13.25	186.79	186.44	-35.67	491.19	0.00	0.00	491.19	60.41	10.20	561.80	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Jan/2024

Position as on 6.30 Hrs of 03/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	15/01/2024
MSPGCL	Koyna STG-IV Unit-3	250	24/11/2023	08:00		Continued.	Capital Overhauling	24/01/2024
MSPGCL	Chandrapur Unit 7	500	25/12/2023	15:28		Continued.	Air heater basket replacement work(converted to planned outage from 00.00Hrs DT. 30-12-2023)	07/01/2024
Total Capacity MSPGCL		938						
TPC-G								
TPC-G	Trombay 7B	60	20/12/2023	12:37	02/01/2024	19:05	Annual Overhaul	03/01/2024
TPC-G	Trombay 7A	120	20/12/2023	12:42	02/01/2024	06:50	Annual Overhaul	03/01/2024
Total Capacity TPC-G		180						
AEML								
AEML	AEML Unit 2	250	20/12/2023	10:54		Continued.	Annual Overhaul	20/01/2024
Total Capacity AEML		250						
IPP								
IPP	Adani U-3	660	31/12/2023	23:59		Continued.	COH activities	05/02/2024
Total Capacity IPP		660						
Total Capacity PLANNED OUTAGE		2028						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	01/01/2024	20:30		Continued.	Boiler Tube Leakage(converted to tolling from 00.00Hrs DT.	
MSPGCL	Uran Unit 7	108	02/01/2024	07:41	02/01/2024	10:32	Excitation Protection Fail.	
MSPGCL	Nasik Unit 5	210	02/01/2024	20:00	03/01/2024	04:34	Boiler Validity Renevoation	03/01/2024
Total Capacity MSPGCL		756						
TPC-G								
TPC-G	Trombay 7B	60	03/01/2024	02:00	03/01/2024	13:37	Condenser problem	
Total Capacity TPC-G		60						
IPP								
IPP	RPL(AMT) U-2	270	30/12/2023	13:30		Continued.	Hydrogen leakage in Generator.	12/01/2024
IPP	Adani U-1	660	01/01/2024	04:15	03/01/2024	23:47	APH -A hot Bellow leakage.	03/01/2024
Total Capacity IPP		930						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Jan/2024

Position as on 6.30 Hrs of 03/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2066						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (708) OF AKOLA CKT - 1 & TIRODA CKT - 2 @ KORADI - 3	IntraState	02/01/2024	09:13	02/01/2024	19:02	PO	Annual maintenance of CB at Koradi- III SS.
400 KV TIEBAY Outages/Trippings							
TIE BAY (412) OF CHANDRAPUR-1 & ADANI - 1 @ WARORA	IntraState	02/01/2024	10:44	02/01/2024	14:28	PO	Routine maintenance and IR Values, Testing works and isolator maintenance work .
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-2	InterState	20/12/2023	12:11			HT	For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS�
SOLAPUR PG - ALKUD	InterState	02/01/2024	08:42	02/01/2024	17:10	PO	Bay AMP Works
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	03/01/2024	19:06	03/01/2024	21:44	EO	TO ATTEND HOT SPOT ON LINE CT BPH
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/11/2023	19:17			HT	HT Load Management
PADGHE - KALWA CKT - 2	IntraState	30/12/2023	22:01			PO	During the outage on Dtd: 30.12.2023 temporary tapping arrangement on 400kv Kalwa-Padgha Ckt.2 line will be done by making a bunching arrangement from loc no 3 to loc 132 of 400Kv Padgha-Kharghar (dead line) line at Padgha substation premises. By this bunching arrangement, line will be diverted from loc no.132 to loc.No .09. Due to this tapping of 400Kv Kalwa-Padgha Ckt.2-line section b/w loc no 3 to Kalwa Substation (loc1135) will become dead. And this dead Ckt. will be free for completion of the balance HTLS conversion work i.e between Loc no. 61-62 to 1012 (approximately 2.7 km).
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	30/12/2023	22:43			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	30/12/2023	22:44			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
KHADKA-AURANGABAD (WALUJ)	IntraState	01/01/2024	20:18	02/01/2024	09:42	HT	H/T For Voltage Management.
JAIGAD - KARAD CKT - 1	IntraState	02/01/2024	02:08	02/01/2024	09:24	HT	HT due to Overvoltage
NEW KOYNA-KARAD CKT - 2	IntraState	02/01/2024	10:17	03/01/2024	09:52	PO	Diagnostic testing & Relay testing work , Routine maint. Work
MAIN BUS - 1 @ AKOLA 2	IntraState	03/01/2024	10:04	03/01/2024	16:27	PO	For Annual Testing of Bus CVT & LED light installation.
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 1 @ WARORA	IntraState	16/12/2023	10:30	02/01/2024	14:35	PO	Removing cable from TB and Glands in Panel for taking continuity test and confirming other cables also i.e control room to ICT , Control room to panel.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	30/12/2023	23:20			T	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	30/12/2023	23:21			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	30/12/2023	23:22			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400KV/21KV GT - 3 @ TIRORA	IntraState	01/01/2024	10:45			PO	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.
GTR - 7 @ CHANDRAPUR	IntraState	01/01/2024	11:11				1) Measurement of CB timing, CRM & DCRM. 2) Measurement of tandelta & capacitance of CT & Sych CVT 2) Maintenance and alignment of Isolators. 3) Bay routine maintenance work.
400 KV BR Outages/Trippings							
400KV 125 MVAR BUS REACTOR@400KV DHULE SS	InterState	02/01/2024	10:00	02/01/2024	14:03	PO	for taking 25 MVAR Bus Reactor CB CRM & DCRM as per the data required by OEM Siemens
220 KV TBC Outages/Trippings							
TBC @ MAHAPE	IntraState	03/01/2024	10:12	03/01/2024	15:35	PO	Maintenance and diagnostic testing work.
220 KV TBC	IntraState	03/01/2024	12:00	03/01/2024	15:29	PO	ONLINE WASHING OF INSULATORS AND DISCS BY HOTLINE METHOD
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	31/12/2023	18:05			T	Distance Protection
DAHANU - VERSOVA	IntraState	02/01/2024	08:04			PO	Tranmission Line Project: High speed train project work ADTPS: Bay 04 Overhauling of Isolator -C Bus 02 Isolator OH and Breaker PM
DAHANU - VIRAJ	IntraState	02/01/2024	08:30			PO	Transmission Line Project : High speed train project work ADTPS: Bay 03 Overhauling of Isolator -C Bus 02 Isolator Overhauling Breaker PM PM & tan delta testing of Line CT / CVT LA Replacement
MAIN BUS @ MIRAJ	IntraState	02/01/2024	09:05	02/01/2024	13:51	PO	Annual Bus Maintenance Work
KADEGAON-MIRAJ	IntraState	02/01/2024	09:05	02/01/2024	16:34	PO	Cold Washing of Insulator Strings & Rotating bird guard fixing work at Loc No. 145 & 160

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	02/01/2024	09:10	02/01/2024	17:02	PO	For carry out anticorrosive treatment (Painting) on Wave trap & CT gantry beam for 220kV Pawas Niwali line bay at 220kV Pawas S/s.
NAGOTHANE - ACCIL	IntraState	02/01/2024	10:16	02/01/2024	17:52	PO	"Twin jumperring work."
220KV TULJAPUR-BALE CKT	IntraState	02/01/2024	10:45	02/01/2024	13:20	PO	R/M work
TALANDAGE - FIVE STAR MIDC 1	IntraState	02/01/2024	11:40	02/01/2024	14:21	PO	CB CRM testing work due to Higher CRM value. Also to attain other problem of CB.
220 KV KALMESHVAR WARUD CKT I	IntraState	02/01/2024	21:37		Continued.	T	Distance protection operated
APTA - TAMBATI	IntraState	03/01/2024	06:42	03/01/2024	11:05	PO	"Twin jumperring work."
NERLE - PEDAMBE	IntraState	03/01/2024	09:39	03/01/2024	17:56	PO	For replacement of damaged conductor at loc no 36 R ph Pedhambe side, Y ph Pedhambe side, B ph Nerale side
KADEGAON-MIRAJ	IntraState	03/01/2024	09:39	03/01/2024	18:00	PO	Cold Washing of Insulator Strings & Rotating bird guard fixing work at Loc No. 145 & 160
WATHAR - MUDSHINGI 3 LINE	IntraState	03/01/2024	10:06	03/01/2024	17:19	PO	Quarterly maintenance Work
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	03/01/2024	12:31	03/01/2024	16:21	PO	CT DIAGNOSTIC TESTING WORK AND ALLIED MAINTENANCE WORK , RELAY TESTING WORK
220 KV CHALISGAON - KHADKA CKT -2	IntraState	03/01/2024	13:35	03/01/2024	17:42	EO	FOR REPLACEMENT OF FLASHOVER PILOT INSULATOR STRING AT LOC. NO. 276 (B-PH) & REMOVAL OF OLD EARTHWIRE WHICH WAS BINDED TO TOWERS AT LOC. NO. 269,271 & 272.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	02/01/2024	12:01	02/01/2024	12:35	PO	Cable testing work
220/132 KV 200 MVA ICT - 2 @ HARANGUL	IntraState	02/01/2024	12:32	02/01/2024	14:55	PO	Tan Delta Testing work
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	02/01/2024	14:42	02/01/2024	16:58	PO	CB pole overhauling, Diagnostic testing & RM work
220/100 KV 200 MVA ICT 2 @ PALDOMBIVALI	IntraState	03/01/2024	09:09	03/01/2024	19:12	PO	Diagnostic of ICT & Bay RM work
220/132KV 200 MVA ICT 1	IntraState	03/01/2024	10:40	03/01/2024	17:51	PO	FOR DIGONOSTIC TESTING,EQUIPMENT AND AUXILLARY ISOLATOR MAINTENANCE AND SERVICING WORK ALSO ALLIED MAINTENANCE WORK.
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	03/01/2024	10:45	03/01/2024	12:34	PO	Outage is required for Quarterly Maintenance
220/132 KV 100 MVA ICT 2	IntraState	03/01/2024	11:42	03/01/2024	16:05	PO	TO REPLACE R-PH BUS TO BUS ISOLATOR JUMPER OF 132KV HIMAYATNAGAR CKT BAY. TO REPLACE R-PH BUS TO BUS ISOLATOR JUMPER 132KV BUS SECTION2 OUTAGE REQUIRED.
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	03/01/2024	12:29	03/01/2024	19:20	PO	For rechecking tan Delta Value of LV bushing due to C2 tan delta of Y ph Bushing found High
220/132KV 200MVA ICT 1 @ JEUR	IntraState	03/01/2024	16:00	03/01/2024	19:28	PO	Outage is required for Quarterly Maintenance

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage