

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 17/Feb/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.398	2770.453	1) Gujrat	-0.127	-20.450
2) Hydro	6.658	133.359	2) Madhya Pradesh	8.511	83.932
3) Gas	6.953	113.551	3) Chattisgarh	0.000	63.340
Total MSPGCL	176.009	3017.363	4) Maharashtra	181.101	2997.225
B) 1) APLM	66.756	1118.236	5) Goa (Amona)	-1.923	-29.223
2) JSWEL	24.534	411.766	Total	187.562	3094.824
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.858	497.530
4) RPL(AMT)	31.460	534.702	b) Mumbai Drawl	34.247	570.850
5) SWPGPL	12.337	209.709	c) MSEDCL Bilateral *	88.128	1426.027
6) Other IPP	47.866	817.197	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.856	497.527
C) 1) TPCL Thermal	8.777	139.960	Include PX	0.000	0.000
2) TPCL Hydro	2.901	57.548	Standby	0.003	0.003
3) TPCL Gas	3.546	55.279	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.701	165.918	1) MSEDCL	528.499	8857.854
D) STATE			2) Mumbai Discoms	60.172	989.448
1) Thermal	364.829	6167.941	3) Other Discoms	10.583	177.912
(A1+C1+C4+(B1-B6))			TOTAL STATE	599.254	10025.214
2) Hydro (A2+C2)	9.559	190.907			
3) Gas (A3+B7+C3)	10.499	168.830			
4) Wind	10.803	140.285			
6) SOLAR	16.002	262.534			
TOTAL STATE	411.692	6930.497			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6764	6249	7293	6304
MSPGCL Hydro	301	226	977	193
MSPGCL Gas	284	273	287	298
MSPGCL Total Generation	7349	6748	8557	6795
Central Sector Receipt	9293	9346	7450	6595
WIND	269	152	189	876
CPP / IPP Thermal	7920	7111	8152	7188
CPP / IPP Gas	0	0	0	0
SOLAR	2070	2351	0	0
Exchange with Mumbai	-1840	-1915	-1349	-1110
MSEDCL DEMAND MET	24595	23356	22510	19971
Load Shedding	0	0	0	0
MSEDCL DEMAND	24595	23356	22510	19971
TPCL GENERATION	657	679	1030	420
AEML GENERATION	456	414	468	373
MUMBAI DEMAND	2953	3008	2847	1903
OTHER DISCOM DEMAND	466	437	489	373
STATE DEMAND MET	28014	26801	25846	22247
STATE DEMAND	28014	26801	25846	22247
Frequency (Hz)	49.95	49.92	49.96	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 06:02 Hrs	49.76 Hz at 10:23 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 17/Feb/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.12	75.14	185	150
Unit 8	15.02	245.66	660	593
Unit 9	14.13	224.00	605	564
Unit 10	14.60	225.07	635	590
Total	47.87	769.87		
Bhusawal				
Unit 3	3.82	59.24	180	120
Unit 4	0.00	120.58	0	0
Unit 5	11.20	141.94	500	310
Total	15.02	321.75		
Parli				
Unit 6	4.43	72.35	250	143
Unit 7	4.34	70.26	248	140
Unit 8	4.48	72.02	250	145
Total	13.25	214.64		
Chandrapur				
Unit 3	3.48	56.06	159	124
Unit 4	3.70	59.52	168	126
Unit 5	9.38	141.99	445	290
Unit 6	0.00	35.12	0	0
Unit 7	2.16	119.33	460	0
Unit 8	9.98	159.89	429	391
Unit 9	11.28	182.62	489	428
Total	39.98	754.54		
Paras				
Unit 3	5.78	93.09	252	230
Unit 4	6.04	95.75	256	248
Total	11.83	188.84		
Khaparkheda				
Unit 1	3.82	65.48	185	120
Unit 2	3.79	13.78	201	83
Unit 3	4.09	67.95	176	150
Unit 4	4.36	72.42	193	155
Unit 5	11.07	184.35	480	430
Total	27.13	403.98		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.90	60.45	191	122
Unit 5	3.41	56.39	164	120
Total	7.32	116.84		
Uran				
All Units	6.95	113.55	302	273
Total	6.95	113.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.24	0	0
Total	0.00	1.24		
Koyna				
Stage 1-2	1.63	31.00	170	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.35	13.42	179	0
Stage 3	0.63	10.16	240	0
Total	2.61	54.58		
Hydro				
KDPH	0.86	14.69	36	36
VTRNA	0.16	3.02	60	0
TILLARI	0.00	2.67	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.72	47.90	118	105
GHATGHAR	0.30	9.26	175	0
Total	4.04	77.54		
Wind				
Total	10.80	140.28	0	0
Total	10.80	140.28		
CPP				
APML(Mus)	66.76	1118.24	0	0
JSWEL(Mus)	24.53	411.77	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.46	534.70	0	0
SWPGPL-Mus	12.34	209.71	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.64	94.78	268	197
Other(Mus)	39.41	679.59	0	0
JPL	2.82	42.83	133	106
Total	182.95	3091.61		
SOLAR				
Total	16.00	262.53	0	0
Total	16.00	262.53		
Tata				
Trombay 5	8.42	139.60	463	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.13	33.22	107	46
Trombay 7B	1.41	22.06	65	41
TATA Hydro	2.90	57.55	395	39
Trombay 8	0.36	0.36	114	0
Total	15.22	252.79		
AEML				
DTPS U-1&2	10.70	165.92	493	333
Total	10.70	165.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.40	2770.45	MSPGCL Total	176.01	3017.36
			MSPGCL Thml+Gas	169.35	2884.00	Koyna 1,2 & 4 Total	1.98	44.42
			MSPGCL Hydro	6.66	133.36	State Total	411.69	6930.50

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 17/Feb/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6370	197	298	6865	801	7179	0	0	7163	6755	-1157	20035	0	0	20035	2150	408	22593	49.96
2	6326	203	298	6827	832	7137	0	0	7031	7014	-997	20433	0	0	20433	2001	380	22814	49.97
3	6304	193	298	6795	876	7188	0	0	6958	6595	-1110	19971	0	0	19971	1903	373	22247	49.96
4	6230	197	299	6726	912	7200	0	0	6900	6849	-1072	20269	0	0	20269	1827	346	22442	49.94
5	6488	207	300	6995	924	7239	0	0	6990	7017	-1019	20789	0	0	20789	1822	367	22978	49.94
6	6802	286	302	7390	1058	7607	0	0	7209	6928	-1042	21547	0	0	21547	1925	394	23866	50.01
7	6937	278	299	7514	1109	8132	0	0	7153	6954	-1111	22198	0	0	22198	2051	400	24649	50.04
8	6962	245	298	7505	1019	8199	0	214	7312	7294	-985	22812	0	2	22812	2185	434	25431	50.04
9	6849	266	299	7414	683	8043	0	795	7840	8141	-1173	23442	0	13	23442	2451	461	26354	50.05
10	6790	249	297	7336	435	7810	0	1477	8706	9000	-1548	24056	0	29	24056	2730	454	27240	49.96
11	6764	301	284	7349	269	7920	0	2070	9408	9293	-1840	24595	0	44	24595	2953	466	28014	49.95
12	6647	189	280	7116	218	7683	0	2322	9714	9346	-1940	24287	0	25	24287	3025	458	27770	49.99
13	6249	226	273	6748	152	7111	0	2351	9474	9346	-1915	23356	0	22	23356	3008	437	26801	49.92
14	6154	246	273	6673	115	6968	0	2253	8868	8923	-1866	22601	0	16	22601	2871	465	25937	49.99
15	6616	249	274	7139	84	7142	0	1889	8903	9007	-1849	22936	0	12	22936	2909	476	26321	49.97
16	6896	194	276	7366	75	7724	0	1441	9257	8914	-1813	23220	0	11	23220	2933	487	26640	50.01
17	6975	193	280	7448	72	7949	0	866	8976	8695	-1839	22697	0	11	22697	2873	494	26064	49.98
18	7069	193	282	7544	89	8088	0	313	8127	8080	-1670	21955	0	5	21955	2826	489	25270	50.01
19	7125	667	284	8076	128	8026	0	11	7642	7405	-1477	21677	0	0	21677	2830	492	24999	49.94
20	7293	977	287	8557	189	8152	0	0	7449	7450	-1349	22510	0	0	22510	2847	489	25846	49.96
21	7185	288	290	7763	191	7992	0	0	7548	7027	-1427	21079	0	0	21079	2712	467	24258	50.00
22	7000	222	292	7514	152	7254	0	0	7406	7402	-1482	20373	0	0	20373	2576	467	23416	50.01
23	7228	199	293	7720	189	7624	0	0	7182	7164	-1418	20828	0	0	20828	2429	451	23708	49.96
24	7139	193	297	7629	231	7586	0	0	7192	6963	-1148	20833	0	0	20833	2335	428	23596	49.94
MUs	162.40	6.66	6.95	176.01	10.80	182.95	0.00	16.00	190.41	187.56	-34.25	528.50	0.00	0.19	528.50	60.17	10.58	599.25	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to overloading of 132KV BBLSR-Rahuri line and 50MVA T/F overload at 220KV Kopargaon S/stn.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 17/Feb/2024

Position as on 6.30 Hrs of 18/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	29/02/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
MSPGCL	Chandrapur Unit 6	500	06/02/2024	00:01		Continued.	For Planned short shutdown and Airheater Basket replacement.	19/02/2024
Total Capacity MSPGCL		898						
TPC-G								
TPC-G	Trombay 8	250	21/01/2024	21:28	17/02/2024	20:19	Annual Overhaul	21/02/2024
Total Capacity TPC-G		250						
CENT.SECTOR								
CENT.SECTOR	Tarapur 3	540	11/01/2024	21:45		Continued.	Annual Overhaul	29/02/2024
Total Capacity CENT.SECTOR		540						
Total Capacity PLANNED OUTAGE		1688						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Chandrapur Unit 7	500	14/02/2024	20:01	17/02/2024	17:24	SUSPECTED BTL	17/02/2024
MSPGCL	Bhusawal Unit 4	500	16/02/2024	02:54		Continued.	PA Fan problem	20/02/2024
MSPGCL	Ghatghar Unit-1	125	17/02/2024	18:53	17/02/2024	19:25	GM Link Fault	
MSPGCL	Khaparkheda Unit 4	210	18/02/2024	14:16		Continued.	Boiler Tube Leakage	21/02/2024
Total Capacity MSPGCL		1563						
IPP								
IPP	JPL Unit 1	150	13/01/2024	01:00		Continued.	Due to low net sale realisation. (while rolling at 21.00hrs. dtd. 31/01/2024 tripped on high vibration during rolling)	25/02/2024
Total Capacity IPP		150						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea.	01/05/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 17/Feb/2024

Position as on 6.30 Hrs of 18/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							The outage extended for repair and re-fueling.	
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2033						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	18/02/2024	13:08	18/02/2024	20:59	PO	Changeover of Rph Reactor with Y ph (765 KV Akola -Ektuni Line-02 non-switchable reactor) for Cable replacement of mechanical protection and CTs for Y ph (Akola - Ektuni line-02 non-switchable Reactor) at Ektuni.
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LR Outages/Trippings							
400KV KORADI-BHILAI (Koradi end)	IntraState	15/02/2024	12:30		Continued.	PO	Overhauling of BHI CGL CB at Koradi SS, 400kv Koradi-Bhilai Line
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 2	InterState	12/02/2024	13:46			PO	1)H/t requires for replacement B Bus Conductor between 500MVA ICT-5 & 400kV Tarapur-II of Sec-I.
PADGHE - TARAPUR CKT - 1	InterState	12/02/2024	14:03			PO	Stringing of diversion work of 400kV Tarapur-Phadga
DHULE - SSNNL CKT - 1	InterState	15/02/2024	09:24			PO	Major Maintenance of GIS
KORADI - BHILAI	InterState	15/02/2024	11:39	18/02/2024	00:01	PO	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Bhilai Line Out of Service.
DHULE - SSNNL CKT - 2	InterState	17/02/2024	13:33	17/02/2024	18:21	T	Distance Protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
105 MVA SPARE ICT @ AKOLA	IntraState	04/02/2024	09:21			EO	for removal of 401 52 circuit breaker of spare ICT for replacement of 40952 B phase CB of Tie Bay 409
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	12/02/2024	10:28			PO	Erection of CS Type Gantry Beam Structure for RRS Scheme of ICTs
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	18/02/2024	04:21	18/02/2024	05:08	T	220 kV Main bus 2 busbar operated
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	18/02/2024	04:21	18/02/2024	05:42	T	220 kV Main bus 2 busbar operated
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV TBC Outages/Trippings							
GIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	17/02/2024	09:53	17/02/2024	16:17	PO	Annual Maintenance of Bay & C.B.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ TALANDGE	IntraState	18/02/2024	04:21	18/02/2024	05:25	T	220 kV Main bus 2 busbar operated
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	31/12/2023	18:05		Continued.	T	Distance Protection, Line is charged from Bapgaon end only for soak test of repaired cable of said line.
CHEMBUR (AEML) - NERUL (M)	IntraState	18/01/2024	23:29	17/02/2024	03:38	PO	LILO removal by Bunching at Tower No 720 .Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILO arrangement shall be normalized on 09.02.2024 after debunching
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	18/01/2024	23:36	17/02/2024	03:40		LILO removal by Bunching at Tower No 720 . Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILO arrangement shall be normalized on 09.02.2024 after debunching
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
CHEMBUR (AEML) - NERUL (M)	IntraState	16/02/2024	22:25	17/02/2024	03:38	PO	Outage of Reconfigured 220kV Nerul-Trombay line required for Removal of Bunching at Tower No 720 .Post this earlier lines will be normalized
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	16/02/2024	22:25	17/02/2024	03:40	PO	Outage of Reconfigured 220kV Nerul-Trombay line required for Removal of Bunching at Tower No 720 .Post this earlier lines will be normalized
BHUGAON- WARDHA	IntraState	17/02/2024	09:13	17/02/2024	11:13	PO	For binding work of opened strands of Y&B phase Jumper
BOISAR - VERSOVA	IntraState	17/02/2024	12:32	17/02/2024	15:38	PO	Bay maintenance & Equipment Diagnostic Testing
MALHARPETH SATARA MIDC	IntraState	17/02/2024	18:47	18/02/2024	00:18	T	B-ph LA blast at Malharpeth
TALANDGE - ICHALKARANJI 2	IntraState	18/02/2024	04:21	18/02/2024	05:14	T	220 kV Main bus 2 busbar operated
TALANDAGE - FIVE STAR MIDC 2	IntraState	18/02/2024	04:21	18/02/2024	12:43	T	220 kV Main bus 2 busbar operated
TALANDGE - BIDRI	IntraState	18/02/2024	04:21	18/02/2024	05:48	T	220 kV Main bus 2 busbar operated

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 17/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 18/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - MUDSHINGI CKT - 2	IntraState	18/02/2024	04:21	18/02/2024	05:53	T	220 kV Main bus 2 busbar operated
TALANDGE - HAMIDWADA	IntraState	18/02/2024	05:21	18/02/2024	05:40	T	220 kV Main bus 2 busbar operated
BOMBAY DYEING - SAHARA	IntraState	18/02/2024	08:44	18/02/2024	18:26	PO	Providing of HVI insulation coating at bottom phase conductor at Loc no. LILO 7 to 8 near Patleshwar Temple. Other routine maintenance work.
PALGHAR - NALASOPARA	IntraState	18/02/2024	09:30	18/02/2024	18:09	PO	Cut point formation work Mono pole loc.no 127 A in respect of shifting height raising of 220 Kv Boisar-Nalasopara Dead line & Palghar -Nalasopara Tr.line between loc.no.127 & 130 for maintaining the electrical clearance for construction of Railway flyover for Virar-Surat line in Palghar & Saphale for PWD under EHV Project Dn, Kalyan.
BHIRA - KARANJADE 7	IntraState	18/02/2024	09:36	18/02/2024	16:45	PO	Closer inspection.
SALSETTE BORIVLI - 2	IntraState	18/02/2024	10:01	18/02/2024	14:24	PO	Closer inspection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	18/02/2024	11:45	18/02/2024	15:52	T	Tripped on Distance protection.
NERLE - PEDAMBE	IntraState	18/02/2024	13:27	18/02/2024	15:41	T	Tripped from Nerle end only due to CB problem
BABHALESHWAR - UTECH SUGAR	IntraState	18/02/2024	15:22	18/02/2024	19:22	PO	In view of tripping on date 16.02.2024 vertical patrolling carried out. at loc. No. 24 R Ph. Flashover string observed same is to be replaced. ALSO monkey patrolling flashover string at loc no 36 R ph , need to be carried out.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	17/02/2024	09:48	18/02/2024	16:18	PO	HV/LV bushing lead measurement work to be carried out.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55			PO	PROJECT WORK-Conductor replacement
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
100 KV LINE Outages/Trippings							
KALWA - SALSETTE CKT - 2	IntraState	18/02/2024	08:00		Continued.	PO	CB Pole OH work after shifting the line on TBC

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage