

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 18/Feb/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	162.112	2932.565	1) Gujrat	0.687	-19.763
2) Hydro	4.798	138.157	2) Madhya Pradesh	6.182	90.114
3) Gas	6.991	120.542	3) Chattisgarh	4.270	67.610
Total MSPGCL	173.901	3191.264	4) Maharashtra	174.117	3171.342
B) 1) APML	61.263	1179.499	5) Goa (Amona)	-1.759	-30.982
2) JSWEL	24.146	435.912	Total	183.497	3278.321
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.835	523.365
4) RPL(AMT)	31.330	566.032	b) Mumbai Drawl	29.056	599.906
5) SWPGPL	12.197	221.906	c) MSEDCL Bilateral *	87.003	1513.030
6) Other IPP	47.445	864.642	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.835	523.362
C) 1) TPCL Thermal	10.890	150.850	Include PX	0.000	0.000
2) TPCL Hydro	1.404	58.952	Standby	0.000	0.003
3) TPCL Gas	3.536	58.815	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.213	175.131	1) MSEDCL	517.721	9375.575
D) STATE			2) Mumbai Discoms	54.099	1043.547
1) Thermal	358.596	6526.537	3) Other Discoms	9.979	187.891
(A1+C1+C4+(B1-B6))			TOTAL STATE	581.799	10607.013
2) Hydro	6.202	197.109			
(A2+C2)					
3) Gas	10.527	179.357			
(A3+B7+C3)					
4) Wind	6.673	146.958			
6) SOLAR	16.304	278.838			
TOTAL STATE	398.302	7328.799			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7063	6374	6758	6481
MSPGCL Hydro	223	198	217	151
MSPGCL Gas	286	274	290	299
MSPGCL Total Generation	7572	6846	7265	6931
Central Sector Receipt	8820	8434	7843	7004
WIND	407	213	328	263
CPP / IPP Thermal	7602	7009	7461	7178
CPP / IPP Gas	0	0	0	0
SOLAR	1949	2377	0	0
Exchange with Mumbai	-1498	-1400	-1468	-1286
MSEDCL DEMAND MET	24426	23059	20979	19663
Load Shedding	0	0	0	0
MSEDCL DEMAND	24426	23059	20979	19663
TPCL GENERATION	626	633	708	623
AEML GENERATION	329	491	317	354
MUMBAI DEMAND	2453	2524	2493	2263
OTHER DISCOM DEMAND	426	420	450	426
STATE DEMAND MET	27305	26003	23922	22353
STATE DEMAND	27305	26003	23922	22353
Frequency (Hz)	50.02	50.07	50.02	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 14.02 Hrs	49.57 Hz at 09.19 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 18/Feb/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.33	79.47	190	165
Unit 8	14.74	260.40	632	590
Unit 9	13.33	237.32	605	490
Unit 10	14.39	239.46	640	571
Total	46.79	816.66		
Bhusawal				
Unit 3	3.56	62.79	180	120
Unit 4	0.00	120.58	0	0
Unit 5	10.92	152.86	495	285
Total	14.48	336.23		
Parli				
Unit 6	3.60	75.95	211	144
Unit 7	3.68	73.94	194	144
Unit 8	3.77	75.79	245	142
Total	11.04	225.68		
Chandrapur				
Unit 3	3.36	59.42	150	120
Unit 4	3.35	62.88	155	122
Unit 5	8.84	150.83	440	265
Unit 6	0.00	35.12	0	0
Unit 7	9.41	128.74	480	287
Unit 8	9.82	169.71	420	333
Unit 9	11.03	193.65	485	338
Total	45.82	800.35		
Paras				
Unit 3	5.76	98.85	252	223
Unit 4	5.92	101.66	257	233
Total	11.67	200.51		
Khaparkheda				
Unit 1	3.28	68.76	170	100
Unit 2	4.27	18.05	194	152
Unit 3	4.10	72.06	176	154
Unit 4	2.47	74.88	189	0
Unit 5	11.18	195.53	485	440
Total	25.30	429.28		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.72	64.18	186	120
Unit 5	3.29	59.68	157	117
Total	7.02	123.86		
Uran				
All Units	6.99	120.54	304	268
Total	6.99	120.54		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	1.27	13	0
Total	0.02	1.27		
Koyna				
Stage 1-2	0.78	31.78	65	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	13.42	0	0
Stage 3	0.19	10.35	80	0
Total	0.97	55.55		
Hydro				
KDPH	0.86	15.55	36	36
VTRNA	0.17	3.19	61	0
TILLARI	0.00	2.67	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.77	50.68	122	107
GHATGHAR	0.00	9.26	0	0
Total	3.80	81.34		
Wind				
Total	6.67	146.96	0	0
Total	6.67	146.96		
CPP				
APML(Mus)	61.26	1179.50	0	0
JSWEL(Mus)	24.15	435.91	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.33	566.03	0	0
SWPGPL-Mus	12.20	221.91	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.95	99.73	270	193
Other(Mus)	39.82	719.41	0	0
JPL	2.68	45.51	113	110
Total	176.38	3267.99		
SOLAR				
Total	16.30	278.84	0	0
Total	16.30	278.84		
Tata				
Trombay 5	7.58	147.18	467	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.14	35.36	108	52
Trombay 7B	1.40	23.45	65	44
TATA Hydro	1.40	58.95	130	15
Trombay 8	3.31	3.67	179	117
Total	15.83	268.62		
AEML				
DTPS U-1&2	9.21	175.13	491	299
Total	9.21	175.13		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	162.11	2932.56	MSPGCL Total	173.90	3191.26
			MSPGCL Thml+Gas	169.10	3053.11	Koyna 1,2 & 4 Total	0.78	45.20
			MSPGCL Hydro	4.80	138.16	State Total	398.30	7328.80

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 18/Feb/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6905	193	298	7396	256	7178	0	0	7505	7167	-989	20594	0	0	20594	2208	414	23216	49.95
2	7018	193	299	7510	245	7198	0	0	7203	6911	-871	20623	0	0	20623	2069	371	23062	49.97
3	7209	193	299	7701	348	7192	0	0	6856	6397	-724	20559	0	0	20559	1968	355	22882	49.97
4	6909	191	299	7399	395	7209	0	0	6791	6676	-650	20683	0	0	20683	1887	346	22916	49.95
5	7035	202	301	7538	334	7217	0	0	6897	6792	-658	20864	0	0	20864	1872	359	23095	49.94
6	7164	203	303	7670	247	7554	0	0	7132	7333	-869	21558	0	0	21558	1896	377	23831	49.94
7	7381	211	304	7896	191	8079	0	3	7079	6934	-928	21794	0	0	21794	1951	382	24126	50.03
8	7206	216	304	7726	149	8159	0	206	7464	7865	-941	22753	0	1	22753	1999	411	25163	50.00
9	7118	287	302	7707	159	8038	0	781	8049	7956	-1146	23077	0	17	23077	2119	418	25614	50.00
10	7095	296	293	7684	362	7578	0	1376	8528	8398	-1358	23621	0	28	23621	2304	419	26344	49.86
11	7063	223	286	7572	407	7602	0	1949	9123	8820	-1498	24426	0	40	24426	2453	426	27305	50.02
12	6587	188	278	7053	291	7230	0	2251	9259	8829	-1492	23732	0	47	23732	2526	430	26688	50.05
13	6374	198	274	6846	213	7009	0	2377	8744	8434	-1400	23059	0	38	23059	2524	420	26003	50.07
14	6129	198	270	6597	221	6902	0	2338	8411	8251	-1494	22406	0	25	22406	2432	409	25247	50.09
15	6071	199	268	6538	236	6962	0	2082	8434	8409	-1517	22283	0	13	22283	2395	427	25105	50.12
16	6276	198	275	6749	257	7037	0	1632	8864	8262	-1488	22006	0	7	22006	2390	443	24839	49.95
17	6251	156	281	6688	299	6979	0	995	8570	8396	-1410	21511	0	3	21511	2350	436	24297	49.88
18	6721	158	286	7165	379	7318	0	312	7711	7462	-1427	20753	0	1	20753	2346	456	23555	50.05
19	6762	201	290	7253	309	7535	0	2	7645	7619	-1411	20855	0	0	20855	2387	451	23694	50.03
20	6758	217	290	7265	328	7461	0	0	7814	7843	-1468	20979	0	0	20979	2493	450	23922	50.02
21	6725	215	296	7236	270	7427	0	0	7333	7188	-1362	20290	0	0	20290	2486	469	23245	50.03
22	6416	157	297	6870	273	7159	0	0	7340	7409	-1379	19897	0	0	19897	2432	435	22764	50.05
23	6458	154	299	6911	241	7180	0	0	7242	7142	-1290	19735	0	0	19735	2349	449	22532	50.01
24	6481	151	299	6931	263	7178	0	0	7223	7004	-1286	19663	0	0	19663	2263	426	22353	49.97
MUs	162.11	4.80	6.99	173.90	6.67	176.38	0.00	16.30	187.22	183.50	-29.06	517.72	0.00	0.22	517.72	54.10	9.98	581.80	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR Carried out due to 132 kV BBLR To Rahuri Line Over Load

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Feb/2024

Position as on 6.30 Hrs of 19/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	29/02/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
MSPGCL	Chandrapur Unit 6	500	06/02/2024	00:01	19/02/2024	17:55	For Planned short shutdown and Airheater Basket replacement.	19/02/2024
Total Capacity MSPGCL		898						
CENT.SECTOR								
CENT.SECTOR	Tarapur 3	540	11/01/2024	21:45		Continued.	Annual Overhaul	29/02/2024
Total Capacity CENT.SECTOR		540						
Total Capacity PLANNED OUTAGE		1438						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Bhusawal Unit 4	500	16/02/2024	02:54		Continued.	PA Fan problem	20/02/2024
MSPGCL	Khaparkheda Unit 4	210	18/02/2024	14:16		Continued.	Boiler Tube Leakage	21/02/2024
MSPGCL	Chandrapur Unit 4	210	19/02/2024	09:58		Continued.	Boiler Tube Leakage	22/02/2024
MSPGCL	Ghatghar Unit-1	125	19/02/2024	18:30		Continued.	GM link fault.	
MSPGCL	Ghatghar Unit-2	125	19/02/2024	18:30	19/02/2024	20:15	GM link fault.	
Total Capacity MSPGCL		1398						
IPP								
IPP	JPL Unit 1	150	13/01/2024	01:00		Continued.	Due to low net sale realisation. (while rolling at 21.00hrs. dtd. 31/01/2024 tripped on high vibration during rolling)	25/02/2024
Total Capacity IPP		150						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 18/Feb/2024

Position as on 6.30 Hrs of 19/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity FORCED OUTAGE		1868						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 18/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 19/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	18/02/2024	13:08	18/02/2024	20:59	PO	Changeover of Rph Reactor with Y ph (765 KV Akola -Ektuni Line-02 non-switchable reactor) for Cable replacement of mechanical protection and CTs for Y ph (Akola - Ektuni line-02 non-switchable Reactor) at Ektuni.
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LR Outages/Trippings							
400KV KORADI-BHILAI (Koradi end)	IntraState	15/02/2024	12:30		Continued.	PO	Overhauling of BHI CGL CB at Koradi SS, 400kv Koradi-Bhilai Line
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 2	InterState	12/02/2024	13:46			PO	1)H/t requires for replacement B Bus Conductor between 500MVA ICT-5 & 400kV Tarapur-II of Sec-I.
PADGHE - TARAPUR CKT - 1	InterState	12/02/2024	14:03			PO	Stringing of diversion work of 400kV Tarapur-Phadga
DHULE - SSNNL CKT - 1	InterState	15/02/2024	09:24			PO	Major Maintenance of GIS
KORADI - BHILAI	InterState	15/02/2024	11:39	18/02/2024	00:01	PO	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Bhilai Line Out of Service.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
105 MVA SPARE ICT @ AKOLA	IntraState	04/02/2024	09:21			EO	for removal of 401 52 circuit breaker of spare ICT for replacement of 40952 B phase CB of Tie Bay 409
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 19/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	12/02/2024	10:28			PO	Erection of CS Type Gantry Beam Structure for RRS Scheme of ICTs
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	18/02/2024	04:21	18/02/2024	05:08	T	220 kV Main bus 2 busbar operated
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	18/02/2024	04:21	18/02/2024	05:42	T	220 kV Main bus 2 busbar operated
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ TALANDGE	IntraState	18/02/2024	04:21	18/02/2024	05:25	T	220 kV Main bus 2 busbar operated
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	31/12/2023	18:05		Continued.	T	Distance Protection, Line is charged from Bapgaon end only for soak test of repaired cable of said line.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS & Waghivali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
MALHARPETH SATARA MIDC	IntraState	17/02/2024	18:47	18/02/2024	00:18	T	B-ph LA blast at Malharpeth
TALANDGE - ICHALKARANJI 2	IntraState	18/02/2024	04:21	18/02/2024	05:14	T	220 kV Main bus 2 busbar operated
TALANDGE - MUDSHINGI CKT - 2	IntraState	18/02/2024	04:21	18/02/2024	05:53	T	220 kV Main bus 2 busbar operated
TALANDGE - BIDRI	IntraState	18/02/2024	04:21	18/02/2024	05:48	T	220 kV Main bus 2 busbar operated
TALANDAGE - FIVE STAR MIDC 2	IntraState	18/02/2024	04:21	18/02/2024	12:43	T	220 kV Main bus 2 busbar operated
TALANDGE - HAMIDWADA	IntraState	18/02/2024	05:21	18/02/2024	05:40	T	220 kV Main bus 2 busbar operated
BOMBAY DYEING - SAHARA	IntraState	18/02/2024	08:44	18/02/2024	18:26	PO	Providing of HVI insulation coating at bottom phae conductor at Loc no. LILO 7 to 8 near Patleshwar Temple. Other routine maintenance work.
PALGHAR - NALASOPARA	IntraState	18/02/2024	09:30	18/02/2024	18:09	PO	Cut point formation work Mono pole loc.no 127 A in respect of shifting height raising of 220 Kv Boisar-Nalasopara Dead line & Palghar -Nalasopara Tr.line between loc.no.127 & 130 for maintaining the electrical clearance for construction of Railway flyover for Virar-Surat line in Palghar & Saphale for PWD under EHV Project Dn, Kalyan.
BHIRA - KARANJADE 7	IntraState	18/02/2024	09:36	18/02/2024	16:45	PO	Closer inspection.
SALSETTE BORIVLI - 2	IntraState	18/02/2024	10:01	18/02/2024	14:24	PO	Closer inspection
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	18/02/2024	11:45	18/02/2024	15:52	T	Tripped on Distance protection.
NERLE - PEDAMBE	IntraState	18/02/2024	13:27	18/02/2024	15:41	T	Tripped from Nerle end only due to CB problem

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 18/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 19/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABHALESHWAR - UTECH SUGAR	IntraState	18/02/2024	15:22	18/02/2024	19:22	PO	In view of tripping on date 16.02.2024 vertical patrolling carried out. at loc. No. 24 R Ph. Flashover string observed same is to be replaced. ALSO monkey patrolling flashover string at loc no 36 R ph , need to be carried out.
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	19/02/2024	08:55	19/02/2024	15:28	T	Tripped on Distance protection
GADCHANDUR - VIRUR-I	IntraState	19/02/2024	10:23	19/02/2024	18:00	HT	Diagnostic testing work.
BUS COUPLER @ VERSOVA	IntraState	19/02/2024	13:09	19/02/2024	17:53	PO	Annual maintenance of CB 552 and CT
MIRAJ - ICHALKARANJI	IntraState	19/02/2024	16:41	19/02/2024	19:07	PO	1)For load management , 220KV Miraj Circuit Kept off for 220KV Talandage Circuit-2
TALANDGE - ICHALKARANJI 2	IntraState	19/02/2024	16:45	19/02/2024	19:00	PO	1) For Quarterly bay maintenance work. 2) Attending hotspots
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	17/02/2024	09:48	18/02/2024	16:18	PO	HV/LV bushing lead measurement work to be carried out.
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	19/02/2024	10:10	19/02/2024	14:45	PO	for Testing work (WRM) on dt.19.02.2024 at 220 kV Five Star MIDC S/Stn.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55			PO	PROJECT WORK-Conductor replacement
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
100 KV LINE Outages/Trippings							
KALWA - SALSETTE CKT - 2	IntraState	18/02/2024	08:00		Continued.	PO	CB Pole OH work after shifting the line on TBC

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage