

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	24	470	260	210	AS PER SYSTEM CONDITION
		30	96	470	260	210	AS PER SYSTEM CONDITION
2	TPC U-8	1	24	229	126	103	AS PER SYSTEM CONDITION
		30	96	229	126	103	AS PER SYSTEM CONDITION
3	DTPS U-1 & U-2	1	23	455	250	205	AS PER SYSTEM CONDITION #
		30	89	455	250	205	AS PER SYSTEM CONDITION #
4	NASIK U-3, U-4 & U-5	1	23	362	204	158	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV
		31	96	362	204	158	
5	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
6	SWPGL to MSEDCL	33	59	154	132	22	AS PER SYSTEM CONDITION/ U-2 OUT
		65	96	154	132	22	AS PER SYSTEM CONDITION/ U-2 OUT
7	BHUSAWAL U-3	33	59	174	104	70	AS PER SYSTEM CONDITION
		65	96	174	104	70	AS PER SYSTEM CONDITION
8	PARALI U-6 & U-7	33	59	400	242	158	AS PER SYSTEM CONDITION
		65	96	400	242	158	AS PER SYSTEM CONDITION
9	PARALI U-8	33	59	190	122	68	AS PER SYSTEM CONDITION
		65	96	190	122	68	AS PER SYSTEM CONDITION
10	DHARIWAL to MSEDCL (Case-IV)	33	58	185	101.75	83.25	AS PER SYSTEM CONDITION
		65	96	185	101.75	83.25	AS PER SYSTEM CONDITION
11	APML U-1,U-4 & U-5 (PPA440 MW)	33	56	440	0	440	AS PER SYSTEM CONDITION
		65	91	440	0	440	AS PER SYSTEM CONDITION
12	APML U-1,U-4 & U-5 (PPA 125 MW)	34	55	125	96	29	AS PER SYSTEM CONDITION
		66	79	125	96	29	AS PER SYSTEM CONDITION
13	APML U-1,U-4 & U-5 (PPA 1200 MW)	34	55	1200	921	279	AS PER SYSTEM CONDITION
		66	79	1200	921	279	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	34	38	1200	675	525	AS PER SYSTEM CONDITION
		66	79	1200	675	525	AS PER SYSTEM CONDITION
15	BHUSAWAL U-4 & U-5	73	79	910	518	392	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	74	78	262	197	65	AS PER SYSTEM CONDITION/ U-2&4 OUT
17	CHANDRAPUR U-3 TO U-7	74	78	378	251	127	AS PER SYSTEM CONDITION/ U-3,4,5&7 OUT
18	PARAS U-3 & U-4	X	X	X	X	X	NO BACK DOWN
19	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
23	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	UNIT OUT

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th Apr 2021