

## STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE:

01/08/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	96	470	260	210	AS PER SYSTEM CONDITION
2	TPC U-8	1	96	229	126	103	AS PER SYSTEM CONDITION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	96	455	250	205	AS PER SYSTEM CONDITION
5	NASIK U-3, U-4 & U-5	1	31	185	102	83	AS PER SYSTEM CONDITION #/ U-3 UNDER CASE IV & U-4 UNDER ZERO SCHEDULE
		52	78	185	102	83	
		83	96	185	102	83	
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARAS U-3 & U-4	1	78	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		82	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
9	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	CHANDRAPUR U-3 TO U-7	1	78	1055	712	343	AS PER SYSTEM CONDITION/ U-7 UNDER ZERO SCHEDULE
		82	96	1055	712	343	
13	BHUSAWAL U-4 & U-5	1	20	940	518	422	AS PER SYSTEM CONDITION
		26	75	940	518	422	AS PER SYSTEM CONDITION
		82	96	940	518	422	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	1	19	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		29	74	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		82	96	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
15	APML U-1,U-4 & U-5 (PPA 440 MW)	1	18	377	0	377	AS PER SYSTEM CONDITION
		46	65	377	0	377	AS PER SYSTEM CONDITION
		71	74	377	0	377	AS PER SYSTEM CONDITION
		83	89	377	0	377	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case- IV)	1	17	185	101.75	83.25	AS PER SYSTEM CONDITION
		49	65	185	101.75	83.25	AS PER SYSTEM CONDITION
		71	74	185	101.75	83.25	AS PER SYSTEM CONDITION
		84	89	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	1	17	107	96	11	AS PER SYSTEM CONDITION
		50	63	107	96	11	AS PER SYSTEM CONDITION
		71	74	107	96	11	AS PER SYSTEM CONDITION
		84	89	107	96	11	AS PER SYSTEM CONDITION
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	1	17	1030	921	109	AS PER SYSTEM CONDITION
		50	63	1030	921	109	AS PER SYSTEM CONDITION
		71	74	1030	921	109	AS PER SYSTEM CONDITION
		84	89	1030	921	109	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	51	62	X	X	X	DC TECH MIN
		71	74	X	X	X	DC TECH MIN
20	CHANDRAPUR U-8 & U-9	51	62	400	259	141	AS PER SYSTEM CONDITION/ U-9 OUT
		71	74	400	259	141	AS PER SYSTEM CONDITION/ U-9 OUT
21	KORADI U-8 TO U-10	51	59	910	682	228	AS PER SYSTEM CONDITION/ U-8 OUT
		71	74	910	682	228	AS PER SYSTEM CONDITION/ U-8 OUT
22	APML U-2 & U-3	51	58	1040	678	362	AS PER SYSTEM CONDITION
23	JSW U-1	52	58	290	160	130	AS PER SYSTEM CONDITION
24	SWPGL to BEST	53	58	100	66	34	AS PER SYSTEM CONDITION

## Note :

- MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.  
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- # Indicates that back down withdrawn due to Line loading/system constraints.
- \* Indicates that back down implemented due to Line loading/system constraints.
- Revised MOD Rates effective from 00:00 hrs of 30th July 2021
- Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.