

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

02/08/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	34	470	260	210	AS PER SYSTEM CONDITION
		41	71	470	260	210	AS PER SYSTEM CONDITION
		81	96	470	260	210	AS PER SYSTEM CONDITION
2	TPC U-8	1	34	229	126	103	AS PER SYSTEM CONDITION
		41	70	229	126	103	AS PER SYSTEM CONDITION
		81	96	229	126	103	AS PER SYSTEM CONDITION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	33	455	250	205	AS PER SYSTEM CONDITION
		41	68	455	250	205	AS PER SYSTEM CONDITION
		83	96	455	250	205	AS PER SYSTEM CONDITION
5	NASIK U-3, U-4 & U-5	1	33	185	102	83	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV & U-4 UNDER ZERO SCHEDULE
		45	67	185	102	83	
		87	96	185	102	83	
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARAS U-3 & U-4	1	33	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		45	66	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		87	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
9	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	CHANDRAPUR U-3 TO U-7	1	32	1055	712	343	AS PER SYSTEM CONDITION/ U-7 UNDER ZERO SCHEDULE
		45	64	1055	712	343	
		89	96	1055	712	343	
13	BHUSAWAL U-4 & U-5	1	22	940	518	422	AS PER SYSTEM CONDITION
		47	61	940	518	422	AS PER SYSTEM CONDITION
		90	96	940	518	422	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	1	21	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		47	51	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		91	96	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
15	APML U-1,U-4 & U-5 (PPA 440 MW)	1	18	337	4	333	AS PER SYSTEM CONDITION
		95	96	337	4	333	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case-IV)	1	18	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	1	18	X	X	X	DC TECH MIN
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	1	18	X	X	X	DC TECH MIN
19	KHAPERKHEDA U-5	1	18	432	256	176	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-8 & U-9	2	17	423	259	164	AS PER SYSTEM CONDITION/ U-9 OUT
21	KORADI U-8 TO U-10	6	17	935	682	253	AS PER SYSTEM CONDITION/ U-8 OUT
22	APML U-2 & U-3	12	16	1040	678	362	AS PER SYSTEM CONDITION
23	JSW U-1	X	X	X	X	X	NO BACKING DOWN
24	SWPGL to BEST	X	X	X	X	X	NO BACKING DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 30th July 2021
- 6 Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.