

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

03/08/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	23	470	260	210	AS PER SYSTEM CONDITION
		52	63	470	260	210	AS PER SYSTEM CONDITION
		92	96	470	260	210	AS PER SYSTEM CONDITION
2	TPC U-8	1	23	229	126	103	AS PER SYSTEM CONDITION
		52	58	229	126	103	AS PER SYSTEM CONDITION
		92	96	229	126	103	AS PER SYSTEM CONDITION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	23	455	250	205	AS PER SYSTEM CONDITION
		54	58	455	250	205	AS PER SYSTEM CONDITION
		95	96	455	250	205	AS PER SYSTEM CONDITION
5	NASIK U-3, U-4 & U-5	1	23	185	102	83	AS PER SYSTEM CONDITION/ U-3 UNDER
		55	58	185	102	83	CASE IV & U-4 UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARAS U-3 & U-4	1	22	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		55	58	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
9	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	CHANDRAPUR U-3 TO U-7	1	21	1042	712	330	AS PER SYSTEM CONDITION/ U-7 UNDER
		55	58	1042	712	330	ZERO SCHEDULE
13	BHUSAWAL U-4 & U-5	1	20	940	518	422	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	1	18	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
15	APML U-1,U-4 & U-5 (PPA 440 MW)	1	8	337	4	333	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case-IV)	1	8	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	NO BACKING DOWN
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	NO BACKING DOWN
19	KHAPERKHEDA U-5	X	X	X	X	X	NO BACKING DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACKING DOWN
21	KORADI U-8 TO U-10	X	X	X	X	X	NO BACKING DOWN
22	APML U-2 & U-3	X	X	X	X	X	NO BACKING DOWN
23	JSW U-1	X	X	X	X	X	NO BACKING DOWN
24	SWPGL to BEST	X	X	X	X	X	NO BACKING DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 30th July 2021
- 6 Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.