

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

4-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	32	483	145	338	AS Per MOD
		33	44				DUE TO SYSTEM CONDITION
		69	81				AS Per MOD
		82	96				DUE TO SYSTEM CONDITION
		45	68	483	250	233	DUE TO SYSTEM CONDITION
2	GEPL-TPCD	x	x	x	x	x	NO SCHEDULE
3	NASIK	11	31	516	465	51	AS Per MOD
		32	37				DUE TO SYSTEM CONDITION
		72	77				AS Per MOD
4	BHUSAWAL 2,3	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	JSW U-2,4-MSEDCL	13	24	250	175	75	AS Per MOD
		25	31	250	175	75	DUE TO SYSTEM CONDITION
		73	77	250	175	75	AS Per MOD
6	TPC U-5	14	25	473	290	183	DUE TO SYSTEM CONDITION
		26	30	473	400	73	AS PER MOD
		35	36	473	430	43	DUE TO SYSTEM CONDITION
		73	77	473	280	193	AS PER MOD
7	TPC U-8	14	22	235	180	55	DUE TO SYSTEM CONDITION
8	KORADI 5,6,7	16	20	432	425	7	DUE TO SYSTEM CONDITION
9	PARLI 3,4,5	x	x	x	x	x	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
10	REL G	16	20	478	360	118	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View

2 MOD rates revised w.e.f 18-April-2013.