

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2 3 AND 4 TO BEST 2	1	96	50	35	15	AS PER SYSTEM CONDITION
2	JSW U-2 3 AND 4 TO BEST	1	96	60	42	18	AS PER SYSTEM CONDITION
3	DTPS U-1 & U-2	1	22	456	336	120	AS PER SYSTEM CONDITION
		23	30	X	X	X	#
		31	42	456	336	120	AS PER SYSTEM CONDITION
		43	52	X	X	X	#
		53	96	456	336	120	AS PER SYSTEM CONDITION
4	JSW TO AEML	1	48	258	180.6	77.4	AS PER SYSTEM CONDITION
		53	96	258	180.6	77.4	AS PER SYSTEM CONDITION
5	VIPL U-1 & U-2	X	X	X	X	X	UNIT OUT DUE TO COAL SHORTAGE
6	PARALI U-6 & U-7	X	X	X	X	X	ZERO SCHEDULE BY MSEDCL
7	DHARIWAL TO AEML	1	48	160	112	48	AS PER SYSTEM CONDITION
		53	96	160	112	48	AS PER SYSTEM CONDITION
8	TPC U-8	1	22	220	172	48	AS PER SYSTEM CONDITION
		23	30	X	X	X	#
		31	44	220	172	48	AS PER SYSTEM CONDITION
		45	61	X	X	X	#
		62	96	220	172	48	AS PER SYSTEM CONDITION
9	TPC U-5	1	22	473	292	111	AS PER SYSTEM CONDITION
		23	30	X	X	X	#
		31	44	473	292	111	AS PER SYSTEM CONDITION
		45	61	X	X	X	#
		62	90	473	292	111	AS PER SYSTEM CONDITION
10	PARALI U-8	1	22	473	292	111	AS PER SYSTEM CONDITION
		23	30	X	X	X	#
11	BHUSAWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY MSEDCL
12	RATTANINDIA U-1 TO U-5	1	59	1200	860	340	AS PER SYSTEM CONDITION
		63	90	1200	860	340	AS PER SYSTEM CONDITION
		96	96	1200	860	340	AS PER SYSTEM CONDITION
13	NASHIK U-3, U-4 & U-5	1	57	561	425	136	AS PER SYSTEM CONDITION
		66	90	561	425	136	AS PER SYSTEM CONDITION
		96	96	561	425	136	AS PER SYSTEM CONDITION
14	KORADI U-8 TO U-10	1	57	1316	1296	20	AS PER SYSTEM CONDITION
		66	90	1316	1296	20	AS PER SYSTEM CONDITION
15	KORADI U-6 & U-7	1	57	306	306	0	AS PER SYSTEM CONDITION
		66	90	306	306	0	AS PER SYSTEM CONDITION
16	BHUSAWAL U-4 & U-5	1	56	940	644	296	AS PER SYSTEM CONDITION
		66	89	940	644	296	AS PER SYSTEM CONDITION
17	JSW U-1	1	41	285	200	85	AS PER SYSTEM CONDITION
		45	48	285	200	85	AS PER SYSTEM CONDITION
		53	56	285	200	85	AS PER SYSTEM CONDITION
		66	80	285	200	85	AS PER SYSTEM CONDITION
		84	89	285	200	85	AS PER SYSTEM CONDITION
18	ADANI U-1, U-4 & U-5 (PPA 440 MW)	1	41	440	0	440	AS PER SYSTEM CONDITION
		45	48	440	0	440	AS PER SYSTEM CONDITION
		53	56	440	0	440	AS PER SYSTEM CONDITION
		66	77	440	0	440	AS PER SYSTEM CONDITION
		84	89	440	0	440	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-3 TO U-7	1	41	1552	1282	270	AS PER SYSTEM CONDITION
		46	48	1552	1282	270	AS PER SYSTEM CONDITION
		54	56	1552	1282	270	AS PER SYSTEM CONDITION
		67	77	1552	1282	270	AS PER SYSTEM CONDITION
		85	89	1552	1282	270	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-1(PPA 1200MW&125MW)	8	40	918	864	54	AS PER SYSTEM CONDITION
		46	48	918	864	54	AS PER SYSTEM CONDITION
		54	56	918	864	54	AS PER SYSTEM CONDITION
		68	77	918	864	54	AS PER SYSTEM CONDITION
		85	89	918	864	54	AS PER SYSTEM CONDITION
21	PARAS U-3 & U-4	8	38	458	332	126	AS PER SYSTEM CONDITION
		46	48	458	332	126	AS PER SYSTEM CONDITION
		71	77	458	332	126	AS PER SYSTEM CONDITION
		85	89	458	332	126	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-8 & U-9	17	22	940	658	282	AS PER SYSTEM CONDITION
		27	38	940	658	282	AS PER SYSTEM CONDITION
		71	77	940	658	282	AS PER SYSTEM CONDITION
23	KHAPERKHEDA U-1 TO U-4	18	22	504	504	0	AS PER SYSTEM CONDITION
		27	38	504	504	0	AS PER SYSTEM CONDITION
24	KHAPERKHEDA U-5	18	22	475	332	143	AS PER SYSTEM CONDITION
		27	38	475	332	143	AS PER SYSTEM CONDITION
25	ADANI U-2 & 3	21	22	1246	864	382	AS PER SYSTEM CONDITION
		27	37	1246	864	382	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.

Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH MAY- 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.