

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 4-Aug-16 |
|--|------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|--|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | x | x | X | X | X | UNIT SHUTDOWN |
| 2 | NASIK | 1 | 96 | 354 | 283 | 71 | AS PER SYSTEM CONDITION ; UNIT-5 ZERO SCHEDULE BY MSEDCL |
| 3 | BHUSWAL U 2,3 | X | X | X | X | X | MSEDCL W/DN UNIT-3 FOR ZERO SCHEDULE AND UNIT-2SHUT DOWN |
| 4 | REL DAHANU U 1&2 | 1 | 72 | 465 | 336 | 129 | AS PER SYSTEM CONDITION |
| | | 73 | 80 | X | X | X | # |
| | | 81 | 96 | 465 | 336 | 129 | AS PER SYSTEM CONDITION |
| 5 | BHUSWAL U-4 & 5 | x | x | X | X | X | UNIT-4 CONVERTED TO AOH 17/07/2016AND UNIT-5 W/DN BY MSEDCLFOR ZERO SCHEDULE |
| 6 | TPC U-8 | 1 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 7 | TPC U-5 | 1 | 43 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 44 | 52 | X | X | X | # |
| | | 53 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 8 | RATTAN INDIA U1 TO U5 | x | x | X | X | X | MSEDCL W/DN UNIT- 1 TO 5 FOR ZERO SCHEDULE |
| 9 | KORADI U-5 TO U-7 | x | x | X | X | X | UNIT-6 SHUT DOWN UNIT-5 AND UNIT-7 W/DN BY MSEDCL FOR ZERO SCHEDULE |
| 10 | KHAPERKHEDA U1 TO U4 | X | X | X | X | X | AS PER SYSTEM CONDITION UNIT-4 W/DN AOH . MSEDCL W/DN UNIT-2 UNIT-3 UNIT-1 FOR ZERO SCHEDULE |
| 11 | VIPL U1&2 | 1 | 96 | 273 | 191 | 82 | AS PER SYSTEM CONDITION |
| 12 | ADANI U-1 | 1 | 78 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| 13 | ADANI U-4 | x | x | x | x | x | UNIT W/DN FOR ZERO SCHEDULE BY MSEDCL |
| 14 | ADANI U-5 | 1 | 78 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| 15 | PARAS U-3 AND U-4 | 1 | 27 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| | | 34 | 44 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| | | 45 | 61 | 365 | 299 | 66 | AS PER SYSTEM CONDITION and DC REV IN U-4 |
| | | 62 | 78 | 230 | 164 | 66 | AS PER SYSTEM CONDITION AND U-4 TRIPPED AT 15:20 HRS |
| | | 89 | 96 | 412 | 332 | 80 | AS PER SYSTEM CONDITION; U4 SYN AT 18:53 HRS. |
| 16 | CHANDRAPUR U-3 to 7 | 1 | 27 | 1423 | 1282 | 141 | AS PER SYSTEM CONDITION |
| | | 34 | 78 | 1423 | 1282 | 141 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 1423 | 1282 | 141 | AS PER SYSTEM CONDITION |
| 17 | KHAPERKHEDA U-5 | 1 | 27 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 34 | 78 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| 18 | KORADI U-8 | 1 | 32 | x | x | x | UNIT SHUT DOWN |
| | | 33 | 78 | 620 | 432 | 188 | UNIT SYN AT 7:28 HRS |
| | | 90 | 96 | 620 | 432 | 188 | AS PER SYSTEM CONDITION |
| 19 | CHANDRAPUR U-8 | X | X | X | X | X | UNIT SHUT DOWN |
| 20 | ADANI U-3 | 1 | 23 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 35 | 76 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 90 | 96 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| 21 | ADANI U-2 | X | X | X | X | X | UNIT SHUT DOWN |
| 22 | JSW U-1 | 1 | 15 | 290 | 200 | 90 | AS PER SYSTEM CONDITION |
| | | 36 | 75 | 290 | 200 | 90 | AS PER SYSTEM CONDITION |
| | | 92 | 96 | 290 | 200 | 90 | AS PER SYSTEM CONDITION |

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM 12 TH OF JULY 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.