

## STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE:

04/08/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	18	470	260	210	AS PER SYSTEM CONDITION #
		29	35	470	260	210	AS PER SYSTEM CONDITION #
		45	73	470	260	210	AS PER SYSTEM CONDITION #
		81	96	470	260	210	AS PER SYSTEM CONDITION #
2	TPC U-8	1	18	229	126	103	AS PER SYSTEM CONDITION #
		29	35	229	126	103	AS PER SYSTEM CONDITION #
		49	73	229	126	103	AS PER SYSTEM CONDITION #
		81	96	229	126	103	AS PER SYSTEM CONDITION #
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	18	455	250	205	AS PER SYSTEM CONDITION #
		29	35	455	250	205	AS PER SYSTEM CONDITION #
		52	73	455	250	205	AS PER SYSTEM CONDITION #
		81	96	455	250	205	AS PER SYSTEM CONDITION #
5	NASIK U-3, U-4 & U-5	5	35	185	102	83	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV & U-4 UNDER ZERO SCHEDULE
		41	73	185	102	83	
		81	96	185	102	83	
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
8	PARAS U-3 & U-4	5	35	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		41	73	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		81	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
9	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	7	35	494	309	185	AS PER SYSTEM CONDITION/ U-1 OUT
		41	73	494	309	185	AS PER SYSTEM CONDITION/ U-1 OUT
		81	96	494	309	185	AS PER SYSTEM CONDITION/ U-1 OUT
12	CHANDRAPUR U-3 TO U-7	7	18	1236	963	273	AS PER SYSTEM CONDITION
		41	59	1236	963	273	AS PER SYSTEM CONDITION
		69	73	1236	963	273	AS PER SYSTEM CONDITION
		81	91	1236	963	273	AS PER SYSTEM CONDITION
		42	47	855	518	337	AS PER SYSTEM CONDITION
13	BHUSAWAL U-4 & U-5	53	59	855	518	337	AS PER SYSTEM CONDITION
		88	90	855	518	337	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	53	56	980	740	240	AS PER SYSTEM CONDITION/ U-3 OUT
15	APML U-1,U-4 & U-5 (PPA 440 MW)	X	X	X	X	X	NO BACKING DOWN
16	DHARIWAL to MSEDCL (Case-IV)	X	X	X	X	X	NO BACKING DOWN
17	APML U-1,U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	NO BACKING DOWN
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	NO BACKING DOWN
19	KHAPERKHEDA U-5	X	X	X	X	X	NO BACKING DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACKING DOWN
21	KORADI U-8 TO U-10	X	X	X	X	X	NO BACKING DOWN
22	APML U-2 & U-3	X	X	X	X	X	NO BACKING DOWN
23	JSW U-1	X	X	X	X	X	NO BACKING DOWN
24	SWPGL to BEST	X	X	X	X	X	NO BACKING DOWN

## Note :

- MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- # Indicates that back down withdrawn due to Line loading/system constraints.
- \* Indicates that back down implemented due to Line loading/system constraints.
- Revised MOD Rates effective from 00:00 hrs of 30th July 2021
- Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.