

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 4-Nov-16							4-Nov-16
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASIK	1	33	364	283	81	UNIT-4W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		58	68	364	283	81	UNIT-4W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		84	96	364	283	81	UNIT-4W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
3	REL DAHANU U 1&2	1	33	467	336	131	AS PER SYSTEM CONDITION
		58	68	467	336	131	aS PER SYSTEM CONDITION
		84	96	467	336	131	AS PER SYSTEM CONDITION
4	BHUSWAL U-2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE
5	RATTANINDIA U1 TO U5	X	X	X	X	X	UNIT-1syn. At 9:11HRS AND UNIT-4 SYN. AT 15:16HRS UNIT-2 ,3,5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		58	65	245	172	73	UNIT-1syn. At 9:11HRS AND UNIT-4 SYN. AT 15:16HRS UNIT-2 ,3,5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		84	96	490	344	146	UNIT-1syn. At 9:11HRS AND UNIT-4 SYN. AT 15:16HRS UNIT-2 ,3,5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
6	TPC U8	1	32	235	187	48	AS PER SYSTEM CONDITION
		58	65	235	187	48	AS PER SYSTEM CONDITION
		84	96	235	187	48	AS PER SYSTEM CONDITION
7	TPC U5	1	32	473	292	181	AS PER SYSTEM CONDITION
		58	65	473	292	181	AS PER SYSTEM CONDITION
		84	96	473	292	181	AS PER SYSTEM CONDITION
8	VIPL U1&2	1	31	546	382	164	AS PER SYSTEM CONDITION
		58	65	546	382	164	AS PER SYSTEM CONDITION
		86	96	546	382	164	AS PER SYSTEM CONDITION
9	BHUSWAL U-4 &U-5	1	24	940	644	296	AS PER SYSTEM CONDITION
		86	96	940	644	296	AS PER SYSTEM CONDITION
10	KORADI U5 TO U7	X	X	X	X	X	UNIT-6 SHUT DOWN UNI-5 SHUT DOWN AND UNIT-7 D.C TECH MIN
11	PARLEY U-6 AND U-7	1	24	458	332	126	B/D AS PER SYSTEM CONDITION
		86	96	229	166	63	UNIT-6 TRIPPED AT 16:43HRS B/D AS PER SYSTEM CONDITION
12	KHAPERKHEDA U1 TO U4	1	24	543	431	112	UNIT-4 SHUT DOWNAS PER SYSTEM CONDITION
		86	96	362	284	78	UNIT-4 SHUT DOWN ,UNIT-1 TRIPPED AT 18:08 SYN. 21:00HRSAND AGAIN TRIPPED AT 21:03HRS AS PER SYSTEM CONDITION
13	CHANDRAPUR U3 TO U7	1	23	1594	1282	312	AS PER SYSTEM CONDITION
		86	96	1594	1282	312	AS PER SYSTEM CONDITION
14	PARAS U-3 AND U-4	1	23	230	168	62	UNIT-3 SHUT DOWN B/DAS PER SYSTEM CONDITION
		86	96	230	168	62	UNIT-3 SHUT DOWN B/DAS PER SYSTEM CONDITION
15	KHAPERKHEDA U5	1	23	475	335	140	AS PER SYSTEM CONDITION
		86	96	475	335	140	AS PER SYSTEM CONDITION
16	ADANI U1	1	23	466.33	432	34.33	AS PER SYSTEM CONDITION
		88	96	439.67	432	7.67	AS PER SYSTEM CONDITION
17	ADANI U4	1	23	466.33	432	34.33	AS PER SYSTEM CONDITION
		88	96	439.67	432	7.67	AS PER SYSTEM CONDITION
18	ADANI U5	1	23	466.33	432	34.33	AS PER SYSTEM CONDITION
		88	96	439.67	432	7.67	AS PER SYSTEM CONDITION
19	CHANDRAPUR U8	1	23	474	329	145	AS PER SYSTEM CONDITION
		88	96	474	329	145	AS PER SYSTEM CONDITION
20	KORADIU8	1	23	X	X	X	D.C BELOW TECH MIN
		88	96	X	X	X	D.C BELOW TECH MIN
21	ADANI U-2	1	4	623	432	191	AS PER SYSTEM CONDITION
		15	23	623	565	58	AS PER SYSTEM CONDITION
		89	96	610	432	178	AS PER SYSTEM CONDITION
22	ADANI U-3	1	4	623	432	191	AS PER SYSTEM CONDITION
		15	23	623	565	58	AS PER SYSTEM CONDITION
		89	96	600	432	168	AS PER SYSTEM CONDITION
23	JSW U-1	X	X	X	X	X	AS PER SYSTEM CONDITION

X

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD RATES REVISION1 EFFECTIVE FROM 20CCT 2016
- # Indicates that back down withdrawn due to Line loading/system constraints.