

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASIK U-3, U-4 & U-5	1	96	177	102	75	AS PER SYSTEM CONDITION*/ U-3 OUT & U-5 UNDER CASE-IV
2	JSWEL TO AEML DA	X	X	X	X	X	NO TRANSACTION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	25	455	250	205	AS PER SYSTEM CONDITION #
		50	61	455	250	205	AS PER SYSTEM CONDITION #
		71	96	455	250	205	AS PER SYSTEM CONDITION #
5	RATTANINDIA U-1 TO U-5	1	24	245	135	110	AS PER SYSTEM CONDITION/ U-1,3,4&5 UNDER ZERO SCHEDULE
		51	59	245	135	110	
		71	96	245	135	110	
6	KORADI U-6 & U-7	1	23	315	206	109	AS PER SYSTEM CONDITION
		51	59	315	206	109	AS PER SYSTEM CONDITION
		71	96	315	206	109	AS PER SYSTEM CONDITION
7	TPC U-5	1	22	470	260	210	AS PER SYSTEM CONDITION #
		51	58	470	260	210	AS PER SYSTEM CONDITION #
		71	96	470	260	210	AS PER SYSTEM CONDITION #
8	SWPGL to MSEDCL	1	22	170	132	38	AS PER SYSTEM CONDITION
		51	58	170	132	38	AS PER SYSTEM CONDITION
		73	96	170	132	38	AS PER SYSTEM CONDITION
9	PARALI U-6 & U-7	1	22	454	242	212	AS PER SYSTEM CONDITION
		51	58	454	242	212	AS PER SYSTEM CONDITION
		73	96	454	242	212	AS PER SYSTEM CONDITION
10	TPC U-8	1	22	229	126	103	AS PER SYSTEM CONDITION #
		54	58	229	126	103	AS PER SYSTEM CONDITION #
		73	96	229	126	103	AS PER SYSTEM CONDITION #
11	PARALI U-8	1	22	229	122	107	AS PER SYSTEM CONDITION
		54	58	229	122	107	AS PER SYSTEM CONDITION
		73	96	229	122	107	AS PER SYSTEM CONDITION
12	APML U-1,U-4 & U-5 (PPA440 MW)	1	20	440	0	440	AS PER SYSTEM CONDITION
		54	57	440	0	440	AS PER SYSTEM CONDITION
		73	96	440	0	440	AS PER SYSTEM CONDITION
13	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	20	1399	1017	382	AS PER SYSTEM CONDITION
		81	96	1399	1017	382	AS PER SYSTEM CONDITION
14	DHARIWAL to MSEDCL (Case-IV)	1	18	185	101.75	83.25	AS PER SYSTEM CONDITION
		82	96	185	101.75	83.25	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-1 TO U-4	1	18	498	310	188	AS PER SYSTEM CONDITION/ U-3 OUT
		82	96	498	310	188	AS PER SYSTEM CONDITION/ U-3 OUT
16	CHANDRAPUR U-3 TO U-7	1	2	1056	712	344	AS PER SYSTEM CONDITION/ U-7 OUT
		7	18	1056	712	344	AS PER SYSTEM CONDITION/ U-7 OUT
		82	96	1056	712	344	AS PER SYSTEM CONDITION/ U-7 OUT
17	PARAS U-3 & U-4	7	16	431	243	188	AS PER SYSTEM CONDITION
		94	96	431	243	188	AS PER SYSTEM CONDITION
18	BHUSAWAL U-4 & U-5	8	13	940	518	422	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
21	JSW U-1	X	X	X	X	X	NO BACK DOWN
22	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
23	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
24	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 26TH Nov 2020