

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	38	516	425	91	AS PER MOD
		54	71	516	479	37	
		79	96	516	425	91	
3	PARALI 3,4,5	1	32	302	276	26	AS PER MOD
		79	96				
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	JSW U 3,4 TO RINFRA DA (JSWPTC) VARIABLE SCH.GIVEN FROM BLK(33-81)	X	X	X	X	X	X
6	PARALI-7	1	29	180	166	14	AS PER MOD
		80	96				
7	PARALI-6	1	29	180	166	14	AS PER MOD
		80	96				
8	BHUSAWAL-4	1	29	381	322	59	AS PER MOD
		80	96				
9	TPC U-5	1	29	473	292	181	AS PER MOD
		84	96				
10	TPC U-8	1	25	235	172	63	AS PER MOD
		84	96				DUE TO SYSTEM CONDITION
11	KORADI 5,6,7	1	24	342	310	32	AS PER MOD
		86	96				
12	REL G	1	24	237	167	70	AS PER MOD
		86	96				
13	KHAPER KHEDA U 1 TO 4	1	22	652	572	80	AS PER MOD
		87	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	KHAPERKHEDA-U5	1	22	470	335	135	AS PER MOD
		89	96	376	335	41	DUE TO SYSTEM CONDITION
15	CHANDRAPUR	1	21	1400	1206	194	AS PER MOD
16	INDIABULL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
17	PARAS -U3	2	4	210	164	46	DUE TO SYSTEM CONDITION
		5	21				AS PER MOD
		93	96	191	164	27	DUE TO SYSTEM CONDITION
18	PARAS U4	2	5	210	168	42	DUE TO SYSTEM CONDITION
		6	18				AS PER MOD
		19	20				DUE TO SYSTEM CONDITION
		93	96				
19	APML U-1	2	20	605	500	105	DUE TO SYSTEM CONDITION
		29	96	605	432	173	DUE TO SPS OPERATION
20	JSW U-1	2	20	275	200	75	DUE TO SYSTEM CONDITION
		93	96				

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2013.