

| SR. NO. | GENERATING STN. / STOA          | Backing Down Period (in Time Block) |    | TARGET DESPATCHED SCHEDULE (in MW) |                               | Backing Down Quantum (Max) in MW [A-B] | REMARK   |
|---------|---------------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|--|
|         |                                 | FROM                                | TO | Declared Capacity (A)              | Despatched Schedule (Min) (B) |  |  |
| 1       | DHARIWAL TO MSEDCL (DA)         | 2                                   | 58 | 70                                 | 49                            | 21                                     | AS PER SYSTEM CONDITION                                |
|         |                                 | 72                                  | 79 | 70                                 | 49                            | 21                                     | AS PER SYSTEM CONDITION                                |
| 2       | JSW TO MSEDCL                   | 2                                   | 58 | 220                                | 154                           | 66                                     | AS PER SYSTEM CONDITION                                |
|         |                                 | 72                                  | 79 | 220                                | 154                           | 66                                     | AS PER SYSTEM CONDITION                                |
| 3       | SWPCL TO MSEDCL                 | 2                                   | 58 | 100                                | 80                            | 20                                     | AS PER SYSTEM CONDITION                                |
|         |                                 | 72                                  | 79 | 100                                | 80                            | 20                                     | AS PER SYSTEM CONDITION                                |
| 4       | TPC U-8                         | 2                                   | 36 | 204                                | 187                           | 17                                     | AS PER SYSTEM CONDITION                                |
|         |                                 | 37                                  | 57 | X                                  | X                             | X                                      | #  |
|         |                                 | 72                                  | 79 | X                                  | X                             | X                                      | #  |
| 5       | TPC U-5                         | 2                                   | 36 | 473                                | 292                           | 181                                    | AS PER SYSTEM CONDITION                                |
|         |                                 | 37                                  | 57 | X                                  | X                             | X                                      | #  |
|         |                                 | 72                                  | 79 | X                                  | X                             | X                                      | #  |
| 6       | DTPS REL U-1 AND U-2            | 2                                   | 36 | 458                                | 336                           | 122                                    | AS PER SYSTEM CONDITION                                |
|         |                                 | 37                                  | 57 | X                                  | X                             | X                                      | #  |
|         |                                 | 72                                  | 79 | X                                  | X                             | X                                      | #  |
| 7       | JSW TO BEST                     | 2                                   | 56 | 100                                | 70                            | 30                                     | AS PER SYSTEM CONDITION                                |
|         |                                 | 72                                  | 79 | 100                                | 70                            | 30                                     | AS PER SYSTEM CONDITION                                |
| 8       | NASIK U-3,4 AND 5               | 9                                   | 56 | 345                                | 284                           | 61                                     | AS PER SYSTEM CONDITION                                |
| 9       | PARALI U-6 AND U-7              | 9                                   | 56 | 458                                | 332                           |  | AS PER SYSTEM CONDITION                                |
| 10      | BHUSWAL U-3                     | X                                   | X  | X                                  | X                             | X                                      | UNIT SHUT DOWN   |
| 11      | PARALI U-8                      | 9                                   | 56 | 229                                | 166                           |  | AS PER SYSTEM CONDITION                                |
| 12      | VIPL U-1 AND U-2                | 9                                   | 56 | 356                                | X                             | X                                      | D.C. TECH MIN  |
| 13      | RATTANINDIA U-1 TO U-5          | 9                                   | 56 | 735                                | 516                           | 219                                    | UNIT -1 AND UNIT-2 SHUT DOWN AS PER SYSTEM CONDITION   |
| 14      | BHUSWAL U-4 AND U-5             | 35                                  | 40 | 772                                | 644                           | 128                                    | AS PER SYSTEM CONDITION                                |
|         |                                 | 45                                  | 54 | 722                                | 644                           | 78                                     | AS PER SYSTEM CONDITION                                |
| 15      | PARAS U-3 &U-4                  | 46                                  | 54 | 460                                | 332                           | 128                                    | AS PER SYSTEM CONDITION                                |
| 16      | IEPL TO MSEDCL                  | 46                                  | 54 | 172                                | X                             | X                                      | D.C. TECH MIN  |
| 17      | DHARIWAL TO MSEDCL              | 46                                  | 54 | 185                                | 130                           | 55                                     | AS PER SYSTEM CONDITION                                |
| 18      | KHAPERKHEDA U-1 TO U-4          | 46                                  | 54 | X                                  | X                             | X                                      | D.C BELOW TECH MIN                                     |
| 19      | ADANI (TIRODA 440MW PPA) U1,4&5 | 46                                  | 54 | X                                  | X                             | X                                      | D.C. BELOW TECH MIN                                    |
| 20      | KHAPERKHEDA U-5                 | 46                                  | 53 | 333                                | X                             | X                                      | D.C. BELOW TECH MIN                                    |
| 21      | ADANI U-1(1200+125)MW PP        | 46                                  | 53 | 300                                | X                             | X                                      | D.C. TECH MIN  |
| 22      | ADANI U-4(1200+125)MW PP        | 46                                  | 53 | 300                                | X                             | X                                      | D.C. TECH MIN  |
| 23      | ADANI U-5(1200+125)MW PP        | X                                   | X  | X                                  | X                             | X                                      | UNIT SHUT DOWN   |
| 24      | KORADI U-6&U-7                  | 46                                  | 53 | X                                  | X                             | X                                      | UNIT-6 SHUT DOWN D.C. TECH MIN                         |
| 25      | KORADI U-8,9 &U-10              | 46                                  | 53 | X                                  | X                             | X                                      | D.C.TECH MIN unit-8 SHUT DOWN                          |
| 26      | JSW U-1                         | 46                                  | 53 | 250                                | 200                           | 50                                     | AS PER SYSTEM CONDITION                                |
| 27      | CHANDRAPUR U-3 TO U-7           | 46                                  | 53 | 846                                | 660                           | 186                                    | UNIT-3 UNIT-4 UNIT-6 SHUT DOWN AS PER SYSTEM CONDITION |
| 28      | CHANDRAPUR U-8 &U-9             | X                                   | X  | X                                  | X                             | X                                      | NO BACK DOWN   |
| 29      | ADANI U-2                       | X                                   | X  | X                                  | X                             | X                                      | NO BACK DOWN   |
| 30      | ADANI U-3                       | X                                   | X  | X                                  | X                             | X                                      | NO BACK DOWN   |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT 12-May-18

3 # Indicates that back down withdrawn due to Line loading/system constraints.