

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DTPS REL U-1 AND U-2	1	96	458	336	122	AS PER SYSTEM CONDITION
2	TPC U-5	1	35	473	292	181	AS PER SYSTEM CONDITION
		42	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	35	204	187	17	AS PER SYSTEM CONDITION
		42	96	204	187	17	AS PER SYSTEM CONDITION
4	NABK U-3,4 AND 5	1	35	172	142	30	AS PER SYSTEM CONDITION unit-5 with for zero schedule by msedclat00hrs of 12/07/2018
		43	96	172	142	30	AS PER SYSTEM CONDITION unit-5 with for zero schedule by msedclat00hrs of 12/07/2018
5	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U-1 TO U-5	1	22	1200	860	340	AS PER SYSTEM CONDITION
		43	77	1200	860	340	AS PER SYSTEM CONDITION
		81	96	1200	860	340	AS PER SYSTEM CONDITION
7	PARALI U-6&U-7	1	21	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
		46	77	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
		83	96	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
8	BHUSWAL U-4 AND U-5	1	21	940	644	296	AS PER SYSTEM CONDITION
		46	77	940	644	296	AS PER SYSTEM CONDITION
		83	96	940	644	296	AS PER SYSTEM CONDITION
9	IEPL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
10	DHARIWAL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
11	KORADI U-6&U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
12	VIPL U1 &2	1	20	191	X	X	D.C. TECH MIN UNIT-2 SHUT DOWN
		55	75	191	X	X	D.C. TECH MIN UNIT-2 SHUT DOWN
		96	96	191	X	X	D.C. TECH MIN UNIT-2 SHUT DOWN
13	KORADI U-8 ,9,10	1	20	572	X	X	D.C. BELOW TECH MIN UNIT-10 SHUT DOWN
		69	75	558	X	X	D.C. BELOW TECH MIN UNIT-10 SHUT DOWN
		96	96	714	X	X	D.C. BELOW TECH MIN UNIT-10 SHUT DOWN
14	PARAS U-3 AND U-4	11	20	440	332	108	AS PER SYSTEM CONDITION
		55	62	421	332	89	AS PER SYSTEM CONDITION
		69	75	345	332	13	AS PER SYSTEM CONDITION
15	ADANI (TIRODA 440MW PPA) U1,4,8,5	12	19	52	0	52	AS PER SYSTEM CONDITION
		70	75	52	0	52	AS PER SYSTEM CONDITION
16	KHAPERKhedha U-1 TO U-4	13	19	423	X	X	D.C. TECH MIN UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		70	75	423	X	X	D.C. TECH MIN UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
17	KHAPERKhedha U-5	X	X	X	X	X	UNIT SHUT DOWN
18	ADANI U-1(1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
19	ADANI U-4(1200+125)MW PP	13	19	498	432	66	AS PER SYSTEM CONDITION
		70	75	498	432	66	AS PER SYSTEM CONDITION
20	ADANI U-5(1200+125)MW PP	13	19	498	432	66	AS PER SYSTEM CONDITION
		70	75	498	432	66	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	13	19	1397	1134	263	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		71	75	1397	1134	263	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
22	PARALI U-8	71	75	229	166	63	AS PER SYSTEM CONDITION
23	JSW U-1	71	75	283	200	83	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	X	X	X	X	X	NO BACK DOWN
25	ADANI U-2	X	X	X	X	X	NO BACK DOWN
26	ADANI U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT.12TH JULY 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.