

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							5-Nov-15
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TATA U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	9	24	364	283	81	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN
		71	96	364	283	81	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN
3	PARLI -3,4,5	X	X	X	X	X	UNIT SHUT DOWN
4	CHANDRAPUR	9	24	1643	1271	372	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN AND UNIT-3 SHUT DOWN
		71	96	1643	1271	372	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN AND UNIT-3 SHUT DOWN
5	PARLEY U-6 &U-7	X	X	X	X	X	UNIT SHUT DOWN
6	VIPL U1&U-2	9	24	273	191	82	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN
		71	96	273	191	82	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN
7	KORADI	X	X	X	X	X	UNIT 5,6,7 SHUT DOWN
8	REL DAHANU U1AND U2	10	24	470	336	134	AS PER SYSTEM CONDITION
		71	82	X	X	X	#
		83	91	470	336	134	AS PER SYSTEM CONDITION
9	KHAPERKHEDA U-5	71	91	475	335	140	AS PER SYSTEM CONDITION
10	BHUSWAL U4 &, U5	71	91	940	644	296	AS PER SYSTEM CONDITION
11	RATAN INDIA U-1,U-2 ,U-3 ,4,5	71	73	980	688	292	AS PER SYSTEM CONDITION UNIT-5 SHUT DOWN
		89	91	980	850	130	AS PER SYSTEM CONDITION UNIT-5 SHUT DOWN

**Note :**

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 13-OCT-2015.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.