

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

5-Dec-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	5	24	516	425	91	AS PER MOD
		70	84				DUE TO SYSTEM CONDITION
		85	96	344	284	60	
3	PARALI 3,4,5	7	23	151	138	13	AS PER MOD
		70	96				DUE TO SYSTEM CONDITION
4	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	SCH.GIVEN FROM BLK(41-76)
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	5	13	473	292	181	DUE TO SYSTEM CONDITION
		14	25				AS PER MOD
		81	96				DUE TO SYSTEM CONDITION
7	TPC U-8	11	21	235	172	63	AS PER MOD
		86	96				DUE TO SYSTEM CONDITION
8	PARALI-6	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL G	86	96	476	336	140	DUE TO SYSTEM CONDITION
11	BHUSAWAL-4	X	X	X	X	X	UNIT SHUT DOWN
12	KHAPERKHEDA-U5	96	96	360	335	25	DUE TO SYSTEM CONDITION
13	KORADI 5,6,7	96	96	414	407	7	DUE TO SYSTEM CONDITION
14	INDIABULL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
15	CHANDRAPUR	96	96	1364	1198	166	DUE TO SYSTEM CONDITION
16	KHAPER KHEDA U 1 TO 4	96	96	459	427	32	DUE TO SYSTEM CONDITION

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Nov.-2013.