

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	23	204	187	17	AS PER SYSTEM CONDITION
		53	96	204	187	17	AS PER SYSTEM CONDITION
2	SWPL U-1,2,4 TO MSEDCL	X	X	X	X	X	UNIT IS RUNNING BELOW TECH MIN
3	TPC U-6	1	23	473	292	181	AS PER SYSTEM CONDITION
		67	96	473	292	181	AS PER SYSTEM CONDITION
4	VIPL U1 &2	1	22	X	X	X	D.C/ BELOW TECH MIN
		67	96	X	X	X	D.C BELOW TECH MIN
5	DTPS (AEML) U-1 AND U-2	1	22	455	336	119	AS PER SYSTEM CONDITION
		70	96	455	336	119	AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	22	354	283	71	AS PER SYSTEM CONDITION
		71	96	339	284	55	AS PER SYSTEM CONDITION
7	BHUSWAL U-3	X	X	X	X	X	UNIT-3 ZERO SCHEDULE GIVEN BY MSEDCL
8	RATTANINDIA U-1 TO 5 (1200MW PPA)	1	22	490	344	146	unit- 4 and ult-5 shut down , unit-1 zero schedule given by msedcl AS PER SYSTEM CONDITION
		74	96	490	344	146	unit- 4 and ult-5 shut down AS PER SYSTEM CONDITION
9	PARALI U-6 AND U-7	1	21	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
		74	96	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
10	PARALI U-8	1	21	229	166	63	AS PER SYSTEM CONDITION
		74	96	229	166	63	AS PER SYSTEM CONDITION
11	BHUSWAL U-4 AND U-5	1	21	940	644	296	AS PER SYSTEM CONDITION
		74	96	940	644	296	AS PER SYSTEM CONDITION
12	KORADI U-6 AND U-7	X	X	X	X	X	UNIT-6 unit-7 shut down
13	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
14	DHARIWAL TO MSEDCL	1	21	X	X	X	UNIT IS RUNNING ON TECH. MIN
		81	96	X	X	X	UNIT IS RUNNING ON TECH. MIN
15	KHAPERKHEDA U-1 TO U-4	1	21			0	UNIT -1 SHUT DOWN AS PER SYSTEM CONDITION
		82	96			0	UNIT -1 SHUT DOWN AS PER SYSTEM CONDITION
16	JSW U-1	1	21	275	200	75	AS PER SYSTEM CONDITION
		82	96	275	200	75	AS PER SYSTEM CONDITION
17	KORADI U-6, U-9, U-10	1	21	X	X	X	D.C BELOW TECH MIN UNIT-9 SHUT DOWN
		82	96	X	X	X	D.C BELOW TECH MIN UNIT-9 SHUT DOWN
18	KHAPERKHEDA U-5	1	21	475	335	140	RUNNING BELOW TECH MIN
		82	96	428	335	93	AS PER SYSTEM CONDITION
19	PARAS U-3 AND U-4	1	21	230	168	62	UNIT-3 SHUT DOWNAS PER SYSTEM CONDITION
		84	96	230	168	62	UNIT-3 SHUT DOWNAS PER SYSTEM CONDITION
20	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	21	440	0	440	AS PER SYSTEM CONDITION
		84	96	400	0	400	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	1	16	1579	1282	297	AS PER SYSTEM CONDITION
		93	96	1579	1282	297	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	16	466	432	34	AS PER SYSTEM CONDITION
		93	96	466	432	34	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	16	466	432	34	AS PER SYSTEM CONDITION
		93	96	466	432	34	AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	16	466	432	34	AS PER SYSTEM CONDITION
		93	96	466	432	34	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-8 AND U-9	1	16	846	656	190	AS PER SYSTEM CONDITION
		95	96	846	656	190	AS PER SYSTEM CONDITION
26	ADANI U-2	X	X	X	X	X	NO BACK DOWN
27	ADANI U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM D' 12TH NOV-2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.