

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	39	364	283	81	AS PER MOD
		74	74	364	301	63	
3	TPC U-5	1	33	473	292	181	AS PER MOD
4	TPC U-8	1	25	235	172	63	AS PER MOD
5	BHUSAWAL 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
7	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	K'KHEDA U-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	REL G	1	32	479	336	143	AS PER MOD
10	CHANDRAPUR	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	INDIABULL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
12	PARALI-6	1	20	230	166	64	AS PER MOD
13	PARALI-7	1	20	230	166	64	AS PER MOD
14	K'KHEDA U-1,2,3,4	1	20	418	416	2	AS PER MOD
15	JSW U-1	1	20	275	200	75	DUE TO SYSTEM CONDITION
16	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	ABHIJIT TO RINFRA	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
18	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
19	VIPL TO RINFRA	X	X	X	X	X	NO SCHEDULE
20	APML (U 2) TO MSEDCL	1	20	617	432	185	DUE TO SYSTEM CONDITION
21	APML (U 3) TO MSEDCL	1	20	617	432	185	DUE TO SYSTEM CONDITION

Note :

1. Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement.

2. MOD rates revised w.e.f 12-July-2013.