

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							6-Oct-15
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TATA U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	1	9	384	283	101	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		27	73	384	283	101	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		91	96	384	283	101	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
3	PARLI -3,4,5	x	x	x	x	x	UNIT SHUT DOWN
4	JSW TO RINFRA DA	X	X	X	X	X	VARIABLE SCHEDULE
5	VIPL UNIT-2 ,&U1	43	73	546	382	164	AS PER SYSTEM CONDITION
		91	96	546	382	164	AS PER SYSTEM CONDITION
6	CHANDRAPUR	43	73	1772	1419	353	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN
		91	96	1772	1419	353	AS PER SYSTEM CONDITION UNIT-1 SHUT DOWN
7	PARLI -6,7	X	X	X	X	X	UNIT SHUT DOWN
8	KORADI	43	73	315	308	7	AS PER SYSTEM CONDITION
		91	96	315	308	7	AS PER SYSTEM CONDITION
9	KHAPERKHEDA U-5	43	73	380	335	45	AS PER SYSTEM CONDITION
10	REL DAHANU U1AND U2	1	96	x	x	x	#
11	RATAN INDIA U1,2,3,4,5	43	46	980	688	292	AS PER SYSTEM CONDITION
		47	50	980	834	146	AS PER SYSTEM CONDITION UNIT- 5 SHUT DOWN
		51	67	980	688	292	AS PER SYSTEM CONDITION UNIT- 5 SHUT DOWN
12	BHUSWAL U4 &, U5	43	67	752	644	108	AS PER SYSTEM CONDITION UNIT- 5 SHUT DOWN
13	TATA U-5	1	96	x	x	x	#
14	TPC U-8	1	96	x	x	x	#
15	JSW TO TPC DA	X	X	X	X	X	LESS SCHEDULE
16	BHUSWAL U2&, U3	53	67	161	144	17	AS PER SYSTEM CONDITION
17	KHAPERKHEDA U-1 to U-4	53	67	x	x	x	D.C. TECH MIN UNIT-4 SHUT DOWN
18	PARAS U-3 &U-4	53	67	363	332	31	AS PER SYSTEM CONDITION
19	ADANI U-5	53	67	520	432	88	AS PER SYSTEM CONDITION

**Note :**

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-SEPT-2015.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.