

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	28	516	425	91	AS Per MOD
		65	96				
3	PARALI 3,4,5	1	26	297	276	21	AS Per MOD
		66	96				
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	1	26	473	292	181	AS Per MOD
		65	76				
		82	96				
6	JSW U 2,4 TO BEST(100 MW)	69	72	100	70	30	AS Per MOD
7	TPC U-8	1	23	235	172	63	AS Per MOD
		69	72				
		83	96				
8	PARALI-6	X	X	X	X	X	UNIT UNDER OUTAGE
9	PARALI-7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	CHANDRAPUR	1	21	1237	1074	163	AS Per MOD
		70	72	1106	1073	33	
		83	96	1171	1113	58	
11	REL G	1	20	475	336	139	AS Per MOD
		83	96				
12	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	BHUSAWAL-4	X	X	X	X	X	UNIT UNDER OUTAGE
14	KHAPERKHEDE-U 1 TO 4	83	96	938	910	28	DUE TO SYSTEM CONDITION
15	INDIABULL TO MSEDCL	1	20	245	172	73	DUE TO SYSTEM CONDITION
		83	96				
16	PARAS-3	1	4	230	164	66	DUE TO SYSTEM CONDITION
		84	96				
17	JSW U 1	1	4	275	200	75	DUE TO SYSTEM CONDITION
		84	96				
18	PARAS-4	84	96	230	168	62	DUE TO SYSTEM CONDITION
19	APML U 1 TO MSEDCL	1	20	617	500	117	TO CONTROL LOADING ON 400 KV PARLY-LONIKAND
		89	96	617	432	185	DUE TO SYSTEM CONDITION

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Oct.-2013.