

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:06/11/2018

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	Dhariwal to BEST	7	19	X	X	X	No Schedule
		46	74	50	35	15	As per System Condition
		78	92	50	35	15	As per System Condition
		93	96	X	X	X	No Schedule
2	SWPL TO MSEDCL(GMR)	7	19	68	51	17	As per System Condition
		47	74	68	51	17	As per System Condition
		78	96	68	51	17	As per System Condition
3	JSW U-2,3&4 TO MSEDCL (155.5MW)	7	19	155.5	108	47.5	As per System Condition
		46	74	155.5	108	47.5	As per System Condition
		78	96	155.5	108	47.5	As per System Condition
4	JSW U-2,3&4 TO MSEDCL (247MW)	47	67	247	173	74	As per System Condition
		83	96	247	173	74	As per System Condition
5	SWPL TO MSEDCL (MPL) DA	48	68	83	63	20	As per System Condition
		83	96	83	63	20	As per System Condition
6	SWPL TO MSEDCL (MPL) DA	47	67	68	51	17	As per System Condition
		83	96	68	51	17	As per System Condition
7	TPC U-8	47	67	204	187	17	As per System Condition
		83	96	204	187	17	As per System Condition
8	DTPS REL U-1 & 2	47	67	456	336	120	As per System Condition
		83	96	456	336	120	As per System Condition
9	TPC U-5	61	67	473	282	181	As per System Condition
		83	96	473	282	181	As per System Condition
10	VIPL U-1 & 2	X	X	X	X	X	DC Less than Tech Min
11	NASIK U-3,4 & 5	61	67	285	283	2	As per System Condition, U-5 Shut down
		83	96	285	283	2	As per System Condition, U-5 Shut down
12	PARALI U-6 & 7	X	X	X	X	X	DC Less than Tech Min, U-7Shut Down
13	BHUSAWAL U-3	X	X	X	X	X	Unit Shut Down, Coal Swapping IEPL
14	PARALI U-8	X	X	X	X	X	DC Less than Tech Min
15	RATTANINDIA U-1 TO 5 (PPA-1200 MW)	61	66	245	172	73	As per System Condition, U-1,U-3, U-4, U-5 Shut Down
		93	96	245	172	73	As per System Condition, U-1,U-3, U-4, U-5 Shut Down
16	BHUSAWAL U-4 & 5	61	54	710	644	66	As per System Condition
		55	66	X	X	X	DC Less than Tech Min
		93	96	X	X	X	DC Less than Tech Min
17	KHAPERKHEDA U-1 TO 4	61	66	460	426	34	As per System Condition, U-1 Shut Down
		93	96	482	426	56	As per System Condition, U-1 Shut Down
18	KORADI U-6 & 7	X	X	X	X	X	U-6 & U-7Shut Down
19	IDEAL ENERGY PROJECTS LTD. TO MSEDCL	X	X	X	X	X	Unit Shut Down
20	DHARIWAL TO MSEDCL (Case-4)	61	66	X	X	X	DC Less than Tech Min
		94	96	140	129.5	10.5	As per System Condition
21	KORADI U-8 ,9 & 10	X	X	X	X	X	DC Less than Tech Min
22	PARAS U-3 & 4	61	66	230	168	62	As per System Condition, U-3 Shut Down
		95	96	230	168	62	As per System Condition, U-3 Shut Down
23	KHAPERKHEDA U-5	61	66	X	X	X	Unit Shut Down(BTL)
		95	96	X	X	X	DC Less than Tech Min
24	JSW-Ratnagiri U-1	95	96	271	200	71	As per System Condition
25	ADANI (TIRODA 440 MW PPA) U 1,4 & 5	X	X	X	X	X	NO BACK DOWN
26	ADANI, TIRODA U-1, 4 & 5 (PPA-1200 MW and 125 MW)	X	X	X	X	X	NO BACK DOWN
27	CHANDRAPUR U-3 TO 7	X	X	X	X	X	NO BACK DOWN
28	CHANDRAPUR U-8 & 9	X	X	X	X	X	NO BACK DOWN
29	ADANI (TIRODA 1320 MW) U 2 & 3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH SEPT-2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.