

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Targat Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	32	516	425	91	AS Per MOD
		74	96				
3	PARALI 3,4,5	1	28	297	276	21	AS Per MOD
		74	96				
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	1	27	473	292	181	AS Per MOD
		81	96				
6	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	X
7	TPC U-8	1	2	235	195	40	AS Per MOD, Blik 3to 20 Backdown W/dn to control 220 kV Kalwa-Salsett L/L
		83	96	235	172	63	AS Per MOD
8	PARALI-6	X	X	X	X	X	UNIT UNDER OUTAGE
9	PARALI-7	X	X	X	X	X	UNIT UNDER OUTAGE
10	CHANDRAPUR	1	20	1131	1059	72	AS Per MOD
		83	96	1292	1183	109	DUE TO SYSTEM CONDITION
11	REL G	1	20	475	336	139	AS Per MOD
		83	96				DUE TO SYSTEM CONDITION
12	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	KHAPERKHEDA-U 1 TO 4	1	19	631	572	59	DUE TO SYSTEM CONDITION
15	INDIABULL TO MSEDCL	1	19	245	172	73	DUE TO SYSTEM CONDITION
16	PARAS-3	4	4	210	187	23	AS Per MOD
17	JSW U 1	1	6	275	200	75	DUE TO SYSTEM CONDITION
18	PARAS-4	X	X	X	X	X	X
19	APML U 1 TO MSEDCL	1	54	617	432	185	TO CONTROL LINE LOADING
		55	68	617	540	77	
		81	96	617	540	77	
20	APML U2 TO MSEDCL	14	36	617	580	37	TO CONTROL LINE LOADING
		37	50	617	540	77	
21	APML U3 TO MSEDCL	14	36	617	580	37	TO CONTROL LINE LOADING
		37	50	617	540	77	

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Oct.-2013.