

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|----------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|---|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT WITHDRAWN ON ECONOMIC SHUTDOWN |
| 2 | JSW TO MSEB FIRM | 1 | 25 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| | | 31 | 40 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| 3 | PARALI U-6 AND U-7 | X | X | X | X | X | UNIT-6 AND UNIT-7 SHUT DOWN |
| 4 | TPC U-5 | 1 | 22 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 31 | 40 | 473 | 305 | 168 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 5 | DTPS REL U1 AND U2 | 1 | 22 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| | | 31 | 40 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| 6 | TATA U-8 | 1 | 22 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| | | 31 | 40 | 235 | 205 | 30 | AS PER SYSTEM CONDITION |
| | | 76 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 7 | NASHIK U-3,4,5 | 1 | 22 | 314 | 283 | 31 | B/D AS PER SYSTEM CONDITION UNIT-3 W/DN |
| | | 76 | 96 | 314 | 283 | 31 | B/D AS PER SYSTEM CONDITION UNIT-3 W/DN |
| 8 | BHUSWAL U-2 AND U-3 | X | X | X | X | X | UNIT-2 AND UNIT-3 SHUT DOWN |
| 9 | RATTANINDIA U1 TO U-5 | 1 | 21 | 735 | 516 | 219 | UNIT-3,5 SHUT DOWN , B/DAS PER SYSTEM CONDITION |
| | | 76 | 96 | 735 | 516 | 219 | UNIT-3,5 SHUT DOWN , B/DAS PER SYSTEM CONDITION |
| 10 | PARLEY U-8 | 1 | 21 | X | X | X | D.C. BELOW TECH MIN |
| | | 76 | 96 | X | X | X | D.C. BELOW TECH MIN |
| 11 | BHUSWAL U-4 AND U-5 | 1 | 21 | 676 | 644 | 32 | AS PER SYSTEM CONDITION |
| | | 77 | 96 | 676 | 644 | 32 | AS PER SYSTEM CONDITION |
| 12 | KHAPERKHEDA U-1 TO U-4 | 1 | 21 | X | X | X | D.C. BELOW TECH MIN UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION |
| | | 77 | 96 | X | X | X | D.C. BELOW TECH MIN UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION |
| 13 | VIPL U-1 AND U-2 | 12 | 20 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |
| | | 77 | 96 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |
| 14 | ADANI TIRODA 440 PPA | 12 | 20 | 440 | 240 | 200 | AS PER SYSTEM CONDITION |
| | | 77 | 96 | 440 | 0 | 440 | AS PER SYSTEM CONDITION |
| 15 | ADANI U- 1 (1200+125)MW PP | 77 | 96 | 466 | 432 | 34 | AS PER SYSTEM CONDITION |
| 16 | ADANI U-4 (1200+125)MW PP | 77 | 96 | 466 | 432 | 34 | AS PER SYSTEM CONDITION |
| 17 | ADANI U-5 (1200+125)MW PP | 77 | 96 | 466 | 432 | 34 | AS PER SYSTEM CONDITION |
| 18 | KHAPERKHEDA U-5 | 77 | 96 | 376 | 335 | 41 | AS PER SYSTEM CONDITION |
| 19 | CHANDRAPUR U-3 TO U-7 | X | X | X | X | X | NO BACK DOWN UNIT-3, UNIT-4 UNIT-5 SHUT DOWNAS PER SYSTEM CONDITION |
| 20 | KORADI U-5,6,7 | X | X | X | X | X | UNIT-5,6,7 SHUT DOWN |
| 21 | PARAS U-3 AND U-4 | X | X | X | X | X | NO BACK DOWN |
| 22 | CHANDRAPUR U-8 AND U-9 | X | X | X | X | X | NO BACK DOWN |
| 23 | KORADI U-8,9,10 | X | X | X | X | X | NO BACK DOWN |
| 24 | JSW U-1 | X | X | X | X | X | NO BACK DOWN |
| 25 | ADANI U-3 | X | X | X | X | X | NO BACK DOWN |
| 26 | ADANI U-2 | X | X | X | X | X | NO BACK DOWN |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH OCT. 2017

3 # Indicates that back down withdrawn due to Line loading/system constraints.