

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	28	516	425	91	AS PER MOD
		70	74				
		80	96				
3	PARALI 3,4,5	1	28	302	276	26	AS PER MOD
		80	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	JSW U 3,4 TO RINFRA DA (JSWPTC) VARIABLE SCH.GIVEN FROM BLK(32-84)	71	72	78	55	23	AS PER MOD
		81	82	98	69	29	
6	PARALI-7	1	28	180	166	14	AS PER MOD
		81	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
7	PARALI-6	1	28	180	166	14	AS PER MOD
		81	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-4	1	28	381	322	59	AS PER MOD
		71	71	381	355	26	
		81	96	381	322	59	
9	TPC U-5	1	26	473	292	181	AS PER MOD
		80	96	473	335	138	DUE TO SYSTEM CONDITION
10	TPC U-8	1	26	235	172	63	AS PER MOD
		84	86	235	200	35	DUE TO SYSTEM CONDITION
11	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	REL G	1	14	238	167	71	AS PER MOD
		84	96				
13	KHAPER KHEDA U 1 TO 4	1	15	508	429	79	AS PER MOD
		85	96	490	427	63	DUE TO SYSTEM CONDITION
14	KHAPERKHEDA-U5	1	15	451	335	116	AS PER MOD
		87	96	432	335	97	
15	CHANDRAPUR	1	14	1409	1206	203	AS PER MOD
		88	96				
16	INDIABULL TO MSECL	X	X	X	X	X	UNIT SHUT DOWN
17	PARAS -U3	1	13	201	164	37	AS PER MOD
		91	96				
18	PARAS U4	1	13	201	168	33	AS PER MOD
		91	96				
19	APML U-1	1	6	611	432	179	DUE TO SYSTEM CONDITION
20	JSW U-1	1	6	275	200	75	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2013.