

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW TO AEML	1	31	90	63	27	AS PER SYSTEM CONDITION
		36	96	90	63	27	AS PER SYSTEM CONDITION
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	NASHIK U-3, U-4 & U-5	1	31	187	142	45	AS PER SYSTEM CONDITION / U-3 UNDER
		36	96	187	142	45	ZERO SCHEDULE & U-5 UNDER CASE-IV
5	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
6	JSW TO AEML	1	31	130.98	91.69	39.29	AS PER SYSTEM CONDITION
		36	96	130.98	91.69	39.29	AS PER SYSTEM CONDITION
7	DTPS U-1 & U-2	1	31	456	336	120	AS PER SYSTEM CONDITION
		36	96	456	336	120	AS PER SYSTEM CONDITION
8	TPC U-5	1	30	473	292	181	AS PER SYSTEM CONDITION
		36	59	473	292	181	AS PER SYSTEM CONDITION
		67	96	473	292	181	AS PER SYSTEM CONDITION
9	TPC U-8	1	30	229	187	42	AS PER SYSTEM CONDITION
		36	59	229	187	42	AS PER SYSTEM CONDITION
		67	96	229	187	42	AS PER SYSTEM CONDITION
10	JSW TO AEML	1	30	150	105	45	AS PER SYSTEM CONDITION
		36	59	150	105	45	AS PER SYSTEM CONDITION
		67	96	150	105	45	AS PER SYSTEM CONDITION
11	BHUSAWAL U-4 & U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	DHARIWAL TO AEML	1	30	X	X	X	DC TECH MIN
		36	59	X	X	X	DC TECH MIN
		67	96	X	X	X	DC TECH MIN
13	RATTANINDIA U-1 TO U-5	1	25	735	516	219	AS PER SYSTEM CONDITION / U-1 & U-4 UNDER ZERO SCHEDULE
		36	39	735	516	219	
		47	56	735	516	219	
		67	96	735	516	219	
14	PARALI U-6 & U-7	1	24	458	332	126	AS PER SYSTEM CONDITION
		48	56	458	332	126	AS PER SYSTEM CONDITION
		68	96	458	332	126	AS PER SYSTEM CONDITION
15	PARALI U-8	1	23	229	166	63	AS PER SYSTEM CONDITION
		68	96	229	166	63	AS PER SYSTEM CONDITION
16	PARAS U-3 & U-4	1	23	458	332	126	AS PER SYSTEM CONDITION
		69	96	458	332	126	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA440 MW)	1	22	440	0	440	AS PER SYSTEM CONDITION
		69	73	440	0	440	AS PER SYSTEM CONDITION
		78	96	440	0	440	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-1 TO U-4	1	22	711	572	139	AS PER SYSTEM CONDITION
		69	73	711	572	139	AS PER SYSTEM CONDITION
		78	96	711	572	139	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-3 TO U-7	1	22	1032	802	230	AS PER SYSTEM CONDITION/ U-3&5 OUT
		69	73	1032	802	230	AS PER SYSTEM CONDITION/ U-3&5 OUT
		78	96	1032	802	230	AS PER SYSTEM CONDITION/ U-3&5 OUT
20	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	22	1399	1296	103	AS PER SYSTEM CONDITION
		69	73	1399	1296	103	AS PER SYSTEM CONDITION
		78	96	1399	1296	103	AS PER SYSTEM CONDITION
21	KHAPERKHEDA U-5	1	22	465	335	130	AS PER SYSTEM CONDITION
		79	96	465	335	130	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	1	22	1350	1259	91	AS PER SYSTEM CONDITION
		79	96	1350	1259	91	AS PER SYSTEM CONDITION
23	DHARIWAL TO MSEDCL(CASE IV)	1	21	185	129.5	56	AS PER SYSTEM CONDITION
		79	96	185	129.5	56	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 & U-9	1	21	931	656	275	AS PER SYSTEM CONDITION
		80	96	931	656	275	AS PER SYSTEM CONDITION
25	JSW U-1	6	18	290	200	90	AS PER SYSTEM CONDITION
		80	96	290	200	90	AS PER SYSTEM CONDITION
26	APML U-2 & U-3	7	16	1246	864	382	AS PER SYSTEM CONDITION
		81	96	1246	864	382	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 Revised MOD Rates effective from 00:00 HRS of 1st Feb 2020