

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS Per MOD
2	JSW U-4 (STOA)	x	x	x	x	x	1) MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs to 190 MW (TECHNICAL MINIMUM) 2) FROM 05:00 to 24:00 hrs POWER IS CURTAILED BY MSEDCL
3	ABHIJIT TO MSEDCL(STOA)	x	x	x	x	x	1) MSEDCL HAS CURTAILED POWER FROM 52 TO 35MW ( 00:00 TO 05:00 HRS) 2) FROM 05:00 to 24:00 hrs POWER IS CURTAILED BY MSEDCL
4	WPCL TO MSEDCL (STOA)	x	x	x	x	x	1) MSEDCL HAS CURTAILED POWER FROM 06:00 to 22:00 hrs(30MW)
5	JSW U-3 TO MSEDCL (STOA)	x	x	x	x	x	1) MSEDCL HAS CURTAILED POWER FROM 06:00 to 22:00 hrs(0MW)
6	TPC U-5	2	75	473	260	213	AS Per MOD
		85	96	473	260	213	
7	TPC U-8	3	43	235	160	75	AS Per MOD
		57	74	235	160	75	
		85	96	235	160	75	
8	JSW U-2 (MTOA)	3	21	275	192.5	82.5	AS Per MOD
		22	43	275	201	74	
		57	74	275	192.5	82.5	
		91	96	275	192.5	82.5	
9	REL_G	9	18	480	336	144	AS Per MOD
		66	74	480	336	144	
		84	96	480	336	144	
10	NASIK	9	18	566	465	101	#
		66	73	566	465	101	AS Per MOD
		83	96	566	465	101	BACKED DOWN AS PER SYSTEM CONDITION
11	BHUSAWAL	10	18	313	307	6	#
		66	73	313	307	6	AS Per MOD
		83	96	313	307	6	BACKED DOWN AS PER SYSTEM CONDITION
12	PARLI 4	10	18	164	155	9	#
		66	73	164	155	9	AS Per MOD
		83	96	164	155	9	BACKED DOWN AS PER SYSTEM CONDITION
13	PARLI 5	x	x	x	x	x	DECLARED CAPACITY(144MW) IS LESS THAN TECHNICAL MINIMUM(155MW)
14	KHAPARKHEDA	10	18	768	620	148	#
		66	73	768	710	58	AS Per MOD
		83	96	768	710	58	BACKED DOWN AS PER SYSTEM CONDITION
15	PARLI_ 6	x	x	x	x	x	DECLARED CAPACITY(160MW) IS LESS THAN TECHNICAL MINIMUM(164MW)
16	PARLI_ 7	x	x	x	x	x	DECLARED CAPACITY(110MW) IS LESS THAN TECHNICAL MINIMUM(164MW)
17	KORADI	x	x	x	x	x	DECLARED CAPACITY OF ALL UNITS WAS LESS THAN TECHNICAL MINIMUM 155MW
18	CHANDRAPUR	15	18	1891	1865	26	#

# SCHEDULE WAS REDUCED AS PER MOD. BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 From 19-1-2012, JSW Unit-3 is having CPP transaction with JSW ISPAT for 220 MW RTC, and from 06:00hrs-22:00hrs 50MW to MSEDCL; No open access ( from 00:00hrs-06:00hrs & from 22:00hrs-24:00hrs)
- 3 From 01-03-2012, WPCL-MSEDCL 50 MW from (06:00hrs to 22:00hrs); No open access ( from 00:00hrs-06:00hrs & from 22:00hrs-24:00hrs)
- 4 Short Term Open Access Contracts of M/s Abhijit are based on station capacity and accordingly Schedule issued to Abhijit is on Station wise basis.
- 5 MOD rates revised w.e.f 14-Feb-2012.