

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							8-Apr-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) / (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASHIK	1	24	364	283	81	UNIT-4 CONVERTED TO ZERO SCHEDULE 00:00HRS OF 26/03/2017 BY MSEDCL, B/D AS PER SYSTEM CONDITION
		33	60	364	283	81	UNIT-4 CONVERTED TO ZERO SCHEDULE 00:00HRS OF 26/03/2017 BY MSEDCL, B/D AS PER SYSTEM CONDITION
		63	96	364	283	81	UNIT-4 CONVERTED TO ZERO SCHEDULE 00:00HRS OF 26/03/2017 BY MSEDCL, B/D AS PER SYSTEM CONDITION
3	TPC U-8	1	22	235	187	48	AS PER SYSTEM CONDITION
		33	43	235	187	48	AS PER SYSTEM CONDITION
		67	96	235	187	48	AS PER SYSTEM CONDITION
4	TPC U-5	1	22	473	292	181	AS PER SYSTEM CONDITION
		33	43	473	292	181	AS PER SYSTEM CONDITION
		67	89	473	292	181	AS PER SYSTEM CONDITION
5	DTPS REL U-1AND U-2	10	21	464	336	128	AS PER SYSTEM CONDITION
		35	41	464	336	128	AS PER SYSTEM CONDITION
		67	76	464	336	128	AS PER SYSTEM CONDITION
6	RATTANINDIA U1,2,3,4,5	37	41	1200	860	340	AS PER SYSTEM CONDITION
		67	76	1200	860	340	AS PER SYSTEM CONDITION
7	BHUSWAL U- 2,3	68	76	161	143	18	UNIT-2 SHUT DOWN D.C IS ZERO , B/D AS PER SYSTEM CONDITION
8	KORADI U-5 TO U-7	68	76	X	X	X	UNIT-7 RUNNING BELOW TECH MIN., UNIT-6 SHUT DOWN, UNIT-5 SHUT DOWN
9	KHAPERKHEDA U1 TO U4	68	76	706	572	134	AS PER SYSTEM CONDITION
10	BHUSWAL U-4AND U-5	68	70	658	644	14	AS PER SYSTEM CONDITION
11	PARLYU-6 AND U-7	X	X	X	X	X	NO BACK DOWN
12	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
13	PARLY U-8	X	X	X	X	X	UNIT SHUTDOWN
14	PARAS U3 AND U-4	X	X	X	X	X	NO BACK DOWN
15	VIPL U1 AND U2	X	X	X	X	X	NO BACK DOWN
16	KORADI U8 ,U9,10	X	X	X	X	X	NO BACK DOWN , KORADI UNIT-8 TRIPPED AT 10:45HRS AND SYN. 14:22 UNIT-10 SHUT DOWN .
17	ADANI 440 PPA	X	X	X	X	X	NO BACK DOWN
18	ADANI U-1(1200MW &125MW PPA)	X	X	X	X	X	NO BACK DOWN UNIT-1 SHUT DOWN
19	ADANI U-4(1200MW &125MW PPA)	X	X	X	X	X	NO BACK DOWN
20	ADANI U-5(1200MW &125MW PPA)	X	X	X	X	X	NO BACK DOWN
21	CHANDRAPUR U3 TO U7	X	X	X	X	X	NO BACK DOWN UNIT-7SHUT DOWN
22	CHANDRAPUR U8 AND U9	X	X	X	X	X	NO BACK DOWN
23	ADANI UNIT-2	X	X	X	X	X	NO BACK DOWN
24	ADANI U-3	X	X	X	X	X	SHUT DOWN
25	JSW U-1	X	X	X	X	X	NO BACK DOWN

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Dispatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES EFFECTIVE FROM 12TH MARCH 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.