

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASHIK U-3, U-4 & U-5	X	X	X	X	X	U-3&4 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	4	18	455	336	119	AS PER SYSTEM CONDITION
		44	83	455	336	119	AS PER SYSTEM CONDITION
5	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
6	TPC U-5	5	18	470	292	178	AS PER SYSTEM CONDITION
		44	83	470	292	178	AS PER SYSTEM CONDITION
7	TPC U-8	5	18	229	172	57	AS PER SYSTEM CONDITION
		44	83	229	172	57	AS PER SYSTEM CONDITION
8	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
9	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	BHUSAWAL U-4 & U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
11	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
12	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
13	CHANDRAPUR U-3 TO U-7	44	78	174	148	26	AS PER SYSTEM CONDITION/ U-4,5,6&7 OUT
14	KHAPERKHEDA U-5	44	78	432	335	97	AS PER SYSTEM CONDITION
15	APML U-1,U-4 & U-5 (PPA440 MW)	44	67	440	34	406	AS PER SYSTEM CONDITION
		73	77	440	34	406	AS PER SYSTEM CONDITION
16	PARAS U-3 & U-4	52	67	454	332	122	AS PER SYSTEM CONDITION
		73	77	454	332	122	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-8 & U-9	X	X	X	X	X	UNITS SHUT DOWN
18	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	73	77	X	X	X	DC TECH MIN
19	KORADI U-8 TO U-10	74	77	X	X	X	DC TECH MIN
20	DHARIWAL TO MSEDCL(CASE IV)	74	77	185	129.5	55.5	AS PER SYSTEM CONDITION
21	JSW U-1	X	X	X	X	X	NO BACK DOWN
22	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 * Indicates that back down implemented due to Line loading/system constraints.
- 4 Revised MOD Rates effective from 00:00 hrs of 1st Apr 2020 (Changes in STOA transactions)