

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 8-May-15 |
|--|------------------------|--|----|---------------------------------------|-------------------------------------|--|---------------------------|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUT DOWN |
| 2 | BHUSAWAL U2-3 | X | X | X | X | X | SCHEDULED ZERO |
| 3 | NASHIK | 51 | 57 | 556 | 425 | 131 | DUE TO SYSTEM CONDITION |
| 4 | PARALI-3,4,5 | X | X | X | X | X | UNIT SHUT DOWN |
| 5 | JSW TO TPC DA | 51 | 57 | 125 | 87.5 | 37.5 | DUE TO SYSTEM CONDITION |
| | | 62 | 96 | 125 | 87.5 | 37.5 | DUE TO SYSTEM CONDITION |
| 6 | PARLY U-6 & 7 | 51 | 57 | 440 | 332 | 108 | DUE TO SYSTEM CONDITION |
| 7 | BHUSAWAL U-4 | 63 | 96 | 470 | 322 | 148 | DUE TO SYSTEM CONDITION |
| 8 | BHUSAWAL U-5 | 63 | 96 | 470 | 322 | 148 | DUE TO SYSTEM CONDITION |
| 9 | VIPL U-1 | 62 | 77 | 273 | 191 | 82 | DUE TO SYSTEM CONDITION |
| 10 | VIPLU-2 | 62 | 77 | 273 | 191 | 82 | DUE TO SYSTEM CONDITION |
| 11 | WPCL TO MSDCL (DA) | 62 | 77 | 280 | 210 | 70 | DUE TO SYSTEM CONDITION |
| 12 | REL DAHANU U1,U2 | X | X | X | X | X | # |
| 13 | TPC U-5 | X | X | X | X | X | # |
| 14 | CHANDRAPUR | 68 | 76 | 1315 | 1087 | 228 | DUE TO SYSTEM CONDITION |
| 15 | TPC U-8 | X | X | X | X | X | # |
| 16 | JSW TO MSCL | 62 | 76 | 170 | 119 | 51 | DUE TO SYSTEM CONDITION |
| 17 | JSW TO RINFRA (DA) | X | X | X | X | X | VARIABLE QUANTUM SCHEDULE |
| 18 | KHAPERKHEDA U-5 | 68 | 76 | 475 | 335 | 140 | DUE TO SYSTEM CONDITION |
| 19 | KHAPERKHEDA U-1 TO 5 | 68 | 76 | 746 | 572 | 174 | DUE TO SYSTEM CONDITION |
| 20 | INDIA BULLU-2 | 63 | 76 | 245 | 172 | 73 | DUE TO SYSTEM CONDITION |
| 21 | PARAS U-4 | 68 | 76 | 230 | 168 | 62 | DUE TO SYSTEM CONDITION |
| 22 | PARAS U-3 | 68 | 76 | 230 | 164 | 66 | DUE TO SYSTEM CONDITION |
| 23 | ADANI U-4 | 62 | 75 | 615 | 450 | 165 | DUE TO SYSTEM CONDITION |
| 24 | ADANI U-5 | 62 | 75 | 615 | 470 | 145 | DUE TO SYSTEM CONDITION |
| 25 | ADANI U-1 | 62 | 75 | 615 | 470 | 145 | DUE TO SYSTEM CONDITION |
| 26 | JSW U-1 | X | X | X | X | X | DC BELOW TECH MIN |
| 27 | ADANI U-3 | 62 | 64 | 623 | 535 | 88 | DUE TO SYSTEM CONDITION |

Note : Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

1 MOD rates revised w.e.f 12-APRIL-2015.

2 # Back down withdrawn due to Line Loading/System Constraints.

3