

STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

8-Jul-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum (Max in MW /A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	36	483	145	338	AS PER MOD
		37	63				DUE TO SYSTEM CONDITION
		64	75				AS PER MOD
		76	83				DUE TO SYSTEM CONDITION
		84	96				AS PER MOD
2	NASK	1	30	354	283	71	AS PER MOD
		31	36				DUE TO SYSTEM CONDITION
		46	64				AS PER MOD
		65	75				DUE TO SYSTEM CONDITION
		76	96				AS PER MOD
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	TPC U-5	1	25	473	292	181	AS PER MOD
		26	40				DUE TO SYSTEM CONDITION
		52	96				AS PER MOD
5	TPC U-8	1	30	235	172	63	AS PER MOD
		31	37				DUE TO SYSTEM CONDITION
		57	69				AS PER MOD
		70	74				DUE TO SYSTEM CONDITION
		75	82				AS PER MOD
		88	96				DUE TO SYSTEM CONDITION
6	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
7	REL G	1	5	479	336	143	DUE TO SYSTEM CONDITION
		6	20				AS PER MOD
		21	37				DUE TO SYSTEM CONDITION
		52	80				AS PER MOD
		89	96				DUE TO SYSTEM CONDITION
8	BHUSAWAL 4	X	X	X	X	X	DC REVISED DUE TO PCO
9	KIKHEDA U-1,2,3,4	6	20	419	409	10	AS PER MOD
		21	34				DUE TO SYSTEM CONDITION
		48	75				AS PER MOD
		89	96				DUE TO SYSTEM CONDITION
10	INDIABULL TO MSEDCIL	6	20	245	171.5	73.5	AS PER MOD
		21	34				DUE TO SYSTEM CONDITION
		48	75				AS PER MOD
		89	96				DUE TO SYSTEM CONDITION
11	CHANDRAPUR	8	20	1148	1125	23	AS PER MOD
		21	65				DUE TO SYSTEM CONDITION
		66	96	X	X	X	DC REVISED DUE TO U-3 TRIPPED
12	KIKHEDA U-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	PARAS-3	8	20	200	164	36	AS PER MOD
		21	34				DUE TO SYSTEM CONDITION
		48	75				AS PER MOD
		89	96				DUE TO SYSTEM CONDITION
14	PARAS-4	8	20	200	168	32	AS PER MOD
		21	34				DUE TO SYSTEM CONDITION
		48	75				AS PER MOD
		89	96				DUE TO SYSTEM CONDITION

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Max) (B)		
15	JSW U-1	8	20	275	192.5	82.5	AS PER MOD
		21	34				DUE TO SYSTEM CONDITION
		48	75				
		89	96				
16	ABHBT TO RINFRA	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	VIPL TO RINFRA	X	X	X	X	X	NO SCHEDULE
18	APMIL (U-3) TO MSEDCL	8	15	617	463	154	AS PER MOD
		16	36	617	432	185	DUE TO SYSTEM CONDITION
		48	79				
		90	96				
19	APMIL (U-2) TO MSEDCL	18	35	617	497	120	DUE TO SYSTEM CONDITION
		48	79	617	432	185	
		96	96	617	572	45	
20	WPCL TO RINFRA	71	75	235	200	35	DUE TO SYSTEM CONDITION

**Note :**

<sup>1</sup> Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

<sup>2</sup> MOD rates revised w.e.f 12 June-2013.