

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							8-Jul-15
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min)		
1	TPC U-6	x	x	x	x	x	UNIT SHUTDOWN
2	NASHIK	1	96	x	x	x	#
3	PARLY -3,4,5	x	x	x	x	x	UNIT SHUTDOWN
4	JSW TO TPC	12	24	125	87.5	37.5	AS PER SYSTEM CONDITION
		69	77	125	87.5	37.5	AS PER SYSTEM CONDITION
5	TPC U-5	1	11	X	X	X	#
		12	23	473	390	83	AS PER SYSTEM CONDITION
		24	96	X	X	X	#
6	TPC U-8	1	96	X	X	X	#
7	BHUSWAL 2 3	71	77	161	144	17	AS PER SYSTEM CONDITION
8	BHUSWAL-5	71	77	470	322	148	AS PER SYSTEM CONDITION
9	BHUSAWAL U-4	x	x	x	x	x	UNIT SHUTDOWN
10	REL DAHANU U1 & 2	1	96	X	X	X	#
11	CHANDRAPUR	71	77	1265	1091	174	AS PER SYSTEM CONDITION
12	PARLY U-7	71	77	x	x	x	UNIT SHUTDOWN
13	PARLEY-6	71	77	x	x	x	UNIT SHUTDOWN
14	VIPL U2	71	77	273	191	82	AS PER SYSTEM CONDITION
15	VIPL U1	71	77	273	191	82	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-JUNE-2015.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.