

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	96	516	425	91	AS Per MOD
3	TPC U-8	1	38	235	172	63	AS Per MOD
		86	96				
4	TPC U-5	1	38	473	292	181	AS Per MOD
		86	96				
5	PARALI-6	1	24	170	166	4	AS Per MOD
		66	71				
		90	96				
6	PARALI 3,4,5	1	24	280	273	7	AS Per MOD
		66	71				
		90	96				
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	24	170	166	4	AS Per MOD
		66	71				
		91	96				
10	REL G	1	24	479	336	143	AS Per MOD
		65	71				
		90	96				
11	CHANDRAPUR	1	24	1223	1146	77	AS Per MOD
		49	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSEDCL	1	24	245	172	73	AS Per MOD
		25	25	245	210	35	DUE TO SYSTEM CONDITION
		67	68	245	200	45	AS Per MOD
14	KHAPERKHEDA-U 1 TO 4	3	24	479	431	48	AS Per MOD
15	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	APML U 1 TO MSEDCL	41	75	617	432	185	DUE TO LINE CONSTRAINT
		76	90	617	532	85	
18	KHAPERKHEDA-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
19	JSW U 1	5	20	X	X	X	#
20	AMNEPL TO REL	5	6	X	X	X	
		8	19				
21	APML U 2 TO MSEDCL	5	19	X	X	X	
		43	74	617	540	77	DUE TO LINE CONSTRAINT
22	APML U 3 TO MSEDCL	13	17	X	X	X	#
		43	74	617	540	77	DUE TO LINE CONSTRAINT

# SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".