

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 8.10.2017

SR. NO.	GENERATING STN. / STDA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TOMSEDCL	1	96	126	87.6	37.6	AS PER SYSTEM CONDITION
3	JSW TO RINFRA DA	1	96	X	X	X	VARIABLE SCHEDULE BLK NO 170 96, BID AS PER SYSTEM CONDITION
4	JSW TO MSEDOLEFIRM	1	96	X	X	X	170 96 SCHEDULE BELOW 96 MW.
5	DHARWAL TO MSEB	1	96	150	140	10	AS PER SYSTEM CONDITION
6	TPC U-8	1	96	235	187	48	AS PER SYSTEM CONDITION
7	NABIK U-3, U-4, U-5	1	96	304	283	21	UNIT-4 SHUT DOWN, BID AS PER SYSTEM CONDITION
8	DTPS REL U1 AND U2	1	96	229	169	60	UNIT-2 SHUT DOWN BID AS PER SYSTEM CONDITION
9	TPC U-6	1	96	X	X	X	D.C. BELOW TECH MIN
10	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
11	RATTANNIDIA U1 TO U-6	1	96	490	344	146	UNIT-2, UNIT-3, UNIT-5 SHUT DOWN AS PER SYSTEM CONDITION
12	PARLEY U-8	X	X	X	X	X	SHUT DOWN
13	KORADI U-5,6 AND U-7	X	X	X	X	X	UNIT-5, UNIT-6 SHUT DOWN, UNIT-7 SHUT DOWN
14	PARALI U-6 AND U-7	1	96	X	X	X	D.C. BELOW TECH MIN
15	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNIT-1,2,3, unit-4 syn. 16:19HRS D.C. BELOW TECH MIN
16	VPL U-1 AND U-2	1	18	477	382	95	AS PER SYSTEM CONDITION
		26	66	477	382	95	AS PER SYSTEM CONDITION
		67	96	572	382	190	AS PER SYSTEM CONDITION
17	BHUSWAL U-4 AND U-5	1	18	X	X	X	D.C. BELOW TECH MIN
		26	96	X	X	X	D.C. BELOW TECH MIN
18	KORADI U-9 AND 10	1	18	878	836	42	AS PER SYSTEM CONDITION
		26	96	909	864	45	AS PER SYSTEM CONDITION UNIT-9 SHUT DOWN
19	ADANI 443MW PPA	1	18	406	72	334	AS PER SYSTEM CONDITION
		26	50	406	72	334	AS PER SYSTEM CONDITION
		55	75	406	72	334	AS PER SYSTEM CONDITION
		84	96	406	72	334	AS PER SYSTEM CONDITION
20	KHAPERKHEDA U-6	1	18	339	336	4	AS PER SYSTEM CONDITION
		29	50	376	336	41	AS PER SYSTEM CONDITION
		55	75	442	336	107	AS PER SYSTEM CONDITION
		84	96	385	336	50	AS PER SYSTEM CONDITION
21	ADANI U-1 (1200+125)MW PP	1	18	405	X	X	D.C. BELOW TECH MIN
		29	50	405	X	X	D.C. BELOW TECH MIN
		55	75	405	X	X	D.C. BELOW TECH MIN
		84	96	405	X	X	D.C. BELOW TECH MIN
22	ADANI U-4 (1200+125)MW PP	1	18	420	X	X	D.C. BELOW TECH MIN
		29	50	420	X	X	D.C. BELOW TECH MIN
		55	75	420	X	X	D.C. BELOW TECH MIN
		84	96	420	X	X	D.C. BELOW TECH MIN
23	ADANI U-6 (1200+125)MW PP	1	18	398	X	X	D.C. BELOW TECH MIN
		29	50	398	X	X	D.C. BELOW TECH MIN
		55	75	398	X	X	D.C. BELOW TECH MIN
		84	96	398	X	X	D.C. BELOW TECH MIN
24	CHANDRAPUR U-3 TO U-7	1	18	934	806	128	AS PER SYSTEM CONDITION
		29	44	934	806	128	AS PER SYSTEM CONDITION
		55	70	934	806	128	AS PER SYSTEM CONDITION
		84	96	684	660	24	UNIT-3 SHUT DOWN, unit-4 tripped 22:57hrs AS PER SYSTEM CONDITION
25	PARAS U-3 AND U-4	1	18	X	X	X	D.C. BELOW TECH MIN
		29	44	X	X	X	D.C. BELOW TECH MIN
		55	70	X	X	X	D.C. BELOW TECH MIN
		84	96	X	X	X	D.C. BELOW TECH MIN
26	CHANDRAPUR U-8 AND U-9	1	18	474	329	145	UNIT-8 SYN. 3:17HRS AS PER SYSTEM CONDITION
		29	43	948	658	290	UNIT-9 SYN. 3:17HRS AS PER SYSTEM CONDITION
		55	70	948	658	290	UNIT-9 SYN. 3:17HRS AS PER SYSTEM CONDITION
27	JSW U-1	1	18	275	200	75	AS PER SYSTEM CONDITION
		29	43	275	200	75	AS PER SYSTEM CONDITION
		65	70	275	200	75	AS PER SYSTEM CONDITION
28	ADANI U-2	1	18	580	432	148	AS PER SYSTEM CONDITION
		29	43	580	432	148	AS PER SYSTEM CONDITION
29	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12SEPT. 2017

3 # Indicates that back down withdrawn due to Line loading/system constraints.