

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-3	X	X	X	X	X	UNIT SHUT DOWN
4	DTPS REL U1 AND U2	1	96	460	336	124	AS PER SYSTEM CONDITION
5	NASHIK U-3,4,5	1	96	464	382	82	UNIT-5 SHUT DOWN AS PER SYSTEM CONDITION
6	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
7	RATTANINDIA U1 TO U-5	1	96	490	344	146	AS PER SYSTEM CONDITION UNIT-2, 3, 5 SHUT DOWN
8	PARLEY U-6 AND U-7	1	34	X	X	X	D.C. BELOW TECH MIN UNIT-7 SHUT DOWN
		37	43	X	X	X	D.C. BELOW TECH MIN UNIT-7 SHUT DOWN
		48	96	X	X	X	D.C. BELOW TECH MIN UNIT-7 SHUT DOWN
9	BHUSWAL U-4 AND U-5	1	34	950	644	306	AS PER SYSTEM CONDITION
		37	43	950	644	306	AS PER SYSTEM CONDITION
		48	96	950	644	306	AS PER SYSTEM CONDITION
10	VPL U-1 AND U-2	1	34	572	382	190	AS PER SYSTEM CONDITION
		37	43	572	382	190	AS PER SYSTEM CONDITION
		48	96	572	382	190	AS PER SYSTEM CONDITION
11	PARLEY U-8	1	34	X	X	X	D.C. BELOW TECH MIN
		37	43	X	X	X	D.C. BELOW TECH MIN
		48	96	X	X	X	D.C. BELOW TECH MIN
12	KHAPERKHEDA U-1 TO U-4	1	34	150	143	7	UNIT-1,3,4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		37	43	150	143	7	UNIT-1,3,4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		48	96	150	143	7	UNIT-1,3,4 SHUT DOWN B/D AS PER SYSTEM CONDITION
13	PARAS U-3 AND U-4	1	24	460	332	128	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		37	42	460	332	128	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		76	96	460	332	128	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
14	ADANI TIRODA 440 PPA	1	25	440	0	440	AS PER SYSTEM CONDITION
		76	96	440	0	440	AS PER SYSTEM CONDITION
15	KORADI U-5,6,7	1	25	X	X	X	UNIT-5,6,SHUTDOWN UNIT-7 RUNNING BELOW TECH MIN
		76	96	X	X	X	UNIT-5,6,SHUTDOWN UNIT-7 RUNNING BELOW TECH MIN
16	ADANI U-1 (1200+125)MW PP	1	25	461	432	29	AS PER SYSTEM CONDITION
		76	96	468	432	36	AS PER SYSTEM CONDITION
17	ADANI U-4 (1200+125)MW PP	1	25	461	432	29	AS PER SYSTEM CONDITION
		76	96	468	432	36	AS PER SYSTEM CONDITION
18	ADANI U-5 (1200+125)MW PP	1	25	X	X	X	RUNNING BELOW TECH MIN
		76	96	468	432	36	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	1	24	430	335	95	AS PER SYSTEM CONDITION
		76	96	470	335	135	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-3 TO U-7	1	22	786	656	130	UNIT-3,4,5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		77	96	786	656	130	UNIT-3,4,5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
21	KORADI U-8,9,10	1	22	897	808	89	UNIT-10 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		77	96	X	X	X	UNIT-10 SHUT DOWN, D.C. BELOW TECH MIN
22	JSW U-1	1	22	282	200	82	AS PER SYSTEM CONDITION
		78	96	282	200	82	AS PER SYSTEM CONDITION
23	CHANDRAPUR U-8 AND U-9	1	22	882	658	224	AS PER SYSTEM CONDITION
		82	96	882	658	224	AS PER SYSTEM CONDITION
24	IEPL TO MSEDCIL DA	X	X	X	X	X	UNIT SHUT DOWN
25	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
26	ADANI U-2	1	22	623	432	191	AS PER SYSTEM CONDITION
		85	96	623	432	191	AS PER SYSTEM CONDITION

Note :
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
2 M.O.D. RATES REVISED FROM DT. 12TH NOV 2016
3 # Indicate that back down withdrawn due to Line loading/system constraints.