

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASIK U-3, U-4 & U-5	1	96	177	102	75	AS PER SYSTEM CONDITION*/ U-3 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
2	JSWEL TO AEML DA	X	X	X	X	X	NO TRANSACTION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	30	455	250	205	AS PER SYSTEM CONDITION #
		47	60	455	250	205	AS PER SYSTEM CONDITION #
		71	96	455	250	205	AS PER SYSTEM CONDITION #
5	RATTANINDIA U-1 TO U-5	1	29	245	135	110	AS PER SYSTEM CONDITION/ U-1,3,4&5 UNDER ZERO SCHEDULE/U-2 W/Dn at 17:30 hrs
		48	58	245	135	110	
6	KORADI U-6 & U-7	1	29	171	103	68	AS PER SYSTEM CONDITION/ U-7 OUT
		54	58	171	103	68	AS PER SYSTEM CONDITION/ U-7 OUT
		72	96	171	103	68	AS PER SYSTEM CONDITION/ U-7 OUT
7	TPC U-5	1	29	470	260	210	AS PER SYSTEM CONDITION #
		72	75	470	260	210	AS PER SYSTEM CONDITION #
		78	96	470	260	210	AS PER SYSTEM CONDITION #
8	SWPGL to MSEDCL	1	29	240	132	108	AS PER SYSTEM CONDITION
		54	58	240	132	108	AS PER SYSTEM CONDITION
		72	75	240	132	108	AS PER SYSTEM CONDITION
		79	96	240	132	108	AS PER SYSTEM CONDITION
9	PARALI U-6 & U-7	1	29	454	242	212	AS PER SYSTEM CONDITION
		55	58	454	242	212	AS PER SYSTEM CONDITION
		79	96	454	242	212	AS PER SYSTEM CONDITION
10	TPC U-8	1	29	229	126	103	AS PER SYSTEM CONDITION #
		79	96	229	126	103	AS PER SYSTEM CONDITION #
11	PARALI U-8	1	29	229	122	107	AS PER SYSTEM CONDITION
		80	96	229	122	107	AS PER SYSTEM CONDITION
12	APML U-1,U-4 & U-5 (PPA440 MW)	1	27	440	0	440	AS PER SYSTEM CONDITION
		80	96	440	0	440	AS PER SYSTEM CONDITION
13	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	27	1399	1017	382	AS PER SYSTEM CONDITION
		81	96	1399	1017	382	AS PER SYSTEM CONDITION
14	DHARIWAL to MSEDCL (Case- IV)	1	27	185	101.75	83.25	AS PER SYSTEM CONDITION
		82	96	185	101.75	83.25	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-1 TO U-4	1	27	498	310	188	AS PER SYSTEM CONDITION/ U-3 OUT
		89	96	498	310	188	AS PER SYSTEM CONDITION/ U-3 OUT
16	CHANDRAPUR U-3 TO U-7	1	22	1056	712	344	AS PER SYSTEM CONDITION/ U-7 OUT
		90	96	1056	712	344	AS PER SYSTEM CONDITION/ U-7 OUT
17	PARAS U-3 & U-4	1	21	227	121	106	AS PER SYSTEM CONDITION/ U-4 OUT
		90	96	227	121	106	AS PER SYSTEM CONDITION/ U-4 OUT
18	BHUSAWAL U-4 & U-5	1	21	940	518	422	AS PER SYSTEM CONDITION
		90	94	940	518	422	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	1	21	1000	682	318	AS PER SYSTEM CONDITION/ U-10 OUT
		90	94	1000	682	318	AS PER SYSTEM CONDITION/ U-10 OUT
20	CHANDRAPUR U-8 & U-9	5	20	940	518	422	AS PER SYSTEM CONDITION
21	JSW U-1	5	13	282	160	122	AS PER SYSTEM CONDITION
22	KHAPERKHEDA U-5	5	13	376	256	120	AS PER SYSTEM CONDITION
23	SWPGL to BEST	6	13	100	69	31	AS PER SYSTEM CONDITION
24	APML U-2 & U-3	6	13	1246	735	511	AS PER SYSTEM CONDITION

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 26TH Nov 2020