

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
2	DTPS REL U-1 AND U-2	1	96	455	336	119	AS PER SYSTEM CONDITION
3	JSW TO REL (AEMI)	1	96	280	196	84	AS PER SYSTEM CONDITION
4	JSW TO REL (PXIL)	1	96	125	87.5	37.5	AS PER SYSTEM CONDITION
5	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
6	PARALI U-6 AND U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 ZERO SCHEDULE BY LMCELL
7	NASHIK U-3,4,5	1	96	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
8	PARALI U-8	X	X	X	X	X	ZERO SCHEDULE BY LM CELL
9	BHUSWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY LM CELL
10	VIPL U-1 AND U-2	X	X	X	X	X	UNIT 1 AND UNIT-2 SHUT DOWN
11	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNIT-1,2,3,4,5 ZERO SCHEDULE BY LM CELL
12	JSW U-1	1	25	290	200	90	AS PER SYSTEM CONDITION
		32	38	290	200	90	AS PER SYSTEM CONDITION
		41	96	290	200	90	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	25	940	644	296	AS PER SYSTEM CONDITION UNIT-5 SYN.
		33	36	940	644	296	AS PER SYSTEM CONDITION UNIT-5 SYN.
		42	96	836	644	192	AS PER SYSTEM CONDITION UNIT-5 SYN.
14	KHAERKHEDA U-1 TO U-4	1	25	X	X	X	D.C. BELOW TECH. MIN
		43	96	X	X	X	D.C. TECH. MIN
15	KORADI U-6 AND U-7	1	24	X	X	X	UNIT-7 , UNIT-6SHUT DOWN
		43	96	X	X	X	UNIT-7 , UNIT-6SHUT DOWN
16	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	24	304	0	304	AS PER SYSTEM CONDITION
		54	56	304	104	200	AS PER SYSTEM CONDITION
		61	74	304	0	304	AS PER SYSTEM CONDITION
		82	96	304	0	304	AS PER SYSTEM CONDITION
17	KORADI U-8, U9,U-10	1	24	1303	1216	87	AS PER SYSTEM CONDITION
		54	56	1303	1216	87	AS PER SYSTEM CONDITION
		61	74	1587	1296	291	AS PER SYSTEM CONDITION
		82	96	1391	1296	95	AS PER SYSTEM CONDITION
18	KHAERKHEDA U-5	1	24	428	335	93	AS PER SYSTEM CONDITION
		82	96	410	335	75	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	24	458	432	26	AS PER SYSTEM CONDITION
		82	96	458	432	26	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	24	458	432	26	AS PER SYSTEM CONDITION
		82	96	458	432	26	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-5(PPA 1200MW&125MW)	X	X	X	X	X	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	24	1378	1130	248	UNIT-4 SHUT DOWN AS PER SYSTEM CONDITION
		82	96	1003	796	207	UNIT-4 ,UNIT-5 SHUT DOWN AS PER SYSTEM CONDITION
23	PARAS U-3, U-4	1	24	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		84	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	24	940	656	284	AS PER SYSTEM CONDITION
		84	96	940	656	284	AS PER SYSTEM CONDITION
25	ADANI U-2	1	23	623	432	191	AS PER SYSTEM CONDITION
		85	96	623	432	191	AS PER SYSTEM CONDITION
26	ADANI U-3	1	23	623	432	191	AS PER SYSTEM CONDITION
		85	96	623	432	191	AS PER SYSTEM CONDITION

Note :
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH JAN-2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.