

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW TO AEML	1	96	90	63	27	AS PER SYSTEM CONDITION
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	NASHIK U-3, U-4 & U-5	1	96	187	142	45	AS PER SYSTEM CONDITION / U-3 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
5	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
6	JSW TO AEML	1	96	130.98	91.69	39.29	AS PER SYSTEM CONDITION
7	DTPS U-1 & U-2	1	96	456	336	120	AS PER SYSTEM CONDITION
8	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
9	TPC U-8	1	96	229	187	42	AS PER SYSTEM CONDITION
10	JSW TO AEML	1	96	150	105	45	AS PER SYSTEM CONDITION
11	BHUSAWAL U-4 & U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	DHARIWAL TO AEML	1	96	X	X	X	DC TECH MIN
13	RATTANINDIA U-1 TO U-5	1	34	490	344	146	AS PER SYSTEM CONDITION / U-1,U-2 & U-4 UNDER ZERO SCHEDULE
14	PARALI U-6 & U-7	1	34	458	332	126	AS PER SYSTEM CONDITION
		40	96	458	332	126	AS PER SYSTEM CONDITION
15	PARALI U-8	1	26	229	166	63	AS PER SYSTEM CONDITION
		30	34	229	166	63	AS PER SYSTEM CONDITION
		41	48	229	166	63	AS PER SYSTEM CONDITION
		67	96	229	166	63	AS PER SYSTEM CONDITION
		1	25	229	166	63	AS PER SYSTEM CONDITION/ U-4 OUT
16	PARAS U-3 & U-4	41	48	229	166	63	AS PER SYSTEM CONDITION/ U-4 OUT
		67	96	229	166	63	AS PER SYSTEM CONDITION/ U-4 OUT
		1	24	440	0	440	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA440 MW)	41	48	440	0	440	AS PER SYSTEM CONDITION
		67	96	440	0	440	AS PER SYSTEM CONDITION
		1	24	711	572	139	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-1 TO U-4	74	96	711	572	139	AS PER SYSTEM CONDITION
		1	24	1032	802	230	AS PER SYSTEM CONDITION/ U-3&5 OUT
19	CHANDRAPUR U-3 TO U-7	74	96	1032	802	230	AS PER SYSTEM CONDITION/ U-3&5 OUT
		1	23	1399	1296	103	AS PER SYSTEM CONDITION
20	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	76	96	1399	1296	103	AS PER SYSTEM CONDITION
		1	23	475	335	140	AS PER SYSTEM CONDITION
21	KHAPERKHEDA U-5	80	96	475	335	140	AS PER SYSTEM CONDITION
		1	23	1329	1240	89	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	80	96	1329	1240	89	AS PER SYSTEM CONDITION
		1	22	185	129.5	56	AS PER SYSTEM CONDITION
23	DHARIWAL TO MSEDCL(CASE IV)	81	96	185	129.5	56	AS PER SYSTEM CONDITION
		1	22	912	656	256	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 & U-9	81	96	912	656	256	AS PER SYSTEM CONDITION
		1	20	290	200	90	AS PER SYSTEM CONDITION
25	JSW U-1	82	96	290	200	90	AS PER SYSTEM CONDITION
		1	20	1246	864	382	AS PER SYSTEM CONDITION
26	APML U-2 & U-3	82	96	1246	864	382	AS PER SYSTEM CONDITION

## Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.  
Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 Revised MOD Rates effective from 00:00 HRS of 1st Feb 2020