

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: <u>9-Mar-14</u>							
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	ECONOMY SHUTDOWN
2	NASIK	1	35	516	425	91	AS PER MOD
		36	49	516	425	91	DUE TO SYSTEM CONDITION
		50	55	516	425	91	AS PER MOD
		56	60	516	425	91	DUE TO SYSTEM CONDITION
		61	96	516	425	91	AS PER MOD
3	JSW TO RINFRA DA (JSWPTC)	x	x	x	x	x	NO SCHEDULE
4	BHUSAWAL-2,3	x	x	x	x	x	DECL BELOW TECH MIN
5	TPC U-5	1	11	x	x	x	#
		12	33	473	292	181	AS PER MOD
		34	48	473	292	181	DUE TO SYSTEM CONDITION
		49	57	473	292	181	AS PER MOD
		58	60	473	292	181	DUE TO SYSTEM CONDITION
		61	77	473	292	181	AS PER MOD
		78	96	x	x	x	#
6	TPC U-8	x	x	x	x	x	UNIT SHUTDOWN
7	PARALI-3,4,5	1	29	151	138	13	AS PER MOD
		30	36	151	138	13	DUE TO SYSTEM CONDITION
		37	48	171	138	33	
		49	65	151	138	13	
		66	75	151	138	13	AS PER MOD
		76	81	151	138	13	DUE TO SYSTEM CONDITION
		82	96	151	138	13	AS PER MOD
8	KORADI	x	x	x	x	x	DECL BELOW TECH MIN
9	DHARIWAL	25	88	220	150	70	DUE TO SYSTEM CONDITION
10	KHAPERKHEDA U5	1	28	475	335	140	AS PER MOD
		29	65	475	335	140	DUE TO SYSTEM CONDITION
		66	75	475	335	140	AS PER MOD
		76	81	475	335	140	DUE TO SYSTEM CONDITION
		82	96	475	335	140	AS PER MOD
11	PARLY U-6	1	36	x	x	x	DECL BELOW TECH MIN
		37	48	228	166	62	DUE TO SYSTEM CONDITION
		49	96	x	x	x	DECL BELOW TECH MIN
12	BHUSAWAL U4	1	27	400	322	78	AS PER MOD
		28	36	400	322	78	DUE TO SYSTEM CONDITION
		37	48	465	322	143	
		49	66	400	322	78	
		67	74	400	322	78	AS PER MOD
		75	83	400	322	78	DUE TO SYSTEM CONDITION
		84	96	400	322	78	AS PER MOD
13	REL_G	1	24	477	336	141	AS PER MOD
		25	42	477	336	141	DUE TO SYSTEM CONDITION
		43	55	x	x	x	#
		56	66	477	336	141	DUE TO SYSTEM CONDITION
		67	74	477	336	141	AS PER MOD
		75	83	477	336	141	DUE TO SYSTEM CONDITION
		84	96	477	336	141	AS PER MOD
14	PARLY U-7	1	36	x	x	x	DECL BELOW TECH MIN
		37	48	228	166	62	DUE TO SYSTEM CONDITION
		49	96	x	x	x	DECL BELOW TECH MIN

15	KHAPER KHEDA U 1 TO 4	1	23	503	430	73	AS PER MOD
		24	67	503	430	73	DUE TO SYSTEM CONDITION
		68	74	503	430	73	AS PER MOD
		75	85	503	430	73	DUE TO SYSTEM CONDITION
		86	96	503	430	73	AS PER MOD
16	BHUSAWAL U5	1	23	350	322	28	AS PER MOD
		24	36	380	322	58	DUE TO SYSTEM CONDITION
		37	67	350	322	28	
		68	73	350	322	28	AS PER MOD
		74	85	350	322	28	DUE TO SYSTEM CONDITION
		86	96	350	322	28	AS PER MOD
17	CHANDRAPUR	1	23	1791	1547	244	AS PER MOD
		24	67	1791	1547	244	DUE TO SYSTEM CONDITION
		68	73	1791	1547	244	AS PER MOD
		74	85	1791	1547	244	DUE TO SYSTEM CONDITION
		86	96	1791	1547	244	AS PER MOD
18	INDIA BULL	1	22	245	172	73	AS PER MOD
		23	32	245	172	73	DUE TO SYSTEM CONDITION
		37	67	245	172	73	
		68	73	245	172	73	AS PER MOD
		74	87	245	172	73	DUE TO SYSTEM CONDITION
		88	96	245	172	73	AS PER MOD
19	PARAS -U3	1	21	230	164	66	AS PER MOD
		22	32	230	164	66	DUE TO SYSTEM CONDITION
		37	67	230	164	66	
		68	73	230	164	66	AS PER MOD
		74	92	230	164	66	DUE TO SYSTEM CONDITION
		93	96	230	164	66	AS PER MOD
20	PARAS U4	1	21	230	168	62	AS PER MOD
		22	32	230	168	62	DUE TO SYSTEM CONDITION
		37	67	230	168	62	
		68	73	230	168	62	AS PER MOD
		74	92	230	168	62	DUE TO SYSTEM CONDITION
		93	96	230	168	62	AS PER MOD
21	ADANI U-1	1	20	605	432	173	AS PER MOD
		21	35	605	432	173	DUE TO SYSTEM CONDITION
		36	47	605	505	100	
		48	68	605	432	173	
		69	72	605	432	173	AS PER MOD
		73	92	605	432	173	DUE TO SYSTEM CONDITION
		93	96	605	563	42	AS PER MOD
22	JSW U-1	1	19	275	200	75	AS PER MOD
		20	30	x	x	x	DC REVISED BELOW TECH MIN
		37	96	275	200	75	DUE TO SYSTEM CONDITION
23	AMNEPL TO RINFRA	x	x	x	x	x	NO SCHEDULE
24	JSW TO RINFRA (RETL) (55 MW)	x	x	x	x	x	DECL BELOW TECH MIN
25	ADANI U-2 AND U-3	1	23	1246	864	382	DUE TO SYSTEM CONDITION
		38	48	1246	1160	86	
		49	96	1246	864	382	

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Feb-2014.
- 3 # Backing Down not implemented due to Line Loading constraints.