

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASHIK U-3, U-4 & U-5	1	44	177	142	35	AS PER SYSTEM CONDITION / U-3 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
		54	62				
		70	96	177	142	35	
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
5	JSW TO AEML	1	44	228.85	160.195	68.655	AS PER SYSTEM CONDITION
		54	62	228.85	160.195	68.655	AS PER SYSTEM CONDITION
		70	96	228.85	160.195	68.655	AS PER SYSTEM CONDITION
6	DTPS U-1 & U-2	1	44	456	336	120	AS PER SYSTEM CONDITION
		54	62	456	336	120	AS PER SYSTEM CONDITION
		70	96	456	336	120	AS PER SYSTEM CONDITION
7	TPC U-5	1	24	473	292	181	AS PER SYSTEM CONDITION
		41	43	473	292	181	AS PER SYSTEM CONDITION
		70	96	473	292	181	AS PER SYSTEM CONDITION
8	JSW TO AEML	1	24	190	133	57	AS PER SYSTEM CONDITION
		41	43	190	133	57	AS PER SYSTEM CONDITION
		70	96	190	133	57	AS PER SYSTEM CONDITION
9	TPC U-8	1	24	229	187	42	AS PER SYSTEM CONDITION
		41	43	229	187	42	AS PER SYSTEM CONDITION
		70	96	229	187	42	AS PER SYSTEM CONDITION
10	RATTANINDIA U-1 TO U-5	1	24	245	172	73	AS PER SYSTEM CONDITION/ U-1,3,4&5 UNDER ZERO SCHEDULE
		42	43	245	172	73	
		70	96	245	172	73	
11	PARALI U-6 & U-7	1	21	458	332	126	AS PER SYSTEM CONDITION
		70	96	458	332	126	AS PER SYSTEM CONDITION
12	BHUSAWAL U-4 & U-5	1	21	894	644	250	AS PER SYSTEM CONDITION
		71	96	894	644	250	AS PER SYSTEM CONDITION
13	PARALI U-8	1	21	229	166	63	AS PER SYSTEM CONDITION
		71	96	229	166	63	AS PER SYSTEM CONDITION
14	CHANDRAPUR U-3 TO U-7	1	21	1621	1282	339	AS PER SYSTEM CONDITION
		73	96	1621	1282	339	AS PER SYSTEM CONDITION
15	APML U-1,U-4 & U-5 (PPA440 MW)	1	20	440	0	440	AS PER SYSTEM CONDITION
		73	96	440	0	440	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	1	20	702	572	130	AS PER SYSTEM CONDITION
		76	96	702	572	130	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	20	1399	1296	103	AS PER SYSTEM CONDITION
		76	96	1399	1296	103	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-5	1	20	428	335	93	AS PER SYSTEM CONDITION
		76	96	428	335	93	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-8 & U-9	1	20	884	656	228	AS PER SYSTEM CONDITION
		80	96	884	656	228	AS PER SYSTEM CONDITION
20	PARAS U-3 & U-4	1	20	458	332	126	AS PER SYSTEM CONDITION
		80	96	458	332	126	AS PER SYSTEM CONDITION
21	KORADI U-8 TO U-10	1	20	1384	1257	127	AS PER SYSTEM CONDITION
		80	96	1384	1257	127	AS PER SYSTEM CONDITION
22	DHARIWAL TO MSEDCL(CASE IV)	1	18	185	129.5	56	AS PER SYSTEM CONDITION
		80	86	185	129.5	56	AS PER SYSTEM CONDITION
23	JSW U-1	X	X	X	X	X	UNIT SHUT DOWN
24	APML U-2 & U-3	1	15	1246	864	382	AS PER SYSTEM CONDITION
		80	86	1246	864	382	AS PER SYSTEM CONDITION
25	SWPGL to BEST	82	86	100	70	30	AS PER SYSTEM CONDITION

## Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.  
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 Revised MOD Rates effective from 00:00 hrs of 1st Mar 2020