

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	32	516	425	91	AS Per MOD
		66	68				DUE TO SYSTEM CONDITION
		69	75				AS Per MOD
		91	96				AS Per MOD
3	TPC U-8	1	30	235	172	63	AS Per MOD
		92	96				AS Per MOD
4	TPC U-5	1	31	473	292	181	AS Per MOD
		93	96	473	320	153	DUE TO SYSTEM CONDITION
5	PARALI-6	1	24	170	166	4	AS Per MOD
		68	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
6	PARALI 3,4,5	1	24	280	273	7	AS Per MOD
		68	74				DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	24	170	166	4	AS Per MOD
		68	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
10	REL G	1	23	479	336	143	AS Per MOD
11	CHANDRAPUR	2	3	1278	1192	86	DUE TO SYSTEM CONDITION
		4	20				AS Per MOD
		68	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO COAL MILL PROBLEM
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSDEL	2	6	245	172	73	DUE TO SYSTEM CONDITION
		7	19				AS Per MOD
		20	20	245	210	35	DUE TO SYSTEM CONDITION
		69	74	245	172	73	DUE TO SYSTEM CONDITION
14	KHAPERKHEDA-U 1 TO 4	2	7	471	428	43	DUE TO SYSTEM CONDITION
		8	19				AS Per MOD
		68	68	448	405	43	DUE TO SYSTEM CONDITION
		69	74	471	405	66	DUE TO SYSTEM CONDITION
15	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	APML U 1 TO MSDEL	2	18	617	432	185	DUE TO SYSTEM CONDITION
		36	96	617	532	85	DUE TO LINE CONSTRAINT
18	KHAPERKHEDA-5	68	74	360	335	25	DUE TO SYSTEM CONDITION
19	JSW U 1	69	75	275	200	75	DUE TO SYSTEM CONDITION
20	AMNEPL TO REL	70	74	53	37.1	15.9	DUE TO SYSTEM CONDITION
21	APML U 3 TO MSDEL	37	76	617	432	185	DUE TO LINE CONSTRAINT
22	APML U 2 TO MSDEL	41	75	617	432	185	DUE TO LINE CONSTRAINT

TPC U 5 ,U 8 & REL G IN BLK(68-74) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.