

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
2	SWPL U-1,2,4 TO MSEDCL	1	96	X	X	X	AS PER SYSTEM CONDITION
3	TPC U-6	1	96	473	292	181	AS PER SYSTEM CONDITION
4	VIPL U1 &2	1	96	X	X	X	RUNNING BELOW TECH MIN UNIT-2 TRIPPED AND SYN.
5	DTPS (AEML) U-1 AND U-2	1	40	455	336	119	AS PER SYSTEM CONDITION
		47	96	455	336	119	AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	96	X	X	X	#
7	BHUSWAL U-3	X	X	X	X	X	UNIT-3 ZERO SCHEDULE GIVEN BY MSEDCL
8	RATTANINDIA U-1 TO 5 (1200MW PPA)	1	24	735	516	219	unit- 4 and unit-5 shut down , AS PER SYSTEM CONDITION
		28	39	735	516	219	unit- 4 and unit-5 shut down , AS PER SYSTEM CONDITION
		53	96	735	516	219	unit- 4 and unit-5 shut down AS PER SYSTEM CONDITION
9	PARALI U-6 AND U-7	1	24	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
		28	39	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
		53	96	229	166	63	AS PER SYSTEM CONDITION UNIT-6 SHUT DOWN
10	PARALI U-8	1	24	229	166	63	AS PER SYSTEM CONDITION
		54	96	229	166	63	AS PER SYSTEM CONDITION
11	BHUSWAL U-4 AND U-5	1	22	940	644	296	AS PER SYSTEM CONDITION
		59	96	940	644	296	AS PER SYSTEM CONDITION
12	KORADI U-6 AND U-7	1	22	X	X	X	UNIT-6 unit-7 shut down
		59	96	X	X	X	UNIT-6 unit-7 shut down
13	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
14	DHARWAL TO MSEDCL	1	22	X	X	X	UNIT IS RUNNING ON TECH. MIN
		59	96	X	X	X	UNIT IS RUNNING ON TECH. MIN
15	KHAPERKHEDA U-1 TO U-4	1	22	501	431	70	UNIT -1 SHUT DOWN AS PER SYSTEM CONDITION
		59	96	505	431	74	UNIT -1 SHUT DOWN AS PER SYSTEM CONDITION
16	JSW U-1	1	22	290	200	90	AS PER SYSTEM CONDITION
		59	96	290	200	90	AS PER SYSTEM CONDITION
17	KORADI U-8, U-9, U-10	1	22	X	X	X	D.C BELOW TECH MIN
		62	96	X	X	X	D.C BELOW TECH MIN
18	KHAPERKHEDA U-5	1	22	428	335	93	AS PER SYSTEM CONDITION
		62	96	428	335	93	AS PER SYSTEM CONDITION
19	PARAS U-3 AND U-4	1	22	230	166	64	UNIT-3 SHUT DOWNAS PER SYSTEM CONDITION
		62	96	230	166	64	UNIT-3 SHUT DOWNAS PER SYSTEM CONDITION
20	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	21	440	0	440	AS PER SYSTEM CONDITION
		62	96	440	0	440	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	1	17	1542	1282	260	AS PER SYSTEM CONDITION
		65	96	1496	1282	214	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-1(PPA 1200MW&1250MW)	1	17	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1(PPA 1200MW&1250MW)	1	17	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1(PPA 1200MW&1250MW)	1	17	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-8 AND U-9	1	17	846	656	190	AS PER SYSTEM CONDITION
		65	96	865	656	209	AS PER SYSTEM CONDITION
26	ADANI U-2	1	2	623	432	191	AS PER SYSTEM CONDITION
		70	96	623	432	191	AS PER SYSTEM CONDITION
27	ADANI U-3	1	2	623	432	191	AS PER SYSTEM CONDITION
		70	96	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH NOV- 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.