

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASHIK U-3, U-4 & U-5	1	96	177	142	35	AS PER SYSTEM CONDITION / U-3 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
5	JSW TO AEML	1	96	228.85	160.195	68.655	AS PER SYSTEM CONDITION
6	DTPS U-1 & U-2	1	37	456	336	120	AS PER SYSTEM CONDITION
		47	96	456	336	120	AS PER SYSTEM CONDITION #
7	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
8	JSW TO AEML	1	96	190	133	57	AS PER SYSTEM CONDITION
9	TPC U-8	1	96	229	187	42	AS PER SYSTEM CONDITION
10	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
11	PARALI U-6 & U-7	1	96	229	166	63	AS PER SYSTEM CONDITION/ U-7 UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 & U-5	1	96	893	644	249	AS PER SYSTEM CONDITION
13	PARALI U-8	1	96	229	166	63	AS PER SYSTEM CONDITION
14	CHANDRAPUR U-3 TO U-7	1	24	1621	1282	339	AS PER SYSTEM CONDITION
		32	96	1621	1282	339	AS PER SYSTEM CONDITION
15	APML U-1,U-4 & U-5 (PPA440 MW)	1	23	440	0	440	AS PER SYSTEM CONDITION
		32	96	440	0	440	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	1	23	684	572	112	AS PER SYSTEM CONDITION
		32	96	684	572	112	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	23	1399	1296	103	AS PER SYSTEM CONDITION
		33	96	1399	1296	103	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-5	1	23	413	335	78	AS PER SYSTEM CONDITION
		34	96	413	335	78	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-8 & U-9	1	20	921	656	265	AS PER SYSTEM CONDITION
		34	96	921	656	265	AS PER SYSTEM CONDITION
20	PARAS U-3 & U-4	1	20	458	332	126	AS PER SYSTEM CONDITION
		34	96	458	332	126	AS PER SYSTEM CONDITION
21	KORADI U-8 TO U-10	1	20	1476	1257	219	AS PER SYSTEM CONDITION
		34	96	1476	1257	219	AS PER SYSTEM CONDITION
22	DHARIWAL TO MSEDCL(CASE IV)	12	20	185	129.5	56	AS PER SYSTEM CONDITION
		37	96	185	129.5	56	AS PER SYSTEM CONDITION
23	JSW U-1	X	X	X	X	X	UNIT SHUT DOWN
24	APML U-2 & U-3	13	18	1246	864	382	AS PER SYSTEM CONDITION
		38	44	1246	864	382	AS PER SYSTEM CONDITION
		58	96	1246	864	382	AS PER SYSTEM CONDITION
25	SWPGL to BEST	39	44	100	70	30	AS PER SYSTEM CONDITION
		59	96	100	70	30	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 Revised MOD Rates effective from 00:00 hrs of 1st Mar 2020