

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							10-Apr-14
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	BELOW TECH MIN
2	NASIK	70	76	500	425	75	AS PER MOD
		78	85	500	485	15	DUE TO SYSTEM CONDITION
		88	92	500	485	15	DUE TO SYSTEM CONDITION
3	BHUSAWAL-2,3	x	x	x	x	x	DECL BELOW TECH MIN
4	TPC U-5	70	78	x	x	x	#
		88	92	x	x	x	
5	TPC U-8	x	x	x	x	x	UNIT SHUTDOWN
6	VIPL TO RINFRA	x	x	x	x	x	DECL BELOW TECH MIN
7	PARALI-3,4,5	72	74	141	138	3	AS PER MOD
		75	76	141	138	3	DUE TO SYSTEM CONDITION
		88	92	222	138	84	
8	KORADI	x	x	x	x	x	DECL BELOW TECH MIN
9	DHARIWAL TO TPCD (100 MW)	72	74	100	70	30	AS PER MOD
		75	76	100	70	30	DUE TO SYSTEM CONDITION
		88	92	100	70	30	
10	DHARIWAL TO TPCD (150 MW)	72	74	150	105	45	AS PER MOD
		75	76	150	105	45	DUE TO SYSTEM CONDITION
		88	92	150	105	45	
12	BHUSAWAL U4	73	73	329	322	7	AS PER MOD
		74	76	329	322	7	DUE TO SYSTEM CONDITION
		88	92	338	322	16	
13	KHAPERKHEDA U5	73	73	472	411	61	AS PER MOD
		74	76	472	411	61	DUE TO SYSTEM CONDITION
		88	92	472	411	61	
14	PARLY U-6	74	76	x	x	x	DECL BELOW TECH MIN
		88	92	x	x	x	
15	REL_G	74	76	x	x	x	#
		88	92	x	x	x	
16	BHUSAWAL U5	74	76	x	x	x	DECL BELOW TECH MIN
		88	92	x	x	x	
17	PARLY U-7	74	76	x	x	x	DECL BELOW TECH MIN
		88	92	x	x	x	
18	KHAPER KHEDA U 1 TO 4	74	76	516	431	85	DUE TO SYSTEM CONDITION
		88	92	516	431	85	
19	CHANDRAPUR	74	76	1851	1547	304	DUE TO SYSTEM CONDITION
		88	92	1851	1547	304	
20	INDIA BULL	74	76	245	172	73	DUE TO SYSTEM CONDITION
		88	92	245	172	73	
21	PARAS -U3	74	76	230	164	66	DUE TO SYSTEM CONDITION
		88	92	210	164	46	
22	PARAS U4	74	76	210	168	42	DUE TO SYSTEM CONDITION
		88	92	210	168	42	

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Mar.-2014.
- 3 # BACKED DOWN AS PER MOD. WITHDRWAN DUE TO LINE LOADING CONSTRAINTS.