

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

10-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	35	483	145	338	AS PER MOD
		36	39	483	260	223	
		40	66	483	280	203	
		67	71	483	400	83	
		72	78	483	250	233	DUE TO SYSTEM CONDITION
		79	96	483	200	283	
2	APML TO MSDEL	49	66	617	400	217	DUE TO LINE CONSTRAINT#

SCHEDULE WAS REDUCED DUE TO 400KV WARDHA(PG)-PARLY (PG) OUTAGE.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View

2 MOD rates revised w.e.f 18-April-2013.