

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							10-May-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	TPC U-8	1	32	235	187	48	AS PER SYSTEM CONDITION
		33	68	X	X	X	#
		69	96	235	187	48	AS PER SYSTEM CONDITION
3	TPC U-5	1	32	473	292	181	AS PER SYSTEM CONDITION
		33	72	X	X	X	#
		73	96	473	292	181	AS PER SYSTEM CONDITION
4	NASIK	1	4	546	425	121	AS PER SYSTEM CONDITION
		5	27	364	284	80	AS PER SYSTEM CONDITION UNIT-5 TRIPPED AT 1:15HRS AND SYN. 6:35HRS
		28	58	546	425	121	AS PER SYSTEM CONDITION
		59	80	X	X	X	#
		81	94	546	425	121	AS PER SYSTEM CONDITION
		95	96	X	X	X	#
5	REL DAHANU U1 AND U2	1	32	462	336	126	AS PER SYSTEM CONDITION
		33	47	X	X	X	#
		48	58	462	336	126	
		59	72	X	X	X	#
		73	96	462	336	126	B/D AS PER SYSTEM CONDITION
6	RATTANINDIA U1,2,3,4,5	1	25	735	516	219	U-4 & 5 SHUTDOWN; BD AS PER SYSTEM CONDITION
		29	96	735	516	219	U-4 & 5 SHUTDOWN; BD AS PER SYSTEM CONDITION
7	BHUSWAL U2,3	1	25	X	X	X	UNIT-2 SHUT DOWN; UNIT-3 SHUT DOWN
		29	36	X	X	X	UNIT-2 SHUT DOWN; UNIT-3 SHUT DOWN
		29	96	X	X	X	UNIT-2 SHUT DOWN; UNIT-3 SYN. 12-51HRS RUNNING BELOW TECH MIN
8	DHARIWAL TO MSEB	1	25	150	140	10	AS PER SYSTEM CONDITION
		30	96	150	140	10	AS PER SYSTEM CONDITION
9	KORADI U-5 TO U-7	1	25	X	X	X	UNIT-7 RUNNING BELOW TECH MIN UNIT-5 AND UNIT-6 SHUT DOWN
		30	96	X	X	X	UNIT-7 RUNNING BELOW TECH MIN UNIT-5 AND UNIT-6 SHUT DOWN
10	KHAPERKHEDA U1 TO U4	1	24	711	572	139	AS PER SYSTEM CONDITION
		32	80	711	572	139	AS PER SYSTEM CONDITION
		85	96	711	572	139	AS PER SYSTEM CONDITION
11	JSWPTC TO REL DA	X	X	X	X	X	VARIABLE SCHEDULE
12	PARLY U-6 AND U7	1	10	458	332	126	AS PER SYSTEM CONDITION
		16	24	458	332	126	AS PER SYSTEM CONDITION
		32	58	458	332	126	AS PER SYSTEM CONDITION
		64	80	458	332	126	AS PER SYSTEM CONDITION
		85	96	458	332	126	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	10	846	644	202	AS PER SYSTEM CONDITION
		16	24	846	644	202	AS PER SYSTEM CONDITION
		32	36	846	644	202	AS PER SYSTEM CONDITION
		41	44	846	644	202	AS PER SYSTEM CONDITION
		50	57	846	644	202	AS PER SYSTEM CONDITION
		64	79	846	644	202	AS PER SYSTEM CONDITION
		86	96	846	644	202	AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-5	1	10	475	335	140	AS PER SYSTEM CONDITION
		16	24	475	335	140	AS PER SYSTEM CONDITION
		32	36	475	335	140	AS PER SYSTEM CONDITION
		41	44	475	335	140	AS PER SYSTEM CONDITION
		50	57	475	335	140	AS PER SYSTEM CONDITION
		64	79	475	335	140	AS PER SYSTEM CONDITION
		86	96	475	335	140	AS PER SYSTEM CONDITION
15	PARLY U-8	X	X	X	X	X	UNIT-8SHUT DOWN
16	PARAS U3 AND U-4	1	10	460	332	128	AS PER SYSTEM CONDITION
		32	36	460	332	128	AS PER SYSTEM CONDITION
		41	44	460	332	128	AS PER SYSTEM CONDITION
		50	57	460	332	128	AS PER SYSTEM CONDITION
		64	79	460	332	128	AS PER SYSTEM CONDITION
		89	96	460	332	128	AS PER SYSTEM CONDITION
17	VIPL U1 AND U2	1	9	546	382	164	AS PER SYSTEM CONDITION
		32	36	546	418	128	AS PER SYSTEM CONDITION
		41	44	546	440	106	AS PER SYSTEM CONDITION
		50	56	546	382	164	AS PER SYSTEM CONDITION
		73	79	546	382	164	AS PER SYSTEM CONDITION
		89	96	546	382	164	AS PER SYSTEM CONDITION
18	KORADI U8 ,U9,10	1	9	1439	1176	263	AS PER SYSTEM CONDITION
		32	36	1496	1290	206	AS PER SYSTEM CONDITION
		41	44	1496	1290	206	AS PER SYSTEM CONDITION
		74	79	1555	1290	265	AS PER SYSTEM CONDITION
		89	96	1291	1225	66	AS PER SYSTEM CONDITION
		1	9	440	92	348	AS PER SYSTEM CONDITION

19	ADANI 440 PPA	41	44	440	166	274	AS PER SYSTEM CONDITION
		74	78	440	146	294	AS PER SYSTEM CONDITION
		89	96	440	95	345	AS PER SYSTEM CONDITION
20	ADANI U-1(1200MW &125MW PPA)	1	9	401	X	X	D.C BELOW TECH
		41	44	401	X	X	D.C BELOW TECH
		74	78	401	X	X	D.C BELOW TECH
		89	96	401	X	X	D.C BELOW TECH
21	ADANI U-4(1200MW &125MW PPA)	1	9	401	X	X	D.C BELOW TECH
		41	44	401	X	X	D.C BELOW TECH
		74	78	401	X	X	D.C BELOW TECH
		89	96	401	X	X	D.C BELOW TECH
22	ADANI U-5(1200MW &125MW PPA)	1	9	401	X	X	D.C BELOW TECH
		41	44	401	X	X	D.C BELOW TECH
		74	78	401	X	X	D.C BELOW TECH
		89	96	401	X	X	D.C BELOW TECH
23	CHANDRAPUR U3 TO U7	1	9	1216	954	262	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
		41	44	1216	954	262	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
		74	78	1216	954	262	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
		90	96	1216	954	262	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
24	CHANDRAPUR U8 AND U9	1	9	702	658	44	AS PER SYSTEM CONDITION
		41	44	702	658	44	AS PER SYSTEM CONDITION
		77	78	702	658	44	AS PER SYSTEM CONDITION
		90	96	702	658	44	AS PER SYSTEM CONDITION
25	ADANI UNIT-2	1	8	623	432	191	AS PER SYSTEM CONDITION
		41	44	623	580	43	AS PER SYSTEM CONDITION
		91	96	623	530	93	AS PER SYSTEM CONDITION
26	ADANI U-3	1	8	623	432	191	AS PER SYSTEM CONDITION
		41	44	623	580	43	AS PER SYSTEM CONDITION
		91	96	623	530	93	AS PER SYSTEM CONDITION
27	JSW U-1	1	4	230	200	30	AS PER SYATEM CONDITION

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Dispatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 1 M.O.D.RATES EFFECTIVE FROM 12TH APRIL 2017
- 2
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.