

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:						10-Jul-14	
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	BELOW TECH MIN
2	JSW TO RINFRA (DA)	9	40	x	x	x	NO SCHEDULE
		71	77	78	55	23	AS PER MOD
		88		116	111	5	
		93	95	51	36	15	
3	NASIK	9	40	344	283	61	DUE TO SYSTEM CONDITION
		71	77	352	283	69	AS PER MOD
		94	96	172	141	31	
4	JSW TO TPC (DA)	9	20	x	x	x	TECHNICAL MIN SCHEDULE
		21	40	191	146	45	DUE TO SYSTEM CONDITION
		77		75	68	7	AS PER MOD
5	KORADI	x	x	x	x	x	BELOW TECH MIN
6	BHUSAWAL-2,3	x	x	x	x	x	BELOW TECH MIN
7	VIPL TO RINFRA U-1	9	32	250	190	60	DUE TO SYSTEM CONDITION
		41	45	250	190	60	AS PER MOD
		73	76	250	208	42	
8	VIPL TO RINFRA U-2	9	32	250	190	60	DUE TO SYSTEM CONDITION
		41	45	250	190	60	AS PER MOD
		73	76	250	209	41	
9	PARALI-3,4,5	9	13	141	138	3	AS PER MOD
		73	75	141	138	3	DUE TO SYSTEM CONDITION
10	JSW TO MSEDCL (300 MW)	9	40	300	210	90	AS PER MOD
		73	75	300	210	90	DUE TO SYSTEM CONDITION
11	TPC U-8	x	x	x	x	x	UNIT SHUT DOWN
12	TPC U-5	9	22	473	447	26	AS PER MOD
13	BHUSAWAL U4	9	13	376	322	54	DUE TO SYSTEM CONDITION
14	BHUSAWAL U-5	9	13	338	322	16	DUE TO SYSTEM CONDITION
15	REL GEN	9	13	240	190	50	DUE TO SYSTEM CONDITION
16	KHAPER KHEDA U 5	9	13	x	x	x	DECL BELOW TECH MIN
17	PARLY U-6	9	13	x	x	x	DECL TECH MIN
18	CHANDRAPUR	9	13	1251	1142	109	DUE TO SYSTEM CONDITION
19	PARLY U-7	9	13	x	x	x	DECL TECH MIN
20	INDIA BULL U1	x	x	x	x	x	UNIT SHUT DOWN
21	KHAPER KHEDA U 1 TO 4	9	13	297	284	13	DUE TO SYSTEM CONDITION
22	INDIA BULL U2	9	12	245	172	73	DUE TO SYSTEM CONDITION
23	PARAS -U3	9	12	x	x	x	DECL BELOW TECH MIN
24	ADANI U-1 AND U-4	9	12	x	x	x	DECL TECH MIN
25	PARAS U4	9	12	230	205	25	DUE TO SYSTEM CONDITION
26	JSW U-1	9	12	240	200	40	DUE TO SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-June-2014.